



Massachusetts Department of Environmental Protection - Drinking Water Program **PFAS**  
**Per- and Polyfluoroalkyl Substances (PFAS) Report**

Page 1 of 2

**I. PWS INFORMATION:** Please refer to your MassDEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #:  City / Town:   
 PWS Name:  PWS Class: COM  NTNC  TNC

MassDEP Location (LOC) ID#	MassDEP Location Name	Sample Information	Date Collected	Collected By
01S	Raw Water	<input type="checkbox"/> (M)ultiple <input checked="" type="checkbox"/> (R)aw <input checked="" type="checkbox"/> (S)ingle <input type="checkbox"/> (F)inished	01/26/2021	B. Cookerly
Routine or Special Sample <input checked="" type="checkbox"/> RS <input type="checkbox"/> SS		Original, Resubmitted or Confirmation Report <input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation		
		If Resubmitted Report, list below: (1) Reason for Resubmission: <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction (2) Collection Date of Original Sample:		
SAMPLE COMMENTS - Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection or if this is a field reagent blank				

**II. ANALYTICAL LABORATORY INFORMATION:**

Primary Lab Cert. #:  Primary Lab Name:  Subcontracted? (Y/N)   
 Analysis Lab Cert. #:  Analysis Lab Name:   
 If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#	
EPA 537.1	02/01/2021	02/02/2021		Primary Lab:	55311-01
				Subcontracted Lab:	4821576

CAS#	REGULATED PFAS CONTAMINANTS	Result <sup>1</sup> ng/L	Result <sup>2</sup> Qualifier	MCL* ng/L	MDL ng/L	MRL ng/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	8.7		-	2.0	2.0
335-67-1	Perfluorooctanoic Acid (PFOA)	5.5			2.0	2.0
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	2.6			2.0	2.0
375-95-1	Perfluorononanoic Acid (PFNA)	0.90	J		2.0	2.0
375-85-9	Perfluoroheptanoic Acid (PFHpA)	2.6			2.0	2.0
335-76-2	Perfluorodecanoic acid (PFDA)	<2.0			2.0	2.0
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA and PFDA; only include Results at or above the MRL; do not include estimated Results as described by a Result Qualifier in the next column)		= 19	-		20	-
UNREGULATED PFAS CONTAMINANTS						
375-73-5	Perfluorobutane sulfonic acid (PFBS)	2.4		-	2.0	2.0
307-55-1	Perfluorododecanoic acid (PFDoA)	<2.0			2.0	2.0
307-24-4	Perfluorohexanoic acid (PFHxA)	3.6			2.0	2.0
376-06-7	Perfluorotetradecanoic acid (PFTA)	<2.0			2.0	2.0
72629-94-8	Perfluorotridecanoic acid (PFTTrDA)	<2.0			2.0	2.0
2058-94-8	Perfluoroundecanoic acid (PFUnA)	<2.0			2.0	2.0
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NtEFOSAA)					
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)					
763051-92-9	11-chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)					
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9Cl-PF3ONS)					
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)					
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)					

<sup>1</sup> A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.  
<sup>2</sup> All qualifiers must be described under Lab Analysis Comments on page 2.