



CHEMICAL ADDITION REPORT - 310 CMR 22.15(4) Chemical Addition Reporting Requirements


I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.					
PWS Name¹:	Randolph-Holbrook Joint Water Treatment	Town¹:	Randolph	PWSID¹:	4244001
Treatment Plant Name²:	Randolph-Holbrook Joint Water Treatment Facility	Treatment Plant ID#²:	4244001	Reporting Period³:	Feb 2025 Month Year

II. Chemical & Operational Information					
Chemical Name⁴:	PolyAluminum Chloride - PolyAluminum Chloride	Purchased Strength (%)⁸:	33	Target Range/min¹²:	.02 - .05
Manufacturer⁵:	Holland Company	Purchased Density (lbs/gal)⁹:	10.59	Target Dose¹³:	17 - 28
Product Name⁶:	PCH-180	Dilution Factor or Mix Ratio¹⁰:	1	Alarm Setting (low)¹⁴:	NA
Reason for Adding Chemical⁷:	Coagulation	NSF Approved (Y/N)¹¹:	Y	Alarm Setting (high)¹⁴:	NA
				Date of last anti-siphon valve inspection/replacement¹⁵:	02/01/2025

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁶	Chemical Dosage (mg/L) ¹⁹	Parameters Measured*, Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²²
	<input type="checkbox"/> Gallons <input type="checkbox"/> MG	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)	a. UV at Settled Water <input type="checkbox"/> G <input type="checkbox"/> A			b. pH Grab at Settled Water <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A		
1	3,370,000	160.0			554.40	19.73				PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
2	3,425,000	140.0			485.10	16.98				
3	3,390,000	150.0			519.75	18.38				
4	3,185,000	132.0			457.38	17.22				
5	3,199,000	138.0			478.17	17.92				
6	3,163,000	168.0			582.12	22.07				
7	3,178,000	164.0			568.26	21.44				
8	3,215,000	158.0			547.47	20.42				
9	3,540,000	140.0			485.10	16.43				
10	2,615,000	110.0			381.15	17.48				
11	4,040,000	135.0			467.78	13.88				
12	4,068,000	128.0			443.52	13.07				
13	4,031,000	117.0			405.41	12.06				
14	4,046,000	158.0			547.47	16.22				
15	4,055,000	140.0			485.10	14.34				
16	4,075,000	140.0			485.10	14.27				
17	3,965,000	125.0			433.13	13.10				
18	3,580,000	105.0			363.83	12.19				
19	3,610,000	95.0			329.18	10.93				
20	3,558,000	137.0			474.71	16.00				
21	3,557,000	98.0			339.57	11.45				
22	3,625,000	115.0			398.48	13.18				
23	3,701,000	132.0			457.38	14.82				
24	3,754,000	154.0			533.61	17.04				
25	3,635,000	128.0			443.52	14.63				
26	3,732,000	109.0			377.69	12.13				
27	3,638,000	123.0			426.20	14.05				
28	3,580,000	112.0			388.08	13.00				
29										
30										
31										

Total	100,530,000	3,711.0	Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:			NA
--------------	-------------	---------	--	--	--	----

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.) ²⁰ .		I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge. PWS Authorized Person - Signature & Date ²⁴ :  03/25/2025
a.	Daily Ultra-Violet Grab Sample at Settled Water using ...	
b.	Daily pH Grab Sample at Settled Water using ...	
c.		Print Name: Louis Dutton Title: Primary Operator



CHEMICAL ADDITION REPORT - 310 CMR 22.15(4) Chemical Addition Reporting Requirements

I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.					
PWS Name¹:	Randolph-Holbrook Joint Water Treatment	Town¹:	Randolph	PWSID¹:	4244001
Treatment Plant Name²:	Randolph-Holbrook Joint Water Treatment Facility	Treatment Plant ID#²:	4244001	Reporting Period³:	Feb 2025 Month Year

II. Chemical & Operational Information					
Chemical Name⁴:	Hydrated Lime - Hydrated Lime	Purchased Strength (%)⁸:	93	Target Range/min¹²:	6.5 - 8.0
Manufacturer⁵:	Graymont, Inc.	Purchased Density (lbs/gal)⁹:	NA	Target Dose¹³:	3.0 - 6.0
Product Name⁶:	High Calcium Hydrated Lime	Dilution Factor or Mix Ratio¹⁰:	1	Alarm Setting (low)¹⁴:	6.0
Reason for Adding Chemical⁷:	pH Adjustment	NSF Approved (Y/N)¹¹:	Y	Alarm Setting (high)¹⁴:	8.5
			Date of last anti-siphon valve inspection/replacement¹⁵:	02/01/2025	

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁸	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured*, Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²² <small>PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.</small>		
	<input checked="" type="checkbox"/> Gallons <input type="checkbox"/> MG	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)	a. pH Average @ POE			b. pH Grab @ POE	c. pH Analyzer; SP at POE				
									<input checked="" type="checkbox"/> G <input type="checkbox"/> A		<input checked="" type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input checked="" type="checkbox"/> A
1	3,070,000		117.0	108.81	4.25	6.940	6.940					
2	3,090,000		117.0	108.81	4.22	6.860	6.860					
3	3,085,000		117.0	108.81	4.23	6.920	6.920					
4	2,965,000		117.0	108.81	4.40	6.970	6.970					
5	2,966,000		117.0	108.81	4.40	6.960	6.960					
6	2,969,000		117.0	108.81	4.39	6.830	6.830					
7	3,035,000		117.0	108.81	4.30	6.830	6.830					
8	3,200,000		117.0	108.81	4.08	6.850	6.850					
9	3,410,000		117.0	108.81	3.83	6.870	6.870					
10	2,075,000		117.0	108.81	6.29	6.980	6.980					
11	3,920,000		117.0	108.81	3.33	7.100	7.100					
12	3,955,000		117.0	108.81	3.30	7.170	7.170					
13	3,676,000		117.0	108.81	3.55	7.030	7.030					
14	3,539,000		117.0	108.81	3.69	7.190	7.190					
15	3,530,000		117.0	108.81	3.70	7.140	7.140					
16	3,585,000		114.0	106.02	3.55	7.160	7.160					
17	3,620,000		114.0	106.02	3.51	7.110	7.110					
18	3,635,000		114.0	106.02	3.50	7.280	7.280					
19	3,592,000		114.0	106.02	3.54	7.190	7.190					
20	3,591,000		114.0	106.02	3.54	7.187	7.170					
21	3,585,000		114.0	106.02	3.55	7.240	7.240					
22	3,582,000		114.0	106.02	3.55	7.210	7.210					
23	3,625,000		114.0	106.02	3.51	7.160	7.160					
24	3,695,000		114.0	106.02	3.44	7.190	7.190					
25	3,685,000		114.0	106.02	3.45	7.210	7.210					
26	3,592,000		114.0	106.02	3.54	7.220	7.220					
27	3,507,000		114.0	106.02	3.62	7.240	7.240					
28	3,466,000		114.0	106.02	3.67	7.000	7.000					
29												
30												
31												
Total	95,245,000		3,237.0			Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:			0			

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.) ²⁰ :		I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.	
a.	Average Grab sample finish water @ POE using pHep Hanna	PWS Authorized Person - Signature & Date ²⁴ :	
b.	Grab sample finish water @ POE using pHep Hanna		03/25/2025
c.	Single Point pH Analyzer collected at same time as Grab Sample	Print Name: Louis Dutton	Title: Primary Operator



CHEMICAL ADDITION REPORT - 310 CMR 22.15(4) Chemical Addition Reporting Requirements

I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.


PWS Name¹:	Randolph-Holbrook Joint Water Treatment	Town¹:	Randolph	PWSID¹:	4244001
Treatment Plant Name²:	Randolph-Holbrook Joint Water Treatment Facility	Treatment Plant ID#²:	4244001	Reporting Period³:	Feb 2025 Month Year

II. Chemical & Operational Information

Chemical Name⁴:	CP 767D - Corrosion Inhibitor	Purchased Strength (%)⁸:	75	Target Range/min¹²:	NA
Manufacturer⁵:	Sterling Water Technologies LLC	Purchased Density (lbs/gal)⁹:	NA	Target Dose¹³:	NA
Product Name⁶:	CP 767D	Dilution Factor or Mix Ratio¹⁰:	1	Alarm Setting (low)¹⁴:	NA
Reason for Adding Chemical⁷:	Corrosion Control	NSF Approved (Y/N)¹¹:	Y	Alarm Setting (high)¹⁴:	NA
		Date of last anti-siphon valve inspection/replacement¹⁵:	02/01/2075		

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶ <input type="checkbox"/> Gallons <input type="checkbox"/> MG	Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁸	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured*, Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²² PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
		Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a.	b.	c.	
						PO4 @ POE <input type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	
1	3,070,000		50.0	37.50	1.46				
2	3,090,000		50.0	37.50	1.46				
3	3,085,000		50.0	37.50	1.46				
4	2,965,000		50.0	37.50	1.52				
5	2,966,000		50.0	37.50	1.52				
6	2,969,000		50.0	37.50	1.51				
7	3,035,000		50.0	37.50	1.48				
8	3,200,000		50.0	37.50	1.41				
9	3,410,000		50.0	37.50	1.32				
10	2,075,000		50.0	37.50	2.17				
11	3,920,000		50.0	37.50	1.15				
12	3,955,000		50.0	37.50	1.14				
13	3,676,000		50.0	37.50	1.22				
14	3,539,000		50.0	37.50	1.27				
15	3,530,000		50.0	37.50	1.27				
16	3,585,000		50.0	37.50	1.25				
17	3,620,000		50.0	37.50	1.24				
18	3,635,000		50.0	37.50	1.24				
19	3,592,000		50.0	37.50	1.25				
20	3,591,000		50.0	37.50	1.25				
21	3,585,000		50.0	37.50	1.25				
22	3,582,000		50.0	37.50	1.26				
23	3,625,000		50.0	37.50	1.24				
24	3,695,000		50.0	37.50	1.22				
25	3,685,000		50.0	37.50	1.22				
26	3,592,000		50.0	37.50	1.25				
27	3,507,000		50.0	37.50	1.28				
28	3,466,000		50.0	37.50	1.30				
29									
30									
31									
Total	95,245,000		1,400.0			Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:			NA

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.) ²⁰ :		I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.	
a.	Daily Polyphosphate (PO4) Grab sample at POE	PWS Authorized Person - Signature & Date ²⁴ :  03/25/2025	
b.		Print Name: Louis Dutton	
c.		Title: Primary Operator	



Massachusetts Department of Environmental Protection - Drinking Water Program

CI

CHLORINE/CHLORAMINES - MONTHLY REPORT

I. PWS INFORMATION:

PWS ID #: 4244001 PWS Name: Randolph-Holbrook Joint Water Treatment City/Town: Class: COM [x] NTNC [] TNC []

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section.

Type Measured: [x] Free Chlorine [] Total Chlorine [] Combined Chlorine Analytical Method: SM 4500-Cl: [] D [] E [] F [x] G [] H [] I ASTM D1253-86 []

Notes:

Table with 7 columns: DEP Sample Type, DEP Location Code, DEP Approved Sample Location, Chlorine Result (mg/L), Date, Time, and Collected and Analyzed By. Contains 20 rows of data for various sample locations and dates.

1 DEP Sample Type, Location Code#, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan. 2 SWTR systems: HPC must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form. 3 Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record ND values as 0 (zero). 4 Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP). 5 All DISTRIBUTION samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month: 50 Average Chlorine Result of All Samples For Month (mg/L): 1.55

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature and Date: [Signature] 3-25-25

DEP Review Status: [] Accepted [] Disapproved Review Comments:



Massachusetts Department of Environmental Protection - Drinking Water Program
CHLORINE/CHLORAMINES - MONTHLY REPORT

CI

I. PWS INFORMATION:

PWS ID #: PWS Name: City/Town: Class: COM NTNC TNC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl: D E F G H I ASTM D1253-86

Notes:

DEP APPROVED SAMPLE SITE INFORMATION ¹			CHLORINE RESULT ² (mg/L)	COLLECTION AND ANALYSIS ³		COLLECTED AND ANALYZED BY:
DEP Sample Type ^{1,4}	DEP Location Code # ¹	DEP Approved SAMPLE LOCATION ¹		DATE	TIME	
RS	003	Tower Hill School - Adams St	1.57	2025-02-10	10:00	Brian Doran
RS	004	JFK School - 20 Hurley Drive	1.53	2025-02-10	08:00	Brian Doran
RS	005	Martin E. Young School Courtney Drive	1.45	2025-02-10	08:30	Brian Doran
RS	006	Comfort Inn - 1374 North Main Street	1.76	2025-02-10	11:00	Brian Doran
RS	008	Community Middle School - High Street	1.61	2025-02-10	10:30	Brian Doran
RS	011	Mobil Station - 93 Mazzeo Drive	1.59	2025-02-10	09:30	Brian Doran
RS	012	Williams Automotive - 685 North Street	1.13	2025-02-10	09:00	Brian Doran
RS	014	AXP Auto - 317 North Main Street	1.32	2025-02-10	07:30	Brian Doran
RS	016	Oak Grove Standpipe	1.31	2025-02-10	09:45	Brian Doran
RS	017	South Main Street Standpipe	1.62	2025-02-10	08:45	Brian Doran
RS	003	Tower Hill School - Adams St	1.27	2025-02-19	10:20	Brian Doran
RS	004	JFK School - 20 Hurley Drive	1.37	2025-02-19	19:30	Brian Doran
RS	005	Martin E. Young School Courtney Drive	1.26	2025-02-19	07:50	Brian Doran
RS	006	Comfort Inn - 1374 North Main Street	1.54	2025-02-19	10:45	Brian Doran
RS	008	Community Middle School - High Street	1.25	2025-02-19	11:05	Brian Doran
RS	011	Mobil Station - 93 Mazzeo Drive	.79	2025-02-19	09:30	Brian Doran
RS	012	Williams Automotive - 685 North Street	1.29	2025-02-19	08:40	Brian Doran
RS	014	AXP Auto - 317 North Main Street	1.51	2025-02-19	08:15	Brian Doran
RS	016	Oak Grove Standpipe	1.26	2025-02-19	09:50	Brian Doran
RS	017	South Main Street Standpipe	1.23	2025-02-19	08:30	Brian Doran

¹ DEP Sample Type, Location Code#, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan.
² SWTR systems: HPC must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form.
³ Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record ND values as 0 (zero).
⁴ Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP).
⁵ All **DISTRIBUTION** samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month⁵: Average Chlorine Result of All Samples For Month⁵ (mg/L):

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature and Date:  3-25-25

DEP Review Status: Accepted Disapproved Review Comments:



CHLORINE/CHLORAMINES - MONTHLY REPORT

I. PWS INFORMATION:

PWS ID #: 4244001 PWS Name: Randolph-Holbrook Joint Water Treatment City/Town: Class: COM [x] NTNC [] TNC []

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section.

Type Measured: [x] Free Chlorine [] Total Chlorine [] Combined Chlorine Analytical Method: SM 4500-Cl: [] D [] E [] F [x] G [] H [] I ASTM D1253-86 []

Notes:

Table with columns: DEP Sample Type, DEP Location Code#, DEP Approved Sample Location, Chlorine Result (mg/L), Date, Time, and Collected and Analyzed By. Contains 17 rows of data for various locations like Tower Hill School, JFK School, etc.

1 DEP Sample Type, Location Code#, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan. 2 SWTR systems: HPC must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form. 3 Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record ND values as 0 (zero). 4 Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP). 5 All DISTRIBUTION samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month: 50 Average Chlorine Result of All Samples For Month (mg/L): 1.55

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature and Date: [Signature]

DEP Review Status: [] Accepted [] Disapproved Review Comments:



CT Determination for Filtered Systems

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph-Holbrook Joint Water Treatment PWS Town: Randolph
Treatment Plant Name: Randolph-Holbrook Joint Water Treatment Facility Reporting Period -> Month: February Year: 2025
Disinfectant: Chlorine Gas Sequence of Application: 1st 2nd 3rd 4th 5 6th

II. DAILY REPORTING: All measurements taken during peak hourly flow.

Table with 10 columns: Day, Peak Hourly Flow (gpm), Disinfectant Concentration (mg/L), Disinfectant Contact Time (min.), CT calc (= C x T), pH, Water Temp (°C), CT 99.9, Inactivation Ratio (CT calc / CT 99.9), Inactivation Ratio < 1.0. Rows 1-31.

- 1. Use a separate form for each disinfectant/sampling point. Enter disinfectant and sequence position, e.g. "ozone/1st" or "ClO2/3rd".
2. Peak hourly flow means the highest pumpage hour during the day, not the absolute peak flow at any instant.
3. The residual disinfectant concentration(s) ("C") of the water before or at the first customer must be measured each day during peak hourly flow.
4. The disinfectant contact time(s) ("T") must be determined for each day during peak hourly flow.
5. If the system uses free chlorine, the pH of the disinfected water must be measured at least once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
6. The temperature of the disinfected water must be measured at least once per day at each residual disinfectant concentration sampling point during peak hourly flow.
7. Use Inactivation Tables at 310 CMR 22.20A Tables 1.1 - 1.6, 2.1 and/or 3.1
8. The inactivation ratio (CTcalc/CT99.9) is determined before or at the first customer during peak hourly flow and if the ratio is < 1.0, the 99.9% Giardia lamblia inactivation requirement has not been achieved.
9. A "Yes" response above indicates a SWTR Treatment Technique violation (Tier 2).

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: [Signature] Date: 03/19/2025 Title: Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



CT Determination for Filtered Systems

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph-Holbrook Joint Water Treatment PWS Town: Randolph
Treatment Plant Name: Randolph-Holbrook Joint Water Treatment Facility Reporting Period -> Month: February Year: 2025
Disinfectant: Chlorine Gas Sequence of Application: 1st 2nd 3rd 4th 5th 6th

II. DAILY REPORTING: All measurements taken during peak hourly flow.

Table with 10 columns: Day, Peak Hourly Flow (gpm), Disinfectant Concentration (mg/L), Disinfectant Contact Time (min.), CT calc (= C x T), pH, Water Temp (°C), CT 99.9, Inactivation Ratio (CT calc / CT 99.9), Inactivation Ratio < 1.0. Rows 1-31.

- 1. Use a separate form for each disinfectant/sampling point. Enter disinfectant and sequence position, e.g. "ozone/1st" or "ClO2/3rd".
2. Peak hourly flow means the highest pumpage hour during the day, not the absolute peak flow at any instant.
3. The residual disinfectant concentration(s) ("C") of the water before or at the first customer must be measured each day during peak hourly flow.
4. The disinfectant contact time(s) ("T") must be determined for each day during peak hourly flow.
5. If the system uses free chlorine, the pH of the disinfected water must be measured at least once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
6. The temperature of the disinfected water must be measured at least once per day at each residual disinfectant concentration sampling point during peak hourly flow.
7. Use Inactivation Tables at 310 CMR 22.20A Tables 1.1 - 1.6, 2.1 and/or 3.1
8. The inactivation ratio (CTcalc/CT99.9) is determined before or at the first customer during peak hourly flow and if the ratio is < 1.0, the 99.9% Giardia lamblia inactivation requirement has not been achieved.
9. A "Yes" response above indicates a SWTR Treatment Technique violation (Tier 2).

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: [Signature]

Date: 03/19/2025 Title: Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
J

(Page 2 of 2)

III. DAILY REPORTING¹:

Day	Filter Number: 1		Filter Number: 2		Filter Number: 3		Filter Number: 4	
	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.482	0.030	0.181	0.035	0.222	0.034	0.377	0.028
2	0.059	0.030	0.052	0.035	0.154		0.540	
3	0.107		0.212		0.210	0.037	0.334	0.031
4	0.037	0.032	0.350	0.036	0.225	0.039	0.450	0.031
5	0.069	0.034	0.233	0.040	0.152	0.038	0.460	0.032
6	0.058	0.034	0.227	0.038	0.242	0.038	0.325	
7	0.057	0.032	0.110		0.173		0.168	0.030
8	0.040		0.059	0.035	0.188	0.036	0.405	0.033
9	0.565	0.034	0.484	0.038	0.299	0.038	1.320	0.034
10	0.420	0.038	0.263	0.041	0.372	0.044	0.490	
11	0.316	0.052	0.816		0.374	0.046	0.475	0.033
12	0.232		0.292	0.046	0.287		0.410	0.237
13	0.322	0.050	0.180	0.046	0.065	0.044	0.294	
14	0.549		0.570	0.058	0.430	0.054	0.460	0.154
15	0.330	0.063	0.100		0.085	0.039	0.386	0.038
16	0.287	0.034	0.148	0.046	0.184	0.039	0.411	0.037
17	0.126	0.043	0.140	0.052	0.200	0.047	0.464	
18	0.182	0.052	0.530		0.157		0.183	0.049
19	0.248		0.204	0.061	0.323	0.054	0.330	0.052
20	0.057	0.049	0.309	0.050	0.196	0.041	0.403	0.037
21	0.135	0.041	0.116	0.053	0.250	0.047	0.326	
22	0.157	0.042	0.146		0.246		0.226	0.040
23	0.194		0.150	0.053	0.540	0.048	0.287	0.047
24	0.380	0.036	0.191	0.050	0.049	0.047	0.470	0.041
25	0.349	0.044	0.174	0.053	0.189	0.049	0.358	
26	0.224	0.043	0.244		0.293		0.350	0.052
27	0.139		0.139	0.053	0.350	0.042	0.470	0.041
28	0.128	0.034	0.193	0.050	0.226	0.048	0.344	0.044
29								
30								
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: _____

Date: 03/19/2025

Title: _____

[Signature]
 Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
J


(Page 2 of 2)

III. DAILY REPORTING¹:

Day	Filter Number: 1		Filter Number: 2		Filter Number: 3		Filter Number: 4	
	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.482	0.030	0.181	0.035	0.222	0.034	0.377	0.028
2	0.059	0.030	0.052	0.035	0.154		0.540	
3	0.107		0.212		0.210	0.037	0.334	0.031
4	0.037	0.032	0.350	0.036	0.225	0.039	0.450	0.031
5	0.069	0.034	0.233	0.040	0.152	0.038	0.460	0.032
6	0.058	0.034	0.227	0.038	0.242	0.038	0.325	
7	0.057	0.032	0.110		0.173		0.168	0.030
8	0.040		0.059	0.035	0.188	0.036	0.405	0.033
9	0.565	0.034	0.484	0.038	0.299	0.038	1.320	0.034
10	0.420	0.038	0.263	0.041	0.372	0.044	0.490	
11	0.316	0.052	0.816		0.374	0.046	0.475	0.033
12	0.232		0.292	0.046	0.287		0.410	0.237
13	0.322	0.050	0.180	0.046	0.065	0.044	0.294	
14	0.549		0.570	0.058	0.430	0.054	0.460	0.154
15	0.330	0.063	0.100		0.085	0.039	0.386	0.038
16	0.287	0.034	0.148	0.046	0.184	0.039	0.411	0.037
17	0.126	0.043	0.140	0.052	0.200	0.047	0.464	
18	0.182	0.052	0.530		0.157		0.183	0.049
19	0.248		0.204	0.061	0.323	0.054	0.330	0.052
20	0.057	0.049	0.309	0.050	0.196	0.041	0.403	0.037
21	0.135	0.041	0.116	0.053	0.250	0.047	0.326	
22	0.157	0.042	0.146		0.246		0.226	0.040
23	0.194		0.150	0.053	0.540	0.048	0.287	0.047
24	0.380	0.036	0.191	0.050	0.049	0.047	0.470	0.041
25	0.349	0.044	0.174	0.053	0.189	0.049	0.358	
26	0.224	0.043	0.244		0.293		0.350	0.052
27	0.139		0.139	0.053	0.350	0.042	0.470	0.041
28	0.128	0.034	0.193	0.050	0.226	0.048	0.344	0.044
29								
30								
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: 

Date: 03/19/2025

Title: Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
For Conventional or Direct Filtered Systems

SWTR
J

(Page 2 of 2)

III. DAILY REPORTING¹:

Day	Filter Number: 5		Filter Number: 6		Filter Number: 7		Filter Number: 8	
	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.052		0.274		0.040		0.190	0.057
2	0.029	0.028	0.295	0.035	0.185	0.037	0.236	0.056
3	0.119	0.034	0.452	0.040	0.107	0.042	0.177	0.065
4	0.251	0.031	0.460	0.039	0.302	0.041	0.085	
5	0.164	0.030	0.298		0.075		0.062	0.061
6	0.087		0.131	0.038	0.186	0.038	0.134	0.062
7	0.088	0.031	0.151	0.035	0.280	0.036	0.320	0.060
8	0.240	0.030	0.407	0.036	0.092	0.037	0.195	
9	0.159	0.033	0.663		0.039		2.090	0.063
10	0.271		0.518	0.047	0.450	0.039	0.436	0.069
11	0.800		0.525	0.050	0.193		0.490	0.071
12	0.143	0.039	0.323	0.049	0.570	0.049	0.340	0.079
13	0.214	0.046	0.230	0.055	0.049		0.238	
14	0.059		0.144	0.058	0.156	0.059	0.628	0.263
15	0.304	0.084	0.255	0.045	0.085	0.046	0.153	
16	0.083	0.039	0.219		0.045		0.107	0.077
17	0.064		0.242	0.049	0.380	0.051	0.318	0.086
18	0.279	0.050	0.390	0.060	0.173	0.067	0.225	0.098
19	0.347	0.056	0.628	0.062	0.205	0.060	0.270	
20	0.062	0.037	0.163		0.059		0.095	0.094
21	0.078		0.472	0.044	0.114	0.049	0.146	0.086
22	0.088	0.041	0.284	0.051	0.102	0.056	0.103	0.091
23	0.153	0.046	0.500	0.046	0.096	0.047	0.268	
24	0.084	0.038	0.262		0.049		0.128	0.084
25	0.229		0.568	0.044	0.102	0.048	0.216	0.091
26	0.301	0.291	0.496	0.052	0.130	0.056	0.197	0.095
27	0.225	0.043	0.367	0.050	0.068	0.051	0.202	
28	0.085	0.040	0.251		0.051		0.095	0.092
29								
30								
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: _____

Date: 03/19/2025

Title: _____

[Signature]
Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
J

(Page 2 of 2)

III. DAILY REPORTING¹:

Day	Filter Number: 5		Filter Number: 6		Filter Number: 7		Filter Number: 8	
	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.052		0.274		0.040		0.190	0.057
2	0.029	0.028	0.295	0.035	0.185	0.037	0.236	0.056
3	0.119	0.034	0.452	0.040	0.107	0.042	0.177	0.065
4	0.251	0.031	0.460	0.039	0.302	0.041	0.085	
5	0.164	0.030	0.298		0.075		0.062	0.061
6	0.087		0.131	0.038	0.186	0.038	0.134	0.062
7	0.088	0.031	0.151	0.035	0.280	0.036	0.320	0.060
8	0.240	0.030	0.407	0.036	0.092	0.037	0.195	
9	0.159	0.033	0.663		0.039		2.090	0.063
10	0.271		0.518	0.047	0.450	0.039	0.436	0.069
11	0.800		0.525	0.050	0.193		0.490	0.071
12	0.143	0.039	0.323	0.049	0.570	0.049	0.340	0.079
13	0.214	0.046	0.230	0.055	0.049		0.238	
14	0.059		0.144	0.058	0.156	0.059	0.628	0.263
15	0.304	0.084	0.255	0.045	0.085	0.046	0.153	
16	0.083	0.039	0.219		0.045		0.107	0.077
17	0.064		0.242	0.049	0.380	0.051	0.318	0.086
18	0.279	0.050	0.390	0.060	0.173	0.067	0.225	0.098
19	0.347	0.056	0.628	0.062	0.205	0.060	0.270	
20	0.062	0.037	0.163		0.059		0.095	0.094
21	0.078		0.472	0.044	0.114	0.049	0.146	0.086
22	0.088	0.041	0.284	0.051	0.102	0.056	0.103	0.091
23	0.153	0.046	0.500	0.046	0.096	0.047	0.268	
24	0.084	0.038	0.262		0.049		0.128	0.084
25	0.229		0.568	0.044	0.102	0.048	0.216	0.091
26	0.301	0.291	0.496	0.052	0.130	0.056	0.197	0.095
27	0.225	0.043	0.367	0.050	0.068	0.051	0.202	
28	0.085	0.040	0.251		0.051		0.095	0.092
29								
30								
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: _____

Date: 03/19/2025

Title: _____

[Signature]
 Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, *TWO* copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



TURBIDITY DATA SHEET FOR FILTERED SYSTEMS

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph-Holbrook Joint Water Treatment PWS Town: Randolph
Treatment Plant Name: Randolph-Holbrook Joint Water Treatment Facility - WTF RHJ - Combined Filter Effluent Reporting Period → Month: February Year: 2025

II. DAILY REPORTING:

Filtered Water Turbidity Measured: (check only one) Combined Filter Effluent Individual Filter Effluent¹ Clearwell Plant Effluent

Filtration Technology: Conventional Direct Alternative Slow Sand Diatomaceous Earth
Monthly Turbidity (95%) NTU Limit = 0.3 Max Day Turbidity NTU Limit = 1
Monthly Turbidity (95%) NTU Limit = 1 Max Day Turbidity NTU Limit = 5

Day	Max Filtered Water Turbidity Result ² (NTU)	Number of Turbidity Measurements ³	Number of Turbidity Measurements ≤ Monthly (95%) NTU Limit ⁴	Number of Turbidity Measurements > Max Day NTU Limit ⁵
1	0.13	95	95	0
2	0.14	96	96	0
3	0.19	96	96	0
4	0.18	96	96	0
5	0.11	96	96	0
6	0.14	96	96	0
7	0.11	96	96	0
8	0.06	96	96	0
9	0.50	96	94	0
10	0.36	96	95	0
11	0.78	96	88	0
12	0.37	96	95	0
13	0.16	96	96	0
14	0.22	96	96	0
15	0.09	96	96	0
16	0.19	96	96	0
17	0.16	96	96	0
18	0.22	96	96	0
19	0.19	96	96	0
20	0.22	96	96	0
21	0.21	96	96	0
22	0.15	96	96	0
23	0.15	96	96	0
24	0.19	96	96	0
25	0.18	96	96	0
26	0.22	96	96	0
27	0.13	96	96	0
28	0.19	96	96	0
29				
30				
31				
Totals:		2687 A	2675 B	% Turbidity Meeting 95% Limit B/A x 100 % = X (Enter on SWTR - Form G)

- 1. May be used by systems serving less than 10,000 persons, subject to DEP approval.
- 2. Enter the Maximum Filtered Water Turbidity Result recorded each day, at the 4th hour or other approved interval.
- 3. Enter the Total # of Turbidity measurements taken for each day. Measurements must be taken at a minimum of 4-hour intervals (i.e. 6 readings per day). For continuous monitors count each 4-hour period as 1 measurement. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. If DEP approved, 15-minute readings (i.e. 96 readings per day) may be submitted. Filtered turbidity data must be kept on file for DEP review.
- 4. Out of the # of turbidity measurements taken and recorded in the previous column, enter the number of turbidity measurements that were less than or equal to the Monthly (95%) NTU Limit for the filtration technology used.
- 5. If at any time the filtered turbidity Max Day NTU Limit is exceeded, the DEP must be notified no later than the end of the next business day. For each exceedance, record the turbidity value(s) and date(s) on SWTR - Form G

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: [Signature] Date: 03/19/2025 Title: PRIMARY OPERATOR

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



TURBIDITY DATA SHEET FOR FILTERED SYSTEMS

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph-Holbrook Joint Water Treatment PWS Town: Randolph
Treatment Plant Name: Randolph-Holbrook Joint Water Treatment Facility - WTF RHJ - Combined Filter Effluent Reporting Period → Month: February Year: 2025

II. DAILY REPORTING:

Filtered Water Turbidity Measured: (check only one) Combined Filter Effluent Individual Filter Effluent¹ Clearwell Plant Effluent
Filtration Technology: Conventional Direct Alternative Slow Sand Diatomaceous Earth
Monthly Turbidity (95%) NTU Limit = 0.3 Max Day Turbidity NTU Limit = 1
Monthly Turbidity (95%) NTU Limit = 1 Max Day Turbidity NTU Limit = 5

Day	Max Filtered Water Turbidity Result ² (NTU)	Number of Turbidity Measurements ³	Number of Turbidity Measurements ≤ Monthly (95%) NTU Limit ⁴	Number of Turbidity Measurements > Max Day NTU Limit ⁵
1	0.13	95	95	0
2	0.14	96	96	0
3	0.19	96	96	0
4	0.18	96	96	0
5	0.11	96	96	0
6	0.14	96	96	0
7	0.11	96	96	0
8	0.06	96	96	0
9	0.50	96	94	0
10	0.36	96	95	0
11	0.78	96	88	0
12	0.37	96	95	0
13	0.16	96	96	0
14	0.22	96	96	0
15	0.09	96	96	0
16	0.19	96	96	0
17	0.16	96	96	0
18	0.22	96	96	0
19	0.19	96	96	0
20	0.22	96	96	0
21	0.21	96	96	0
22	0.15	96	96	0
23	0.15	96	96	0
24	0.19	96	96	0
25	0.18	96	96	0
26	0.22	96	96	0
27	0.13	96	96	0
28	0.19	96	96	0
29				
30				
31				
Totals:		2687 A	2675 B	% Turbidity Meeting 95% Limit B/A x 100 % = X (Enter on SWTR - Form G)

- 1. May be used by systems serving less than 10,000 persons, subject to DEP approval.
- 2. Enter the Maximum Filtered Water Turbidity Result recorded each day, at the 4th hour or other approved interval.
- 3. Enter the Total # of Turbidity measurements taken for each day. Measurements must be taken at a minimum of 4-hour intervals (i.e. 6 readings per day). For continuous monitors count each 4-hour period as 1 measurement. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. If DEP approved, 15-minute readings (i.e. 96 readings per day) may be submitted. Filtered turbidity data must be kept on file for DEP review.
- 4. Out of the # of turbidity measurements taken and recorded in the previous column, enter the number of turbidity measurements that were less than or equal to the Monthly (95%) NTU Limit for the filtration technology used.
- 5. If at any time the filtered turbidity Max Day NTU Limit is exceeded, the DEP must be notified no later than the end of the next business day. For each exceedance, record the turbidity value(s) and date(s) on SWTR - Form G

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: [Signature] Date: 03/19/2025 Title: Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Total Organic Carbon (TOC) Report doc rev 12/2020

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: 4244001 City / Town: RANDOLPH
PWS Name: RANDOLPH HOLBROOK WATER BOARD PWS Class: COM [x] NTNC [] TNC []

Table with columns: DEP LOCATION (LOC) ID#, DEP Location Name, Sample Information, Date Collected, Collected By. Includes rows for Great Pond WTP - Raw Water and Combined Filter Effluent.

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab MA Cert. #: M-MA022 Primary Lab Name: Analytical Balance Subcontracted?(Y/N) Y
Analysis Lab MA Cert. #: M-RI002 Analysis Lab Name: ESS Laboratory

Table for TOC Analyzed by (check one): PWS or Lab, Samples Acidified? Yes or No. Columns include TOC Result (mg/L), MDL, MRL, Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

Surface or GWUDI systems >= 500 persons. Monthly source (raw) water TOC sampling is required at each surface/GWUDI source to qualify for and remain on reduced THM/HAA5 monitoring.

Surface or GWUDI sources using conventional filtration shall each month (unless monitoring is reduced): take one TOC sample at each treatment plant no later than the point of combined filter effluent turbidity monitoring representative of the treated (finished) water, one TOC source (raw) sample prior to any treatment, and one alkalinity source (raw) water sample - at a time representative

Table for Alkalinity Analyzed by (check one): PWS or Lab. Columns include Alkalinity Result (mg/L as CaCO3), MDL, MRL, Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

If using conventional filtration - Raw water alkalinity must be measured at the same time as the raw water TOC sample is collected. Alkalinity analysis does not require the use of a Massachusetts or EPA certified laboratory

Table for LAB SAMPLE COMMENTS. Columns include LAB SAMPLE COMMENTS, Result Qualifier, Result Qualifier Description.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator or Primary Lab Director Signature: Laurel Stoddard Date: 2/10/2025

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the

DEP REVIEW STATUS (Initial & Date) [] Accepted [] Disapproved Review Comments [] WQTS Data Entered



Total Organic Carbon (TOC) Report doc rev 12/2020

PWS ID #: 4244001

City / Town: RANDOLPH

PWS Name: RANDOLPH HOLBROOK WATER BOARD

PWS Class: COM [x] NTNC [] TNC []

Table with columns: DEP LOCATION (LOC) ID#, DEP Location Name, Sample information, Date Collected, Collected By. Rows A and B.

Table for Resubmitted Report with columns: Routine or Special Sample, Original, Resubmitted or Confirmation Report, (1) Reason for Resubmission, (2) Collection Date of Original Sample.

SAMPLE NOTES table with rows A and B.

Primary Lab MA Cert. #: M-MA022
Analysis Lab MA Cert. #: M-R1002

Primary Lab Name: Analytical Excellence
Analysis Lab Name: ESS Laboratory

Subcontracted?(Y/N) Y

TOC Analyzed by (check one): [] PWS or [x] Lab Samples Acidified? [x] Yes or [] No

Table with columns: TOC Result (mg/L), Result Qualifier, MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

Surface or GWUDI systems >= 500 persons. Monthly source (raw) water TOC sampling is required at each surface/GWUDI source to qualify for and remain on reduced THM/HAA5 monitoring.

Surface or GWUDI sources using conventional filtration shall each month (unless monitoring is reduced): take one TOC sample at each treatment plant no later than the point of combined filter effluent turbidity monitoring representative of the treated (finished) water, one TOC source (raw) sample prior to any treatment, and one alkalinity source (raw) water sample - at a time representative

Alkalinity Analyzed by (check one): [] PWS or [x] Lab

Table with columns: ALKALINITY Result (mg/L as CaCO3), Result Qualifier, MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

If using conventional filtration - Raw water alkalinity must be measured at the same time as the raw water TOC sample is collected. Alkalinity analysis does not require the use of a Massachusetts or EPA certified laboratory

Table with columns: LAB SAMPLE COMMENTS, Result Qualifier, Result Qualifier Description. Rows A and B.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator or Primary Lab Director Signature: Laurel Stoddard
Date: 2/10/2025

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner.

Table with columns: DEP REVIEW STATUS (Initial & Date), Review Comments, Entered.

**MASSACHUSETTS DEP/DRINKING WATER PROGRAM
ALTERNATIVE COMPLIANCE RESULTS**

**DOC
UV254**

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule to help complete this section

1. PWS ID #: 2. City / Town:
 3. PWS Name: 4. PWS Class: COM NTNC
 5. DEP Source Code/Location ID 6. Sample Location 7. Date Collected 8. Time Collected¹ 9. Collected By
 Treated:

¹ Time between collection of raw and treated water must not exceed the time it takes the water to move through the plant.

Notes: _____

II. LABORATORY ANALYTICAL INFORMATION:

Analyzed By: Lab Cert. #:
 Subcontracted? (Y/N) Y
 Sub. Lab Name: Sub. Cert. #:

Notes: UV254 Analyzed by ESS Laboratory M-R1002

$B / A \times 100 = C$	Treated Water DOC A	UV254 B	SUVA C
Result mg/L	3.0	.064	2.1
Analytical Method	SM 5310B	5910B	
Detection Limit mg/L	0.5	0.002	
Date Analyzed	2/04/25	2/04/25	
Lab Sample ID#	A5B0031-02		

I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Primary Certified Operator or Laboratory Director Signature and Date: _____

 3-25-25

Attention: Mail TWO copies of this report to your DEP Regional Office within 30 days of receipt of result and no later than 10 days after the end of the reporting period.

FOR DEP/DWP USE ONLY: PLEASE INITIAL AND DATE AS COMPLETED

Accepted:	Disapproved:	Data Entered into WQTS:
Comments:		

**MASSACHUSETTS DEP/DRINKING WATER PROGRAM
ALTERNATIVE COMPLIANCE RESULTS**

**DOC
UV254**

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule to help complete this section

1. PWS ID #: 2. City / Town:
 3. PWS Name: 4. PWS Class: COM NTNC
 5. DEP Source Code/Location ID 6. Sample Location 7. Date Collected 8. Time Collected¹ 9. Collected By
 Treated:

¹ Time between collection of raw and treated water must not exceed the time it takes the water to move through the plant.

Notes: _____


II. LABORATORY ANALYTICAL INFORMATION:

Analyzed By: Lab Cert. #:
 Subcontracted? (Y/N) Y
 Sub. Lab Name: Sub. Cert. #:

Notes: UV254 Analyzed by ESS Laboratory M-R1002

$B / A \times 100 = C$	Treated Water DOC A	UV254 B	SUVA C
Result mg/L	3.0	.064	2.1
Analytical Method	SM 5310B	5910B	
Detection Limit mg/L	0.5	0.002	
Date Analyzed	2/04/25	2/04/25	
Lab Sample ID#	A5B0031-02		

I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Primary Certified Operator or Laboratory Director Signature and Date:  3-25-25

Attention: Mail TWO copies of this report to your DEP Regional Office within 30 days of receipt of result and no later than 10 days after the end of the reporting period.

FOR DEP/DWP USE ONLY: PLEASE INITIAL AND DATE AS COMPLETED

Accepted:	Disapproved:	Data Entered into WQTS:
Comments:		



DBPR TT Compliance Report

I. PWS INFORMATION:

PWS ID #: 4244001 City / Town: Randolph
 PWS Name: Randolph Holbrook Water Joint Board PWS Class: COM NTNC NC

DEP LOCATION (LOC) ID#	DEP Location Name	Date Collected	Collected By
10300	Wtp Combined Filter Effluent	2/3/2025	P. Hennessy
SAMPLE NOTES			

II. COMPLIANCE CALCULATIONS:

Month (mm/yy)	# of Paired Samples	A: % Removal of TOC ¹	B: Required % of TOC ²	Met Alternative Compliance Criteria	Alternative Criteria Result(s) ³ (See Below)	A ÷ B ⁴
Mar-24	1	40	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.38	1.00
Apr-24	1	51	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	2.97	1.13
May-24	1	42	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.06	1.00
Jun-24	1	45	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.9	1.00
Jul-24	1	38	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.53	1.00
Aug-24	1	34	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.45	1.00
Sep-24	1	36	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.58	1.00
Oct-24	1	31	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	0.939	1.00
Nov-24	1	35	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	0.916	1.00
Dec-24	1	42	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	1.88	1.00
Jan-25	1	43	45.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	2.21	1.00
Feb-25	1	40	56.0	<input type="checkbox"/> YES <input type="checkbox"/> NO	2.1	1.00
Sum of Past 12 Months:						12.13
Compliance Value (Sum of Past 12 Months/ 12):						1.01

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: [Signature]
 Date: 3-25-25

In accordance with 310 CMR 22.15(2), if mailing paper reports, ONE copy of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.

¹ Percent Removal: $(1 - (\text{Treated Water TOC} / \text{Raw Water TOC})) \times 100$. If > 1 paired sample sets in any month report the average of all individual percent TOC removals (Example: % TOC Removal = (Average of Set 1 + Average of Set 2) / 2).

² From table at 310 CMR 22.07E(10)(b)2.

³ As listed at 310 CMR 22.07E(10)(a)2 and 310 CMR 22.07E(10)(a)3, summarized as follows:

Alternative Compliance Criteria	Code Value	Result(s) to Report (RAA = Running Annual Average)
Source Water TOC <2.0 mg/L	SWTOC	RAA of source water TOC
Treated Water <2.0 mg/L	TWTOC	RAA of treated water TOC
Source Water TOC < 4.0 mg/L AND Alkalinity >60 mg/L (as CaCO ₃) AND TTHM/HAA5 ≤ 0.040/0.030 mg/L	COMBO	RAA of source water TOC, RAA of source water alkalinity, RAA of TTHM and HAA5
TTHM/HAA5 ≤ 0.040/0.030 mg/L AND only using chlorine	TTHM/HAA5	RAA of TTHM and HAA5
Source Water SUVA ≤ 2.0 L/mg-m	SWSUVA	RAA of treated water SUVA
Treated Water SUVA ≤ 2.0 L/mg-m	TWSUVA	RAA of treated water SUVA
Softening that lowers alkalinity to < 60 mg/L (as CaCO ₃)	SOFT60	RAA of treated water alkalinity
Softening that removes ≥ 10 mg/L (as CaCO ₃) of hardness	SOFT10	RAA of hardness (as CaCO ₃) removal


Note: All supplemental measurements and calculations used to meet the alternative criteria must be attached to this report.

⁴ For any month where the system met an alternative compliance criteria a value of 1.0 may be inserted.

DEP REVIEW STATUS (Initial & Date)	Review Comments
Accepted _____ Disapproved _____	



CHEMICAL ADDITION REPORT - 310 CMR 22.15(4) Chemical Addition Reporting Requirements

I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.												
PWS Name ¹ : Randolph-Holbrook Joint Water Treatment				Town ¹ : Randolph		PWSID ¹ : 4244001						
Treatment Plant Name ² : Randolph-Holbrook Joint Water Treatment Facility				Treatment Plant ID# ² : 4244001		Reporting Period ³ : Feb 2025		Month: Feb Year: 2025				
II. Chemical & Operational Information												
Chemical Name ⁴ : Chlorine Gas - Chlorine				Purchased Strength (%) ⁸ : 100		Target Range/min ¹² : 1.2 - 2.5						
Manufacturer ⁵ : Jones Chemical				Purchased Density (lbs/gal) ⁹ : NA		Target Dose ¹³ : 1.2 - 2.5						
Product Name ⁶ : Chlorine (Gaseous) - Cl ₂				Dilution Factor or Mix Ratio ¹⁰ : 1		Alarm Setting (low) ¹⁴ : 1.0						
Reason for Adding Chemical ⁷ : Disinfection				NSF Approved (Y/N) ¹¹ : Y		Alarm Setting (high) ¹⁴ : 2.7						
				Date of last anti-siphon valve inspection/replacement ¹⁵ : 02/01/2025								
III. Daily Reporting												
Note: Water quality data reported on C-ADD form may be considered for compliance purposes.												
Day	Treated Water ¹⁶ <input type="checkbox"/> Gallons <input type="checkbox"/> MG	Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁵	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured*, Results, Units and Method ²⁰ - (G) Grab or Continuous (A) Analyzer ²¹			O&M Notes/Comments ²² PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.			
		Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. Cl ₂ (Free) Average @ POE		b. Cl ₂ (Free) @ POE		c. Cl ₂ (Free) Analyzer, SP @ POE		
						<input type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A		<input type="checkbox"/> G <input type="checkbox"/> A		
1	3,070,000		98.0	98.00	3.83	2.233	2.160					
2	3,090,000		101.0	101.00	3.92	2.469	2.400					
3	3,085,000		99.0	99.00	3.85	2.313	2.090					
4	2,965,000		97.0	97.00	3.92	2.208	2.300					
5	2,966,000		96.0	96.00	3.88	2.193	2.130					
6	2,969,000		98.0	98.00	3.96	2.251	2.240					
7	3,035,000		96.0	96.00	3.79	2.233	2.350					
8	3,200,000		100.0	100.00	3.75	2.330	2.380					
9	3,410,000		101.0	101.00	3.55	2.239	2.080					
10	2,075,000		114.0	114.00	6.59	2.383	2.380					
11	3,920,000		71.0	71.00	2.17	2.524	2.290					
12	3,955,000		110.0	110.00	3.33	2.470	2.130					
13	3,676,000		126.0	126.00	4.11	2.259	2.230					
14	3,539,000		114.0	114.00	3.86	2.061	2.190					
15	3,530,000		110.0	110.00	3.74	2.195	2.050					
16	3,585,000		106.0	106.00	3.55	2.153	2.210					
17	3,620,000		104.0	104.00	3.44	2.096	2.000					
18	3,635,000		105.0	105.00	3.46	2.040	2.000					
19	3,592,000		108.0	108.00	3.61	2.020	1.890					
20	3,591,000		111.0	111.00	3.71	2.078	2.000					
21	3,585,000		110.0	110.00	3.68	2.157	2.200					
22	3,582,000		109.0	109.00	3.65	2.258	2.360					
23	3,625,000		105.0	105.00	3.47	2.137	2.170					
24	3,695,000		102.0	102.00	3.31	2.216	2.260					
25	3,685,000		112.0	112.00	3.64	2.215	2.150					
26	3,592,000		109.0	109.00	3.64	2.236	2.140					
27	3,507,000		115.0	115.00	3.93	2.174	2.100					
28	3,466,000		102.0	102.00	3.53	2.129	2.130					
29												
30												
31												
Total		95,245,000		2,929.0	Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ : 1							
*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.) ²⁰ :						I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.						
a. Cl ₂ (Free) Average Grab Samples @ POE using DR 3900						PWS Authorized Person - Signature & Date ²⁴ :  03/25/2025						
b. Daily Cl ₂ (Free) Grab Sample @ POE using DR 3900						Print Name: Louis Dutton						
c. Single Point Cl ₂ (Free) Analyzer collected at same time as Grab Sample						Title: Primary Operator						



Compliance Determination for Filtered Systems - Monthly Report

I. PWS INFORMATION:

PWSID#: PWS Name: PWS Town:

Treatment Plant Name: Reporting Period → Month: Year:

II. TURBIDITY PERFORMANCE CRITERIA:

1. **Monthly Turbidity (95%) NTU Limit** - The turbidity level of a system's filtered water must be less than or equal to the Monthly Turbidity NTU Limit in at least 95% of the measurements taken each month for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

2687	= A	Total # of filtered water turbidity measurements for month (SWTR - Form F)
2675	= B	Total # of filtered water turbidity measurements less than or equal to the specified limits for the filtration technology used. (SWTR - Form F)
99.553	= (B / A) x 100	The percentage of turbidity measurements meeting the Monthly Turbidity 95% NTU Limit.

2. **Max Day NTU Limit** - The turbidity level of a system's filtered water must at no time exceed the Max Day NTU Limit for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

Record the date and turbidity value for any measurements exceeding the Max Day NTU. Check box if "None"

Date	Value	Date Reported to DEP	Date	Value	Date Reported to DEP

For each day the Max Day NTU limit is exceeded, the DEP must be notified by the end of the next business day. SWTR TT Violation (Tier 2). If DEP is not consulted within 24 hours then it is a SWTR TT (Tier 1) violation requiring public notification within 24 hours.

III. DISINFECTION PERFORMANCE CRITERIA:

1. **Point-of-Entry Minimum Disinfectant Residual Criteria** - Residual Disinfectant concentration cannot be < 0.2 mg/L for more than 4 hours. SWTR TT Violation (Tier 2).

Minimum Disinfectant Residual at Point-of-Entry to Distribution System

Day	Cl ₂ mg/l												
1	2.070	6	2.110	11	2.290	16	2.060	21	2.020	26	2.050	31	
2	2.250	7	1.890	12	2.020	17	1.820	22	2.170	27	1.820		Residual Measured <input checked="" type="checkbox"/> Free Cl ₂ <input type="checkbox"/> Total Cl ₂ <input type="checkbox"/> Combined Cl ₂
3	2.080	8	2.060	13	1.960	18	1.520	23	1.920	28	2.020		
4	1.970	9	1.930	14	1.450	19	1.860	24	2.080	29			
5	2.040	10	1.720	15	1.930	20	1.960	25	2.040	30			

If at any time the residual falls below 0.2 mg/l in the water entering the distribution system, the supplier of water must notify the Department as soon as possible, but no later than by the end of the next business day. The supplier of water also must notify the Department by the end of the next business day whether or not the residual was restored to at least 0.2 mg/l within four hours.

Date(s) Residual < 0.2 mg/l	Duration of Low Level (hrs.)	Date Reported to DEP	Date(s) Residual < 0.2 mg/l	Duration of Low Level (hrs.)	Date Reported to DEP

2. **Distribution System Disinfectant Residual Criteria** - Residual Disinfectant concentration (V) cannot be undetectable in greater than 5% of samples in a month, for any two consecutive months. SWTR TT Violation (Tier 2). Chlorine residuals must be measured at the same time and location as total coliform *distribution routine & repeat* samples. If no residual is detected, an HPC sample must be collected and analyzed.

Total # of HPC samples taken during month: # HPC sites > 500/mL: # HPC sites ≤ 500/mL:

50	= a	# of sites where Cl ₂ residual measurements were made, whether a residual was detected or not (should be the same # of sites reported on your monthly DBPR Cl ₂ residual report)
0	= b	# of sites HPC samples were analyzed <i>instead of</i> Cl ₂ residual measurements
0	= c	# of sites where no Cl ₂ residual was detected and no HPC sample was analyzed
0	= d	# of sites where no Cl ₂ residual was detected and HPC > 500 CFU/mL
0	= e	# of sites where no Cl ₂ residual measurement was made and HPC > 500 CFU/mL

Water in the distribution system with a heterotrophic bacteria concentration (HPC) less than or equal to 500/mL, is deemed to have a detectable disinfectant residual for purposes of determining compliance with this requirement. When analyzed, report HPC results on your monthly DEP Bacteriological Report.

V = $\frac{(c + d + e)}{(a + b)} \times 100$ This Month % V = Previous Month % V = Is V > 5% for 2 months? Yes or No

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: Date: 03/25/2025 Title: Primary Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Compliance Determination for Filtered Systems - Monthly Report

I. PWS INFORMATION:

PWSID#: PWS Name: PWS Town:

Treatment Plant Name: Reporting Period → Month: Year:

II. TURBIDITY PERFORMANCE CRITERIA:

1. **Monthly Turbidity (95%) NTU Limit** - The turbidity level of a system's filtered water must be less than or equal to the Monthly Turbidity NTU Limit in at least 95% of the measurements taken each month for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

2687	= A	Total # of filtered water turbidity measurements for month (SWTR - Form F)
2675	= B	Total # of filtered water turbidity measurements less than or equal to the specified limits for the filtration technology used. (SWTR - Form F)
99.553	= (B / A) x 100	The percentage of turbidity measurements meeting the Monthly Turbidity 95% NTU Limit.

2. **Max Day NTU Limit** - The turbidity level of a system's filtered water must at no time exceed the Max Day NTU Limit for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

Record the date and turbidity value for any measurements exceeding the Max Day NTU. Check box if "None"

Date	Value	Date Reported to DEP	Date	Value	Date Reported to DEP

For each day the Max Day NTU limit is exceeded, the DEP must be notified by the end of the next business day. SWTR TT Violation (Tier 2). If DEP is not consulted within 24 hours then it is a SWTR TT (Tier 1) violation requiring public notification within 24 hours.

III. DISINFECTION PERFORMANCE CRITERIA:

1. **Point-of-Entry Minimum Disinfectant Residual Criteria** - Residual Disinfectant concentration cannot be < 0.2 mg/L for more than 4 hours. SWTR TT Violation (Tier 2).

Minimum Disinfectant Residual at Point-of-Entry to Distribution System

Day	Cl ₂ mg/l	Day	Cl ₂ mg/l										
1	2.070	6	2.110	11	2.290	16	2.060	21	2.020	26	2.050	31	
2	2.250	7	1.890	12	2.020	17	1.820	22	2.170	27	1.820	Residual Measured <input type="checkbox"/> Free Cl ₂ <input type="checkbox"/> Total Cl ₂ <input type="checkbox"/> Combined Cl ₂	
3	2.080	8	2.060	13	1.960	18	1.520	23	1.920	28	2.020		
4	1.970	9	1.930	14	1.450	19	1.860	24	2.080	29			
5	2.040	10	1.720	15	1.930	20	1.960	25	2.040	30			

If at any time the residual falls below 0.2 mg/l in the water entering the distribution system, the supplier of water must notify the Department as soon as possible, but no later than by the end of the next business day. The supplier of water also must notify the Department by the end of the next business day whether or not the residual was restored to at least 0.2 mg/l within four hours.

Date(s) Residual < 0.2 mg/l	Duration of Low Level (hrs.)	Date Reported to DEP	Date(s) Residual < 0.2 mg/l	Duration of Low Level (hrs.)	Date Reported to DEP

2. **Distribution System Disinfectant Residual Criteria** - Residual Disinfectant concentration (V) cannot be undetectable in greater than 5% of samples in a month, for any two consecutive months. SWTR TT Violation (Tier 2). Chlorine residuals must be measured at the same time and location as total coliform distribution routine & repeat samples. If no residual is detected, an HPC sample must be collected and analyzed.

Total # of HPC samples taken during month: # HPC sites > 500/mL: # HPC sites ≤ 500/mL:

50	= a	# of sites where Cl ₂ residual measurements were made, whether a residual was detected or not (should be the same # of sites reported on your monthly DBPR Cl ₂ residual report)
0	= b	# of sites HPC samples were analyzed <i>instead</i> of Cl ₂ residual measurements
0	= c	# of sites where no Cl ₂ residual was detected and no HPC sample was analyzed
0	= d	# of sites where no Cl ₂ residual was detected and HPC > 500 CFU/mL
0	= e	# of sites where no Cl ₂ residual measurement was made and HPC > 500 CFU/mL

Water in the distribution system with a heterotrophic bacteria concentration (HPC) less than or equal to 500/mL, is deemed to have a detectable disinfectant residual for purposes of determining compliance with this requirement. When analyzed, report HPC results on your monthly DEP Bacteriological Report.

V = $\frac{(c + d + e)}{(a + b)} \times 100$ This Month % V = Previous Month % V = Is V > 5% for 2 months? Yes or No

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: Title: Primary Operator

Date: 03/25/2025

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.