



**Town of Holbrook**  
Office of Joint Superintendent  
(781) 767-1800

# RANDOLPH-HOLBROOK JOINT WATER BOARD

50 North Franklin Street  
Holbrook, MA 02343



**Town of Randolph**

May 6, 2022

Commonwealth of Massachusetts  
Department of Environmental Protection  
Southeast Regional Office  
20 Riverside Drive  
Lakeville, MA 02374

Monthly Reports Filtered System Forms  
Forms F, G, I, J, TT  
Analysis for TOC, DOC, SUVA  
Chemical Addition Reports  
DBPR Compliance Report  
April, 2022 Randolph/Holbrook  
Joint Water System, PWS #424001

Gentlemen:

Enclosed please find all reports as referenced above for the month of April, 2022. Should there be any questions, please do not hesitate to call me.

Sincerely,

William Cookerly  
Chief Plant Operator

Enclosures

Cc: Board of Health Holbrook  
Board of Health Randolph  
Brian Howard, Town Manager, Randolph  
Ryan Allgrove, EPG



# Compliance Determination for Filtered Systems - Monthly Report

## I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH  
 Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period → Month: APRIL Year: 2022

## II. TURBIDITY PERFORMANCE CRITERIA:

1. Monthly Turbidity (95%) NTU Limit - The turbidity level of a system's filtered water must be less than or equal to the Monthly Turbidity NTU Limit in at least 95% of the measurements taken each month for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

<u>180</u>	= A	Total # of filtered water turbidity measurements for month (SWTR - Form F)
<u>180</u>	= B	Total # of filtered water turbidity measurements less than or equal to the specified limits for the filtration technology used. (SWTR - Form F)
<u>100</u>	= (B/A) x 100	The percentage of turbidity measurements meeting the Monthly Turbidity 95% NTU Limit.

2. Max Day NTU Limit - The turbidity level of a system's filtered water must at no time exceed the Max Day NTU Limit for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

Record the date and turbidity value for any measurements exceeding the Max Day NTU. Check box  if "None"

Date	Value	Date Reported to DEP	Date	Value	Date Reported to DEP

For each day the Max Day NTU limit is exceeded, the DEP must be notified by the end of the next business day. SWTR TT Violation (Tier 2). If DEP is not consulted within 24 hours then it is a SWTR TT (Tier 1) violation requiring public notification within 24 hours.

## III. DISINFECTION PERFORMANCE CRITERIA:

1. Point-of-Entry Minimum Disinfectant Residual Criteria - Residual Disinfectant concentration cannot be < 0.2 mg/L for more than 4 hours. SWTR TT Violation (Tier 2).

Minimum Disinfectant Residual at Point-of-Entry to Distribution System:

Day	Cl <sub>2</sub> mg/l												
1	<u>1.84</u>	6	<u>1.78</u>	11	<u>1.52</u>	16	<u>1.52</u>	21	<u>1.84</u>	26	<u>1.53</u>	31	
2	<u>1.61</u>	7	<u>1.67</u>	12	<u>1.97</u>	17	<u>1.48</u>	22	<u>1.98</u>	27	<u>1.85</u>		Residual Measured <input checked="" type="checkbox"/> Free Cl <sub>2</sub> <input type="checkbox"/> Total Cl <sub>2</sub> <input type="checkbox"/> Combined Cl <sub>2</sub>
3	<u>1.92</u>	8	<u>1.82</u>	13	<u>1.88</u>	18	<u>1.24</u>	23	<u>1.53</u>	28	<u>1.95</u>		
4	<u>1.84</u>	9	<u>1.76</u>	14	<u>1.73</u>	19	<u>1.51</u>	24	<u>2.00</u>	29	<u>1.89</u>		
5	<u>1.28</u>	10	<u>1.90</u>	15	<u>1.76</u>	20	<u>1.87</u>	25	<u>1.44</u>	30	<u>1.88</u>		

If at any time the residual falls below 0.2 mg/l in the water entering the distribution system, the supplier of water must notify the Department as soon as possible, but no later than by the end of the next business day. The supplier of water also must notify the Department by the end of the next business day whether or not the residual was restored to at least 0.2 mg/l within four hours.

Date(s) Residual < 0.2 mg/l	Duration of Low Level (hrs.)	Date Reported to DEP	Date(s) Residual < 0.2 mg/l	Duration of Low Level (hrs.)	Date Reported to DEP

2. Distribution System Disinfectant Residual Criteria - Residual Disinfectant concentration (V) cannot be undetectable in greater than 5% of samples in a month, for any two consecutive months. SWTR TT Violation (Tier 2). Chlorine residuals must be measured at the same time and location as total coliform distribution routine & repeat samples. If no residual is detected, an HPC sample must be collected and analyzed.

Total # of HPC samples taken during month: 61 # HPC sites > 500/mL: 0 # HPC sites ≤ 500/mL: 61

<u>66</u>	= a	# of sites where Cl <sub>2</sub> residual measurements were made, whether a residual was detected or not (should be the same # of sites reported on your monthly DBPR Cl <sub>2</sub> residual report)
<u>0</u>	= b	# of sites HPC samples were analyzed <i>instead</i> of Cl <sub>2</sub> residual measurements
<u>0</u>	= c	# of sites where no Cl <sub>2</sub> residual was detected and no HPC sample was analyzed
<u>0</u>	= d	# of sites where no Cl <sub>2</sub> residual was detected and HPC > 500 CFU/mL
<u>0</u>	= e	# of sites where no Cl <sub>2</sub> residual measurement was made and HPC > 500 CFU/mL

Water in the distribution system with a heterotrophic bacteria concentration (HPC) less than or equal to 500/mL, is deemed to have a detectable disinfectant residual for purposes of determining compliance with this requirement. When analyzed, report HPC results on your monthly DEP Bacteriological Report.

V =  $\frac{(c+d+e)}{(a+b)} \times 100$  This Month % V = 0 Previous Month % V = 0 Is V > 5% for 2 months?  Yes or  No

I certify under penalties of law that I am the person authorized to sign this form and the information contained herein is true. 5-6-2022 William Cookerly, Chief Operator



Massachusetts Department of Environmental Protection - Drinking Water Program  
 TURBIDITY DATA SHEET FOR FILTERED SYSTEMS

SWTR  
F

**PWS INFORMATION:**

PWSID#: 1244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH  
 Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period → Month: APRIL Year: 2022

**DAILY REPORTING:**

Filtered Water Turbidity Measured: (check only one)  Combined Filter Effluent  Individual Filter Effluent  Clearwell  Plant Effluent  
 Filtration Technology:  Conventional  Direct  Alternative  Slow Sand  Diatomaceous Earth  
 Monthly Turbidity (95%) NTU Limit = 0.3 Max Day Turbidity NTU Limit = 1  
 Monthly Turbidity (95%) NTU Limit = 1 Max Day Turbidity NTU Limit = 5

Day	Max Filtered Water Turbidity Result (NTU)	Number of Turbidity Measurements	Number of Turbidity Measurements Monthly (95%) NTU Limit	Number of Turbidity Measurements Max Day NTU Limit
	.08	6	6	0
	.06	6	6	0
	.08	6	6	0
	.09	6	6	0
	.07	6	6	0
	.06	6	6	0
	.11	6	6	0
	.09	6	6	0
	.06	6	6	0
	.07	6	6	0
	.09	6	6	0
	.08	6	6	0
	.09	6	6	0
	.05	6	6	0
	.04	6	6	0
	.05	6	6	0
	.05	6	6	0
	.05	6	6	0
	.05	6	6	0
	.05	6	6	0
	.09	6	6	0
	.06	6	6	0
	.05	6	6	0
	.05	6	6	0
	.08	6	6	0
	.05	6	6	0
	.07	6	6	0
	.07	6	6	0
	.05	6	6	0
	.07	6	6	0
Totals		180	180	

Turbidity Meeting 95% Limit  
 B/A % 100% X  
 (Enter on SWTR Form G)

May be used by systems serving less than 10,000 persons, subject to DEP approval.  
 Enter the Maximum Filtered Water Turbidity Result recorded each day, at the 4<sup>th</sup> hour or other approved interval.  
 Enter the Total # of Turbidity measurements taken for each day. Measurements must be taken at a minimum of 4-hour intervals (i.e. 6 readings per day).  
 For continuous monitors count each 4-hour period as 1 measurement. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. If DEP approved, 15-minute readings (i.e. 96 readings per day) may be submitted. Filtered turbidity data must be kept on file for DEP review.  
 Out of the # of turbidity measurements taken and recorded in the previous column, enter the number of turbidity measurements that were less than or equal to the Monthly (95%) NTU Limit for the filtration technology used.  
 If at any time the filtered turbidity Max Day NTU Limit is exceeded, the DEP must be notified no later than the end of the next business day. For each exceedance, record the turbidity value(s) and date(s) on SWTR - Form G

PWS Authorized Signature: William Cookery, Chief Operator  
 Date: 5-2-22 Title: \_\_\_\_\_



Massachusetts Department of Environmental Protection - Drinking Water Program **SWTR**  
**CT Determination for Filtered Systems** **I**

**I. PWS INFORMATION:**

PWSID#: 4244001 PWS Name: Randolph-Hillbrook Joint Water PWS Town: Randolph  
 Treatment Plant Name: Randolph Water Plant Reporting Period → Month: APRIL Year: 2022  
 Disinfectant<sup>1</sup>: Chlorine Gas/Ester Eff. Sequence of Application:  1<sup>st</sup>  2<sup>nd</sup>  3<sup>rd</sup>  4<sup>th</sup>  5  6<sup>th</sup>

**II. DAILY REPORTING: All measurements taken during peak hourly flow.**

Day	Peak Hourly Flow <sup>2</sup> (gpm)	Disinfectant Concentration <sup>3</sup> C (mg/L)	Disinfectant Contact Time <sup>4</sup> T (min.)	CT calc (= C x T)	pH <sup>5</sup>	Water Temp <sup>6</sup> (°C)	CT <sup>7</sup> 99.9	Inactivation Ratio <sup>8</sup> (CT calc / CT 99.9)	Inactivation Ratio <sup>9</sup> < 1.0
1	2,400	1.84	50	92	6.20	7.0	17	5.4	<input type="checkbox"/> Yes
2	2,400	1.61	50	80.5	6.25	7.0	17	4.7	<input type="checkbox"/> Yes
3	2,400	1.92	50	96	6.25	7.2	17	5.7	<input type="checkbox"/> Yes
4	2,400	1.84	50	92	6.30	6.8	17	5.4	<input type="checkbox"/> Yes
5	2,400	1.28	50	64	6.15	7.4	17	3.8	<input type="checkbox"/> Yes
6	2,400	1.78	50	89	6.15	7.9	17	5.2	<input type="checkbox"/> Yes
7	2,400	1.67	50	83.5	6.00	7.4	17	4.9	<input type="checkbox"/> Yes
8	2,400	1.82	50	91	5.95	8.3	17	5.4	<input type="checkbox"/> Yes
9	2,400	1.76	50	88	5.95	8.6	17	5.2	<input type="checkbox"/> Yes
10	2,400	1.90	50	95	6.10	8.3	17	5.6	<input type="checkbox"/> Yes
11	2,400	1.52	50	76	6.05	8.8	17	4.5	<input type="checkbox"/> Yes
12	2,400	1.97	50	98.5	6.05	9.1	17	5.8	<input type="checkbox"/> Yes
13	2,400	1.88	50	94	6.00	9.8	17	5.5	<input type="checkbox"/> Yes
14	2,400	1.73	50	86.5	5.95	9.0	17	5.1	<input type="checkbox"/> Yes
15	2,400	1.76	50	88	6.05	9.3	17	5.2	<input type="checkbox"/> Yes
16	2,400	1.52	50	76	6.10	10.2	17	4.5	<input type="checkbox"/> Yes
17	2,400	1.48	50	74	6.15	10.0	17	4.4	<input type="checkbox"/> Yes
18	2,400	1.24	50	62	6.10	10.6	17	3.7	<input type="checkbox"/> Yes
19	2,400	1.51	50	75.5	6.20	10.8	17	4.4	<input type="checkbox"/> Yes
20	2,400	1.87	50	93.5	6.05	9.9	17	5.5	<input type="checkbox"/> Yes
21	2,400	1.84	50	92	5.90	8.2	17	5.4	<input type="checkbox"/> Yes
22	2,400	1.98	50	99	6.00	8.5	17	5.8	<input type="checkbox"/> Yes
23	2,400	1.53	50	76.5	6.15	8.0	17	4.5	<input type="checkbox"/> Yes
24	2,400	2.00	50	100	6.10	8.0	17	5.9	<input type="checkbox"/> Yes
25	2,400	1.44	50	72	6.20	8.8	17	4.2	<input type="checkbox"/> Yes
26	2,400	1.53	50	76.5	6.05	8.4	17	4.5	<input type="checkbox"/> Yes
27	2,400	1.85	50	92.5	6.15	9.3	17	5.4	<input type="checkbox"/> Yes
28	2,400	1.95	50	97.5	6.00	8.8	17	5.7	<input type="checkbox"/> Yes
29	2,400	1.89	50	94.5	6.20	8.1	17	5.6	<input type="checkbox"/> Yes
30	2,400	1.88	50	94	6.15	8.3	17	5.5	<input type="checkbox"/> Yes
31			50						<input type="checkbox"/> Yes

1. Use a separate form for each disinfectant/sampling point. Enter disinfectant and sequence position, e.g. "ozone/1<sup>st</sup>" or "ClO<sub>2</sub>/3<sup>rd</sup>". If more than one disinfectant sampling point, you must also complete SWTR Form H and calculate the cumulative inactivation ratio SUM (CTcalc/CT99.9) to determine compliance.
2. Peak hourly flow means the highest pumpage hour during the day, not the absolute peak flow at any instant.
3. The residual disinfectant concentration(s) ("C") of the water before or at the first customer must be measured each day during peak hourly flow.
4. The disinfectant contact time(s) ("T") must be determined for each day during peak hourly flow. The time T used in calculating CT, is the time it takes the water, during peak hourly flow, to move between the point of disinfection application and the point at which the residual is measured.
5. If the system uses free chlorine, the pH of the disinfected water must be measured at least once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
6. The temperature of the disinfected water must be measured at least once per day at each residual disinfectant concentration sampling point during peak hourly flow.
7. Use Inactivation Tables at 310 CMR 22.20A Tables 1.1 – 1.6, 2.1 and/or 3.1
8. The inactivation ratio (CTcalc/CT99.9) is determined before or at the first customer during peak hourly flow and if the (CTcalc/CT99.9) is < 1.0, the 99.9% *Giardia lamblia* inactivation requirement has not been achieved.
9. More than one "Yes" response above may indicate a SWTR Treatment Technique violation (Tier 2).

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Cookerly  
 Date: 5-2-2022 Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program  
**CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements**

C-ADD

**I. PWS Information** - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

PWS Name <sup>1</sup> :	RANDOLPH-HOLBROOK JW	Town <sup>1</sup> :	RANDOLPH-HOLBROOK	PWSID <sup>1</sup> :	424001
Treatment Plant Name <sup>2</sup> :	RANDOLPH WATER PLANT	Treatment Plant ID# <sup>2</sup> :	4244001-01T	Reporting Period <sup>3</sup> :	APRIL, 2022
				Month	Year

**II. Chemical & Operational Information**

Chemical Name <sup>4</sup> :	POLYALUMINUM CHLORIDE	Purchased Strength <sup>8</sup> :	1.0	Target Range/min <sup>12</sup> :	14
Manufacturer <sup>5</sup> :	HOLLAND COMPANY	Purchased Density (lbs/gal) <sup>9</sup> :	10.3	Target Dose <sup>13</sup> :	18
Product Name <sup>6</sup> :	PCH-180	Dilution Factor or Mix Ratio <sup>10</sup> :	NA	Alarm Setting (low) <sup>14</sup> :	NA
Reason for Adding Chemical <sup>7</sup> :	COAGULATION	NSF Approved (Y/N) <sup>11</sup> :	Y	Alarm Setting (high) <sup>14</sup> :	NA
		Date of last anti-siphon valve inspection/replacement <sup>15</sup> :			

**III. Daily Reporting** Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water <sup>16</sup>		Measured Chemical Used		Calculated Chemical Used (lbs) <sup>16</sup>	Chemical Dosage <sup>19</sup> (mg/L)	Parameters Measured <sup>17</sup> , Results, Units and Method <sup>20</sup> - (G)rab or Continuous (A)nalyzer <sup>21</sup>			O&M Notes/Comments <sup>22</sup>
	<input type="checkbox"/> Gallons	<input checked="" type="checkbox"/> MCG	Volume <sup>17</sup> (gal/day)	Weight <sup>17</sup> (lbs/day)			a-RAW Ph	b.	c.	
1			2.9	109	1,123	15	6.80			PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
2			2.7	128	1,318	19	6.85			
3			2.8	117	1,205	17	6.85			
4			2.7	111	1,143	17	6.90			
5			2.8	115	1,185	17	6.90			
6			2.8	110	1,133	16	6.80			
7			2.8	105	1,082	15	6.75			
8			2.9	125	1,288	18	6.80			
9			2.9	148	1,524	21	6.70			
10			2.8	132	1,360	19	6.85			
11			2.8	120	1,236	18	6.80			
12			2.3	100	1,030	18	6.80			
13			2.9	146	1,504	21	6.90			
14			3.0	152	1,566	21	6.90			
15			2.9	132	1,340	19	6.85			
16			2.8	107	1,102	16	6.95			
17			2.9	113	1,164	16	6.80			
18			2.8	110	1,133	16	6.90			
19			2.8	130	1,339	19	6.95			
20			2.8	122	1,257	18	6.85			
21			2.8	117	1,205	17	6.90			
22			2.8	105	1,082	15	6.90			
23			2.7	139	1,432	21	7.00			
24			2.8	121	1,246	18	6.85			
25			2.8	135	1,391	20	6.95			
26			2.8	110	1,133	16	6.90			
27			2.8	115	1,185	17	6.90			
28			2.8	108	1,112	16	6.85			
29			2.8	137	1,411	20	6.95			
30			2.9	153	1,576	21	6.90			
31										

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary<sup>23</sup>.

<sup>18</sup>Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)<sup>20</sup>:

a. Raw Ph Daily Average, Test Kit

b. I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

c. PWS Authorized Person - Signature & Date<sup>24</sup>:  
  
 Print Name: William Coakley Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program  
**CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements**

C-ADD

<b>PWS Information</b> - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.					
PWS Name <sup>1</sup> :	RANDOLPH-HOLBROOK JOINT WATER	Town <sup>1</sup> :	RANDOLPH-HOLBROOK	PWSID <sup>1</sup> :	424001
Treatment Plant Name <sup>2</sup> :	RANDOLPH WATER PLANT	Treatment Plant ID# <sup>2</sup> :	4244001-01T	Reporting Period <sup>3</sup> :	APRIL 2022 Month Year

<b>II. Chemical &amp; Operational Information</b>					
Chemical Name <sup>4</sup> :	CHLORINE	Purchased Strength <sup>5</sup> :	1.0	Target Range/min <sup>12</sup> :	0.20
Manufacturer <sup>6</sup> :	AXIALL, LLC	Purchased Density (lbs/gal) <sup>9</sup> :	12.3	Target Dose <sup>13</sup> :	NA
Product Name <sup>7</sup> :	CHLORINE	Dilution Factor or Mix Ratio <sup>10</sup> :	NA	Alarm Setting (low) <sup>14</sup> :	1.0
Reason for Adding Chemical <sup>8</sup> :	DISINFECTANT	NSF Approved (Y/N) <sup>11</sup> :	Y	Alarm Setting (high) <sup>14</sup> :	3.0
		Date of last anti-siphon valve inspection/replacement <sup>15</sup> :			

**III. Daily Reporting** Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water <sup>16</sup> <input type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG	Measured Chemical Used		Calculated Chemical Used (lbs) <sup>18</sup>	Chemical Dosage <sup>19</sup> (mg/L)	Parameters Measured <sup>20</sup> , Results, Units and Method <sup>20</sup> - (G) Grab or Continuous (A) Analyzer <sup>21</sup>			O&M Notes/Comments <sup>22</sup>  PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
		Volume <sup>17</sup> (gal/day)	Weight <sup>17</sup> (lbs/day)			a. FREE CL <sub>2</sub> DAILY AVG	b. FREE CL <sub>2</sub> DAILY MAXIMUM	c.	
1	2.9		85	3.5	2.04	1.84			
2	2.7		82	3.6	1.99	1.61			
3	2.8		82	3.5	2.11	1.92			
4	2.7		80	3.6	1.94	1.84			
5	2.8		84	3.6	1.90	1.28			
6	2.8		76	3.3	2.05	1.78			
7	2.8		78	3.3	2.00	1.67			
8	2.9		77	3.2	2.15	1.82			
9	2.9		70	2.9	2.02	1.76			
10	2.8		77	3.3	2.11	1.90			
11	2.8		82	3.5	1.90	1.52			
12	2.3		50	3.4	2.15	1.97			
13	2.9		83	3.4	2.11	1.88			
14	3.0		82	3.3	1.97	1.73			
15	2.9		81	3.3	1.93	1.76			
16	2.8		78	3.3	1.76	1.52			
17	2.9		73	3.0	1.87	1.48			
18	2.8		76	3.3	1.81	1.24			
19	2.8		79	3.4	1.99	1.57			
20	2.8		86	3.7	2.26	1.87			
21	2.8		89	3.8	2.20	1.84			
22	2.8		87	3.7	2.21	1.98			
23	2.7		82	3.6	2.07	1.53			
24	2.8		90	3.9	2.22	2.00			
25	2.8		88	3.8	1.99	1.44			
26	2.8		86	3.7	2.03	1.53			
27	2.8		85	3.6	2.11	1.85			
28	2.8		78	3.3	2.12	1.95			
29	2.8		83	3.6	2.14	1.89			
30	2.9		78	3.2	2.16	1.88			
31									

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary<sup>23</sup>:

\*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)<sup>20</sup>:

a. Daily Average, Free Chlorine, Finished Water, Grab Sample  
 b. Daily Maximum, Free Chlorine, Finished Water, Test Kit  
 c.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person's Signature & Date<sup>24</sup>:  
 William Cokerly 5-2-2022  
 Print Name: William Cokerly Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program  
**CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements**

C-ADD

**I. PWS Information** - Refer to Mass DEP "Chemical Addition Report Guidance and Instructions" for details.

PWS Name <sup>1</sup> :	RANDOLPH-HOLBROOK JW	Town <sup>1</sup> :	RANDOLPH-HOLBROOK	PWSID <sup>1</sup> :	424001
Treatment Plant Name <sup>2</sup> :	RANDOLPH WATER PLANT	Treatment Plant ID# <sup>2</sup> :	4244001-01T	Reporting Period <sup>3</sup> :	APRIL 2022 Month Year

**II. Chemical & Operational Information**

Chemical Name <sup>4</sup> :	CALCIUM HYDROXIDE	Purchased Strength <sup>5</sup> :	0.85	Target Range/min <sup>12</sup> :	NA
Manufacturer <sup>6</sup> :	CARMEUSE LIME & STONE	Purchased Density (lbs/gal) <sup>5</sup> :	18.7	Target Dose <sup>13</sup> :	NA
Product Name <sup>6</sup> :	HYDRATED LIME	Dilution Factor or Mix Ratio <sup>10</sup> :	NA	Alarm Setting (low) <sup>14</sup> :	NA
Reason for Adding Chemical <sup>7</sup> :	PH ADJUSTMENT	NSF Approved (Y/N) <sup>11</sup> :	Y	Alarm Setting (high) <sup>14</sup> :	NA
		Date of last anti-siphon valve inspection/replacement <sup>15</sup> :			NA

**III. Daily Reporting** Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water <sup>8</sup> <input checked="" type="checkbox"/> Gallons <input type="checkbox"/> MG	Measured Chemical Used		Calculated Chemical Used (lbs) <sup>9</sup>	Chemical Dosage <sup>18</sup> (mg/L)	Parameters Measured <sup>19</sup> , Results, Units and Method <sup>20</sup> - (G) Grab or Continuous (A) Analyzer <sup>21</sup>			O&M Notes/Comments <sup>22</sup>  PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
		Volume <sup>17</sup> (gal/day)	Weight <sup>17</sup> (lbs/day)			a. Finished Ph <input checked="" type="checkbox"/> G <input type="checkbox"/> A	b. <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A	
1	2.8		100		4.3	6.95			
2	2.6		100		4.6	7.00			
3	2.7		100		4.4	7.00			
4	2.6		100		4.6	7.05			
5	2.6		100		4.6	6.90			
6	2.6		100		4.6	7.05			
7	2.6		100		4.6	6.95			
8	2.6		100		4.6	7.00			
9	2.6		100		4.6	7.05			
10	2.7		100		4.4	7.10			
11	2.7		100		4.4	7.00			
12	2.0		100		3.6	7.05			
13	2.9		100		4.1	6.95			
14	2.9		100		4.1	6.90			
15	2.9		100		4.1	6.95			
16	2.7		100		4.4	7.05			
17	2.8		100		4.3	7.00			
18	2.7		100		4.4	7.10			
19	2.6		100		4.6	7.00			
20	2.7		100		4.4	6.90			
21	2.8		100		4.3	7.05			
22	2.8		100		4.3	7.00			
23	2.7		100		4.4	7.00			
24	2.8		100		4.3	7.10			
25	2.8		100		4.3	7.05			
26	2.8		100		4.3	7.05			
27	2.8		100		4.3	7.00			
28	2.8		100		—	6.30			* Lime feeder failure -
29	2.7		100		—	6.25			
30	2.8		100		—	6.25			• REPAIRED TUES 5-3-2022 ✓ - TO EMPTY + REPLACE PARTS
31			100						

Total  Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary<sup>23</sup>:

\*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)<sup>20</sup>:

a. Finished Water Ph, Daily Average Test Kit

b.

c.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person - Signature & Date<sup>24</sup>:  
 William Cookley 5-2-2022  
 Print Name: William Cookley Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program  
**CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements**

C-ADD

**I. PWS Information** - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

PWS Name <sup>1</sup> :	RANDOLPH-HOLBROOK JW	Town <sup>1</sup> :	RANDOLPH-HOLBROOK	PWSID <sup>1</sup> :	424001
Treatment Plant Name <sup>2</sup> :	RANDOLPH WATER PLANT	Treatment Plant ID# <sup>2</sup> :	4244001-01T	Reporting Period <sup>2</sup> :	APRIL 2022 Month Year

**II. Chemical & Operational Information**

Chemical Name <sup>4</sup> :	SODIUM BISULFATE	Purchased Strength <sup>4</sup> :	10-15	Target Range/min <sup>12</sup> :	NA
Manufacturer <sup>4</sup> :	CARUS CORPORATION	Purchased Density (lbs/gal) <sup>4</sup> :	12.03	Target Dose <sup>13</sup> :	NA
Product Name <sup>4</sup> :	CARUS 3350	Dilution Factor or Mix Ratio <sup>10</sup> :	0.33	Alarm Setting (low) <sup>14</sup> :	NA
Reason for Adding Chemical <sup>4</sup> :	CORROSION INHIBITOR	NSF Approved (Y/N) <sup>11</sup> :	Y	Alarm Setting (high) <sup>14</sup> :	NA
		Date of last anti-siphon valve inspection/replacement <sup>15</sup> :	NA		

**III. Daily Reporting** Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water <sup>16</sup> <input type="checkbox"/> Gallons <input checked="" type="checkbox"/> Mic	Measured Chemical Used		Calculated Chemical Used (lbs) <sup>15</sup>	Chemical Dosage <sup>19</sup> (mg/L)	Parameters Measured <sup>17</sup> , Results, Units and Method <sup>18</sup> - (G) Grab or Continuous (A) Analyzer <sup>21</sup>			O&M Notes/Comments <sup>22</sup> <small>PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.</small>
		Volume <sup>17</sup> (gal/day)	Weight <sup>17</sup> (lbs/day)			a. FINISHED Ph <input checked="" type="checkbox"/> G <input type="checkbox"/> A	b. <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A	
1	2.8		50		2.1	6.95			
2	2.6		50		2.3	7.00			
3	2.7		50		2.2	7.00			
4	2.6		50		2.3	7.05			
5	2.6		50		2.3	6.90			
6	2.6		50		2.3	7.05			
7	2.6		50		2.3	6.95			
8	2.6		50		2.3	7.00			
9	2.6		50		2.3	7.05			
10	2.7		50		2.2	7.10			
11	2.7		50		2.2	7.00			
12	2.0		50		1.7	7.05			PLANT DOWN, BASIN CLEANING
13	2.9		50		2.1	6.95			
14	2.9		50		2.1	6.90			
15	2.9		50		2.1	6.95			
16	2.7		50		2.2	7.05			
17	2.8		50		2.1	7.00			
18	2.7		50		2.2	7.10			
19	2.6		50		2.3	7.00			
20	2.7		50		2.2	6.90			
21	2.8		50		2.1	7.05			
22	2.8		50		2.1	7.00			
23	2.7		50		2.2	7.00			
24	2.8		50		2.1	7.10			
25	2.8		50		2.1	7.05			
26	2.8		50		2.1	7.05			
27	2.8		50		2.1	7.00			
28	2.8		50		2.1	6.30			
29	2.7		50		2.2	6.25			
30	2.8		50		2.1	6.25			
31			50						

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary<sup>23</sup>:

\*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)<sup>20</sup>.

a. Finished Ph, Daily Average, Test Kit  
 b.  
 c.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person/Signature & Date<sup>24</sup>:  
 William Costello 5-2-2022  
 Print Name: William Costello Title: Plant Operator



Total Organic Carbon (TOC) Report doc rev 12/2020

I. PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: 4244001 City / Town: RANDOLPH
PWS Name: RANDOLPH HOLBROOK WATER BOARD PWS Class: COM [x] NTNC [ ] TNC [ ]

Table with columns: DEP LOCATION (LOC) ID#, DEP Location Name, Sample Information, Date Collected, Collected By. Includes rows for Great Pond WTP - Raw Water and Combined Filter Effluent.

II. ANALYTICAL LABORATORY INFORMATION: Primary Lab MA Cert. #: M-MA022 Primary Lab Name: Analytical Balance Subcontracted?(Y/N): Y

Table for TOC Analyzed by (check one): PWS or Lab. Samples Acidified? Yes or No. Columns: TOC Result (mg/L), Result Qualifier, MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

Surface or GWUDI systems >= 500 persons. Monthly source (raw) water TOC sampling is required at each surface/GWUDI source to qualify for and remain on reduced THM/HAA5 monitoring.

Table for Alkalinity Analyzed by (check one): PWS or Lab. Columns: ALKALINITY Result (mg/L as CaCO3), Result Qualifier, MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

If using conventional filtration - Raw water alkalinity must be measured at the same time as the raw water TOC sample is collected.

Table for LAB SAMPLE COMMENTS. Columns: LAB SAMPLE COMMENTS, Result Qualifier, Result Qualifier Description.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator or Primary Lab Director Signature: Laurel Stockard Date: 4/20/2022

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner.

DEP REVIEW STATUS (Initial & Date)
[ ] Accepted [ ] Disapproved
Review Comments
[ ] WQTS Data Entered



## CERTIFICATE OF ANALYSIS

Chris Pelleteri  
 Randolph - Holbrook Joint Water Board  
 50 North Franklin Street  
 Holbrook, MA 02343

Project Name: DOC SUVA  
 Work Order Number: A2D0078  
 Date Received: 04/04/2022

Sampled By: Bill Cookerly  
 Location: Raw Water

Date Sampled: 4/4/22 9:00  
 Matrix: Surface Water

### RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Detection Limit	DW MCL/ Recommended Limit #	Result
<b>Test Parameters</b>						
				LAB-ID#: <b>A2D0078-01</b>		
Dissolved Organic Carbon (Average)	5310B	4/6/2022	mg/L	0.500	—	4.31
SUVA	4153	4/6/2022	/100 ml	N/A	—	0.0177
UV 254	5910B	4/5/2022	abs/cm	0.002	—	0.076

Sampled By: Bill Cookerly  
 Location: Combined Filter Effluent

Date Sampled: 4/4/22 9:00  
 Matrix: Drinking Water

### RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Detection Limit	DW MCL/ Recommended Limit #	Result
<b>Test Parameters</b>						
				LAB-ID#: <b>A2D0078-02</b>		
Dissolved Organic Carbon (Average)	5310B	4/6/2022	mg/L	0.500	—	2.69
SUVA	4153	4/6/2022	/100 ml	N/A	—	0.0151
UV 254	5910B	4/5/2022	abs/cm	0.002	—	0.040

NA = Not Applicable  
 ND = Not Detected  
 <= Less Than  
 >= Greater Than

Approved By: *Lance H. Hall*

### Work Order Narrative:

No unusual observations noted.

### Subcontracted Analyses:

ESS Laboratory - Cranston, RI (M-RI002)

Dissolved Organic Carbon 5310B; UVA 254

**REVIEWED**  
 By Amanda Cronin at 2:46 pm, Apr 12, 2022



# DBPR TT Compliance Report

## I. PWS INFORMATION

PWS ID #: 4244001 City/Town: RANDOLPH  
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM  NTNC  TNC

DEP LOCATION (LOC) ID#	DEP Location Name	Date Collected	Collected By
<u>01S/10300</u>	<u>RAW WATER/COMBINED FILTER EFFLUENT</u>	<u>4-4-2022</u>	<u>William Cookerly</u>
SAMPLE NOTES			

## II. COMPLIANCE CALCULATIONS

Month	# of Paired Samples	A: % Removal of TOC <sup>1</sup>	B: Required % Removal of TOC <sup>2</sup>	Met Alternative Compliance Criteria	Alternative Criteria Result(s) <sup>3</sup> (See Below)	A ÷ B <sup>4</sup>
5-21	1	42	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.20
6-21	1	38	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.09
7-21	1	42	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.20
8-21	1	46	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.31
9-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
10-21	1	45	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.29
11-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
12-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
1-22	1	39	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.17
2-22	1	36	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.03
3-22	1	63	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.80
4-22	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
Sum of Past 12 Months:						15.01
Compliance Value (Sum of Past 12 Months/ 12):						1.25

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Cookerly  
 Date: 5-2-2022

Mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

<sup>1</sup> Percent Removal: (1 - (Treated Water TOC ÷ Raw Water TOC)) x 100. If > 1 paired sample sets in any month report the average of all individual percent TOC removals (Example: % TOC Removal = (Average of Set 1 + Average of Set 2) ÷ 2).  
<sup>2</sup> From table at 310 CMR 22.07E(10)(b)2.  
<sup>3</sup> As listed at 310 CMR 22.07E(10)(a)2 and 310 CMR 22.07E(10)(a)3, summarized as follows:

Alternative Compliance Criteria	Code Value	Result(s) to Report (RAA = Running Annual Average)
Source Water TOC <2.0 mg/L	SWTOC	RAA of source water TOC
Treated Water <2.0 mg/L	TWTOC	RAA of treated water TOC
Source Water TOC < 4.0 mg/L AND Alkalinity >60 mg/L (as CaCO <sub>3</sub> ) AND TTHM/HAA5 ≤ 0.040/0.030 mg/L	COMBO	RAA of source water TOC, RAA of source water alkalinity, RAA of TTHM and HAA5
TTHM/HAA5 ≤ 0.040/0.030 mg/L AND only using chlorine	TTHM/HAA5	RAA of TTHM and HAA5
Source Water SUVA ≤ 2.0 L/mg-m	SWSUVA	RAA of treated water SUVA
Treated Water SUVA ≤ 2.0 L/mg-m	TWSUVA	RAA of treated water SUVA
Softening that lowers alkalinity to < 60 mg/L (as CaCO <sub>3</sub> )	SOFT60	RAA of treated water alkalinity
Softening that removes ≥ 10 mg/L (as CaCO <sub>3</sub> ) of hardness	SOFT10	RAA of hardness (as CaCO <sub>3</sub> ) removal

Note: All supplemental measurements and calculations used to meet the alternative criteria must be attached to this report.

<sup>4</sup> For any month where the system met an alternative compliance criteria a value of 1.0 may be inserted.

DEP REVIEW STATUS (Initial & Date)	Review Comments
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved _____	



Massachusetts Department of Environmental Protection - Drinking Water Program

TURBIDITY - INDIVIDUAL FILTER MONITORING For Conventional or Direct Filtered Systems

SWTR J

(Page 1 of 2)

I. PWS INFORMATION

PWS ID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: Randolph Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period: Month: Apr Year: 2022 Total # of Filters at Treatment Plant: 8

II. MONTHLY REPORTING

Filtered Water Turbidity Measured: [X] Individual Filter Effluent (IFE) or [ ] Combined Filter Effluent (CFE) Analytical Method: [ ] SM 2130B [ ] EPA 180.1 [ ] GLI Method 2 (Great Lakes)

Table with 7 rows of monitoring questions and answers. Questions include: 'Was each filter monitored continuously?', 'Were measurements recorded every 15 minutes?', 'Was there a failure of continuous turbidity monitoring equipment?', 'Were individual filter levels greater than 1.0 NTU in two consecutive measurements?', 'Were individual filter levels greater than 0.5 NTU in two consecutive measurements after the filter has been online for more than 4 hours?', 'Were individual filter levels greater than 1.0 NTU in two consecutive measurements in three consecutive months?', 'Were individual filter levels greater than 2.0 NTU in two consecutive measurements in two consecutive months?'.

For each "Yes" response to question #4, #5, #6, or #7 above: Report the following information in the table below.

Table with 4 columns: Filter #, Turbidity Result (NTU), Date, Reason for Exceedance (if known). Includes a note: 'Attach additional documents as necessary for detailed explanations.'

**III. DAILY REPORTING**

Day	Filter Number 1		Filter Number 2		Filter Number 3		Filter Number 4	
	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU
1	0.020000	0.079000	0.017000	0.085000	0.026000		0.067000	
2	0.023000		0.020000		0.021000	0.175000	0.057000	0.130000
3	0.020000	0.091000	0.018000	0.088000	0.021000	0.122000	0.064000	0.088000
4	0.021000	0.110000	0.019000	0.084000	0.021000	0.113000	0.057000	0.120000
5	0.021000	0.049000	0.018000	0.072000	0.022000		0.060000	
6	0.023000		0.021000		0.020000	0.041000	0.059000	0.080000
7	0.022000	0.076000	0.019000	0.110000	0.023000	0.072000	0.059000	0.154000
8	0.034000	0.134000	0.020000	0.112000	0.018000	0.074000	0.055000	0.106000
9	0.019000	0.073000	0.018000	0.068000	0.019000		0.059000	
10	0.037000		0.020000		0.018000	0.070000	0.056000	0.104000
11	0.020000	0.057000	0.017000	0.083000	0.021000	0.075000	0.058000	0.124000
12	0.021000	0.080000	0.017000	0.056000	0.018000	0.041000	0.198000	
13	0.020000	0.032000	0.294000		0.271000		0.099000	0.074000
14	0.026000		0.024000	0.040000	0.029000	0.054000	0.057000	0.066000
15	0.024000	0.037000	0.024000	0.035000	0.032000	0.024000	0.055000	0.062000
16	0.029000	0.045000	0.030000	0.039000	0.024000	0.032000	0.059000	
17	0.033000	0.048000	0.037000		0.028000		0.058000	0.067000
18	0.036000		0.033000	0.043000	0.025000	0.034000	0.060000	0.079000
19	0.032000	0.042000	0.033000	0.051000	0.022000	0.044000	0.057000	0.065000
20	0.033000	0.057000	0.037000	0.048000	0.023000	0.052000	0.061000	
21	0.034000	0.054000	0.042000		0.028000		0.059000	0.072000
22	0.038000		0.038000	0.062000	0.023000	0.035000	0.073000	0.067000
23	0.037000	0.064000	0.052000	0.050000	0.031000	0.027000	0.060000	0.077000
24	0.040000	0.057000	0.046000	0.056000	0.026000	0.041000	0.068000	
25	0.064000	0.057000	0.052000		0.032000		0.066000	0.098000
26	0.048000		0.047000	0.071000	0.024000	0.047000	0.067000	0.080000
27	0.045000	0.060000	0.069000	0.062000	0.041000	0.043000	0.068000	0.083000
28	0.050000	0.071000	0.059000	0.079000	0.032000	0.046000	0.075000	
29	0.047000	0.068000	0.066000		0.035000		0.073000	0.094000
30	0.051000		0.056000	0.071000	0.024000	0.037000	0.069000	0.074000
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: *William Corbett* 5-5-2022  
 Date: 5/5/2022 Title: Chief Plant Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



**Massachusetts Department of Environmental Protection - Drinking Water Program**  
**TURBIDITY - INDIVIDUAL FILTER MONITORING**  
**For Conventional or Direct Filtered Systems**

SWTR  
J

**III. DAILY REPORTING**

Day	Filter Number 5		Filter Number 6		Filter Number 7		Filter Number 8	
	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU
1	0.062000	0.131000	0.042000	0.138000	0.076000	0.166000	0.024000	0.104000
2	0.055000	0.134000	0.042000	0.136000	0.074000	0.157000	0.022000	0.091000
3	0.053000	0.262000	0.043000	0.117000	0.079000		0.025000	
4	0.058000		0.045000		0.076000	0.169000	0.021000	0.190000
5	0.054000	0.106000	0.039000	0.099000	0.075000	0.119000	0.020000	0.049000
6	0.055000	0.105000	0.039000	0.094000	0.076000	0.136000	0.022000	0.105000
7	0.051000	0.138000	0.040000	0.072000	0.083000		0.028000	
8	0.056000		0.051000		0.081000	0.127000	0.024000	0.127000
9	0.050000	0.147000	0.037000	0.127000	0.073000	0.142000	0.019000	0.084000
10	0.049000	0.111000	0.054000	0.075000	0.076000	0.149000	0.020000	0.106000
11	0.051000	0.127000	0.038000	0.115000	0.081000		0.024000	
12	0.249000		0.222000		0.076000	0.165000	0.023000	0.162000
13	0.060000	0.189000	0.041000	0.047000	0.084000	0.087000	0.022000	0.030000
14	0.044000	0.053000	0.038000	0.052000	0.080000	0.093000	0.026000	
15	0.048000	0.056000	0.044000		0.087000		0.024000	0.035000
16	0.051000		0.043000	0.061000	0.086000	0.097000	0.029000	0.046000
17	0.050000	0.059000	0.046000	0.059000	0.090000	0.108000	0.033000	0.046000
18	0.050000	0.069000	0.042000	0.061000	0.089000	0.106000	0.036000	
19	0.044000	0.061000	0.045000		0.093000		0.032000	0.044000
20	0.048000		0.041000	0.054000	0.091000	0.105000	0.055000	0.046000
21	0.046000	0.067000	0.061000	0.054000	0.092000	0.111000	0.036000	0.058000
22	0.045000	0.048000	0.043000	0.053000	0.095000	0.109000	0.041000	
23	0.032000	0.045000	0.046000		0.100000		0.040000	0.059000
24	0.034000		0.043000	0.061000	0.099000	0.116000	0.044000	0.072000
25	0.034000	0.062000	0.048000	0.080000	0.105000	0.133000	0.073000	0.060000
26	0.058000	0.047000	0.066000	0.054000	0.107000	0.137000	0.053000	
27	0.039000	0.053000	0.054000		0.116000		0.054000	0.067000
28	0.039000		0.047000	0.072000	0.111000	0.139000	0.056000	0.091000
29	0.038000	0.063000	0.052000	0.068000	0.115000	0.142000	0.053000	0.075000
30	0.029000	0.049000	0.044000	0.060000	0.110000	0.124000	0.057000	
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: *William Coakley* 5-5-2022  
 Date: 5/5/2022 Title: Chief Plant Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program  
**CHLORINE/CHLORAMINES - MONTHLY REPORT**

I. PWS INFORMATION: PWS ID #: **4133000** PWS Name: **TOWN OF HOLBROOK** City/Town: **HOLBROOK** Class: COM  NTNC  TNC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section. Analytical Method: SM 4500-Cl:  D  E  F  G  H  I ASTM D1263-86

Notes:

DEP Sample Type <sup>1,4</sup>	DEP Location Code # <sup>1</sup>	DEP Approved SAMPLE LOCATION <sup>1</sup>	CHLORINE RESULT <sup>1</sup> (mg/L)	COLLECTION AND ANALYSIS <sup>2</sup> DATE	TIME	COLLECTED AND ANALYZED BY
RS	001	TOWN HALL	1.27	4/4/2022	07:15	J. MacLaine
RS	004	COTTAGE VARIETY	1.29	4/4/2022	07:35	J. MacLaine
RS	008E	STEWARTS POWER EQUIPMENT	.03	4/4/2022	09:10	J. MacLaine
RS	006	COMMUNITY CENTER	.62	4/4/2022	08:50	J. MacLaine
RS	001	TOWN HALL	1.33	4/11/2022	07:30	J. MacLaine
RS	004	COTTAGE VARIETY	1.42	4/11/2022	08:00	J. MacLaine
RS	008E	STEWARTS POWER EQUIPMENT	.04	4/11/2022	07:45	J. MacLaine
RS	006	COMMUNITY CENTER	1.08	4/11/2022	08:30	J. MacLaine
RS	001	TOWN HALL	1.06	4/20/2022	07:20	J. MacLaine
RS	004	COTTAGE VARIETY	1.30	4/20/2022	08:45	J. MacLaine
RS	008E	STEWARTS POWER EQUIPMENT	.12	4/20/2022	09:00	J. MacLaine
RS	006	COMMUNITY CENTER	.32	4/20/2022	07:35	J. MacLaine
RS	001	TOWN HALL	1.39	4/26/2022	07:15	J. MacLaine
RS	004	COTTAGE VARIETY	1.42	4/26/2022	07:55	J. MacLaine
RS	008E	STEWARTS POWER EQUIPMENT	.02	4/26/2022	08:45	J. MacLaine
RS	006	COMMUNITY CENTER	.94	4/26/2022	07:35	J. MacLaine

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month<sup>5</sup>: **66** Average Chlorine Result of All Samples For Month<sup>5</sup> (mg/L): **1.27**

Primary Certified Operator Signature and Date: *[Signature]* 5-2-2022

DEP Review Status:  Accepted  Disapproved Review Comments:

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

# CHILDREN'S CHEMICAL ORGANISMES - MONTHLY REPORT

## 1. PWS INFORMATION:

PWS ID #: 4244000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: COM  NTWC  TWC   
 H. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DEPR monitoring plan to help complete this section.  
 Type Illustrated:  Free Chlorine  Total Chlorine  Combined Chlorine  
 Analytical Method: SM 4500-Cl; DP 01E 01F 02G 01H 01 ASTM D1293-06

DEPR Sample Type	DEPR Location Code	DEPR Approved Sampling Location	CHLORINE RESIDUE (mg/L)	DATE	TIME	COLLECTED AND ANALYZED BY
RS	003	TOWER HILL SCHOOL ... ADAMS STREET	1.50	4/4/2011	10:30 AM	A. PIERRE-LOUIS
RS	004	JFK SCHOOL ... 20 HURLBY DRIVE	1.51		7:30 AM	
RS	008	MARTIN E. YOUNG SCHOOL, COURTESY DRIVE	1.11		8:00 AM	
RS	009	2074 NORTH MAIN STREET	1.61		11:30 AM	
RS	008	NORTH MIDDLE SCHOOL ... HIGH STREET	1.64		11:00 AM	
RS	011	MOELL STATION ... 89 MAZZEO DRIVE	1.45		10:00 AM	
RS	012	7 ... 11 FOOD SHOP ... 676 NORTH STREET	1.33		9:00 AM	
RS	014	7 ... 11 NORTH MAIN STREET	NO ACCESS	DVE	TO	COVID-19
RS	014E	ARR AUTO - 317 NORTH MAIN ST	1.58		9:30 AM	
RS	01C	OAK GROVE STAMPING	1.28		10:15 AM	
RS	01T	SOUTH MAIN STREET STAMPING	1.07		8:15 AM	

1. DEPR Sample Type, Location Code, and DEPR Approved Sampling Site Location must correspond to the same information on your DEPR Total Coliform Sampling Plan.  
 2. SWTR system type must be indicated as either surface or groundwater and results reported on the DEPR analytical report must correspond to the DEPR analytical report.  
 3. Collection and Analysis of the sample should be performed in the field (immediately upon collection) at the same time and location in the distribution system as the sample, except for samples collected by DEPR.  
 4. Samples from the distribution system, including the DEPR analytical report, DEPR analytical report, DEPR analytical report, or DEPR analytical report, should be analyzed by DEPR.  
 5. All DEPR analytical reports should be analyzed and included in determining compliance, even if the number is greater than the minimum required. If you collect representative samples which the distribution system during the month, you must also maintain a record of the representative samples and include these samples, DO NOT include raw water (RW) or plain tap (PT) chlorine residual samples in your calculations.

DEPR Reviewer Signature:  Approved  Disapproved Reviewer Comments: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Average Chlorine Residual of All Samples: \_\_\_\_\_ (mg/L) \_\_\_\_\_  
 Analytical Method: \_\_\_\_\_  
 Date: \_\_\_\_\_



# CHILDREN'S CHELORINE/CHELORAMINES - MONTHLY REPORT

1. PWS INFORMATION:

PWS ID NO: 4224000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class:  CMV  TWC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Collection Sampling Plan and/or DEPR monitoring plan to help complete this section.

Type of Sample:  Free Chlorine  Total Chlorine  Combined Chlorine Analytical Method:  SM 4500-Cl  DP  DE  DF  DM  ASTM D1245-06

Notes:

DEPR Sample Type	DEPR Location Code	DEPR Approved Sampling Location	CHLORINE RESULT (mg/L)	COLLECTION DATE	TIME	COLLECTED AND ANALYZED BY
RS	003	TOWER HILL SCHOOL, ... ADAMS STREET	1.36	4/11/2011	10:00 AM	A. PIERRE-LOUIS
RS	004	JFK SCHOOL, ... 20 HURLEY DRIVE	1.50		9:30 AM	
RS	008	MARTIN E. YOUNG SCHOOL, COURTNEY DRIVE	1.18		8:00 AM	
RS	006	... INN, ... 1574 NORTH MAIN STREET	1.74		11:00 AM	
RS	008	NORTH MIDDLE SCHOOL, ... HIGH STREET	1.43		10:30 AM	
RS	011	MOBIL STATION, ... 88 MAZZEO DRIVE	1.32		9:30 AM	
RS	012	... FOOD SHOP, ... 978 NORTH STREET	1.05		9:00 AM	
RS	014E	ARR AUTO - 317 NORTH MAIN STREET	1.52			
RS	014A	... NORTH MAIN STREET	NO ACCESS	DUE TO	CONDO - 19	
RS	016	OAK GROVE STANDPIPE	1.04		9:45 AM	
RS	017	SOUTH MAIN STREET STANDPIPE	1.05		8:15 AM	

DEPR Sample Type Location Code, and DEPR Approved Sample Site Location must correspond to the same information on your DEPR Total Chlorine Sampling Plan.

SWTR system (WTS) must be collected at distribution sites with zero chlorine residual and (could be reported on the DEPR analytical report form and on the appropriate SWTR Form).

Collection and Analytical data reported on the field (analytical report) at the same time and location in the distribution system as total chlorine are required. Report all values as (Free), (Total) and (Combined) Chlorine. Report (Free) Chlorine as (Free) Chlorine, (Total) Chlorine as (Total) Chlorine, and (Combined) Chlorine as (Combined) Chlorine.

All DEPR analytical samples taken and analyzed during the monitoring compliance, even if that number is greater than the minimum required, if you collect representative samples within the distribution system during the month, you must also monitor for a detectable chlorine residual at the report site and include these samples in your violations.

MR. DEPR ANALYST: [Signature] Present at or delegates collected for Monthly: 66 Average Chlorine Residual of All Samples for Month: (mg/L): 1.27

Under the penalty of law that I am the person authorized to fill out the report and the information contained herein is true, complete and conformable to the best of my knowledge.

DEPR Review Status:  Accepted  Disapproved  Pending Comments: [Signature]







Massachusetts Department of Environmental Protection - Drinking Water Program  
**Disinfection Byproducts Rule Compliance Report**

DBPR

**I. PWS INFORMATION** - Please refer to your DBPR Monitoring Plan to help complete this form.

PWS ID #: 4244001 City / Town: RANDOLPH  
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM  NTNC  TNC   
 Monitoring Period (YEAR): 2022 Monitoring Period (QUARTER):  Q1 (Jan-Mar)  Q2 (Apr-Jun)  Q3 (Jul-Sep)  Q4 (Oct-Dec)

**II. FOR SYSTEMS USING CHLORINATION**

**A. Trihalomethanes (TTHM)**  
 Total Number of TTHM Samples: \_\_\_\_\_ Quarterly Average: \_\_\_\_\_ µg/L  
 Was the Running Annual Average MCL (80 µg/L) exceeded? Yes  No  Running Annual Average: \_\_\_\_\_ µg/L

**B. Haloacetic Acids (HAA5)**  
 Total Number of HAA5 Samples: \_\_\_\_\_ Quarterly Average: \_\_\_\_\_ µg/L  
 Was the Running Annual Average MCL (60 µg/L) exceeded? Yes  No  Running Annual Average: \_\_\_\_\_ µg/L

**C. Chlorine/Chloramines**  
 Total Number of Samples: \_\_\_\_\_ Monthly Averages: \_\_\_\_\_ mg/L  
 Month 1: 166 APRIL  
 Month 2: \_\_\_\_\_ MAY  
 Month 3: \_\_\_\_\_ JUNE  
 Quarterly Average: 1.27 mg/L  
 Was the Running Annual Average MRDL (4.0 mg/L) exceeded? Yes  No  Running Annual Average: 1.25 mg/L

**D. Total Organic Carbon - raw (TOC)** (Required for SW or GWUDI Plant Name: \_\_\_\_\_  
systems >499 seeking or approved to reduce TTHM/HAA5 monitoring.)  
 Total Number of Samples: \_\_\_\_\_ Monthly Averages: \_\_\_\_\_ mg/L  
 Month 1: \_\_\_\_\_  
 Month 2: \_\_\_\_\_  
 Month 3: \_\_\_\_\_  
 Quarterly Average: \_\_\_\_\_ mg/L  
 Was the (4.0 mg/L) threshold exceeded? Yes  No  Running Annual Average: \_\_\_\_\_ mg/L  
(Attach additional sheet(s) to report more than 1 plant)

**III. FOR SYSTEMS USING OZONATION**

**E. Bromate (treated)** Plant Name: \_\_\_\_\_  
 Total Number of Samples: \_\_\_\_\_ Monthly Averages: \_\_\_\_\_ mg/L  
 Month 1: \_\_\_\_\_  
 Month 2: \_\_\_\_\_  
 Month 3: \_\_\_\_\_  
 Quarterly Average: \_\_\_\_\_ mg/L  
 Was the Running Annual Average MCL (0.010 µg/l) exceeded? Yes  No  Running Annual Average: \_\_\_\_\_ mg/L

**F. Bromide (raw)** Plant Name: \_\_\_\_\_  
Required for systems seeking or approved to reduce Bromate monitoring  
 Total Number of Samples: \_\_\_\_\_ Monthly Averages: \_\_\_\_\_ mg/L  
 Month 1: \_\_\_\_\_  
 Month 2: \_\_\_\_\_  
 Month 3: \_\_\_\_\_  
 Quarterly Average: \_\_\_\_\_ mg/L  
 Was the (0.05 mg/l) threshold exceeded? Yes  No  Running Annual Average: \_\_\_\_\_ mg/L

**IV. FOR SYSTEMS USING CHLORINE DIOXIDE**

Report compliance information on your online/Phone/Email/Provide Daily Samples Power  
 I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge.

Primary Certified Operator Signature: William Cookerly Date: 5-2-2022

DEFINITIONS	
MONTHLY AVERAGE:	Monthly average = average of all results within the current month.
QUARTERLY AVERAGE:	Quarterly Average = average result of all locations sampled during monitoring period
RUNNING ANNUAL AVERAGE:	Running Annual Average = Average of 4 quarters. Average of this quarter and three prior consecutive quarterly averages (for systems on quarterly monitoring)
TOTAL NUMBER OF SAMPLES:	Total number of samples collected during the monitoring period.

NOTE: Record and calculate all ND or <MDL results as the number zero (0).

Submit one copy of this form each quarter to your DEP regional office (by Jan 10<sup>th</sup>, April 10<sup>th</sup>, July 10<sup>th</sup>, and Oct 10<sup>th</sup> of each year)

DEP REVIEW STATUS (Initial & Date)  
 Accepted  Disapproved

Review Comments: \_\_\_\_\_