



Town of Holbrook
Office of Joint Superintendent
(781) 767-1800

RANDOLPH-HOLBROOK JOINT WATER BOARD

50 North Franklin Street
Holbrook, MA 02343



Town of Randolph

March 8, 2022

Commonwealth of Massachusetts
Department of Environmental Protection
Southeast Regional Office
20 Riverside Drive
Lakeville, MA 02374

Monthly Reports Filtered System Forms
Forms F, G, I, J, TT
Analysis for TOC, DOC, SUVA
Chemical Addition Reports
DBPR Compliance Report
February, 2022 Randolph/Holbrook
Joint Water System, PWS #424001

Gentlemen:

Enclosed please find all reports as referenced above for the month of February, 2022. Should there be any questions, please do not hesitate to call me.

Sincerely,

William Cookerly
Chief Plant Operator

Enclosures

Cc: Board of Health Holbrook
Board of Health Randolph
Brian Howard, Town Manager, Randolph
Ryan Allgrove, EPG



Compliance Determination for Filtered Systems - Monthly Report

PWS INFORMATION

PWSID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH
Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period -> Month: FEBRUARY Year: 2022

TURBIDITY PERFORMANCE CRITERIA

1. Monthly Turbidity (95%) NTU Limit - The turbidity level of a system's filtered water must be less than or equal to the Monthly Turbidity NTU Limit in at least 95% of the measurements taken each month for the filtration technology used, otherwise SWTR TT Violation (Tier 2).
168 = A Total # of filtered water turbidity measurements for month (SWTR - Form F)
168 = B Total # of filtered water turbidity measurements less than or equal to the specified limits for the filtration technology used.
100 = (B / A) x 100 The percentage of turbidity measurements meeting the Monthly Turbidity 95% NTU Limit.
2. Max Day NTU Limit - The turbidity level of a system's filtered water must at no time exceed the Max Day NTU Limit for the filtration technology used, otherwise SWTR TT Violation (Tier 2).
Record the date and turbidity value for any measurements exceeding the Max Day NTU. Check box [X] if "None"
Table with columns: Date, Value, Date Reported to DEP.
For each day the Max Day NTU limit is exceeded, the DEP must be notified by the end of the next business day. SWTR TT Violation (Tier 2). If DEP is not consulted within 24 hours then it is a SWTR TT (Tier 1) violation requiring public notification within 24 hours.

DISINFECTION PERFORMANCE CRITERIA

1. Point-of-Entry Minimum Disinfectant Residual Criteria - Residual Disinfectant concentration cannot be < 0.2 mg/L for more than 4 hours. SWTR TT Violation (Tier 2).
Minimum Disinfectant Residual at Point-of-Entry to Distribution System.
Table with columns: Day, Cl2 mg/l.
If at any time the residual falls below 0.2 mg/l in the water entering the distribution system, the supplier of water must notify the Department as soon as possible, but no later than by the end of the next business day. The supplier of water also must notify the Department by the end of the next business day whether or not the residual was restored to at least 0.2 mg/l within four hours.
Table with columns: Date(s) Residual < 0.2 mg/l, Duration of Low Level (hrs.), Date Reported to DEP.

2. Distribution System Disinfectant Residual Criteria - Residual Disinfectant concentration (V) cannot be undetectable in greater than 5% of samples in a month, for any two consecutive months. SWTR TT Violation (Tier 2). Chlorine residuals must be measured at the same time and location as total coliform distribution routine & repeat samples. If no residual is detected, an HPC sample must be collected and analyzed.
Total # of HPC samples taken during month: 62 # HPC sites > 500/mL: 0 # HPC sites <= 500/mL: 62
65 = a # of sites where Cl2 residual measurements were made, whether a residual was detected or not (should be the same # of sites reported on your monthly DBPR Cl2 residual report)
0 = b # of sites HPC samples were analyzed instead of Cl2 residual measurements
0 = c # of sites where no Cl2 residual was detected and no HPC sample was analyzed
0 = d # of sites where no Cl2 residual was detected and HPC > 500 CFU/mL
0 = e # of sites where no Cl2 residual measurement was made and HPC > 500 CFU/mL

Water in the distribution system with a heterotrophic bacteria concentration (HPC) less than or equal to 500/mL, is deemed to have a detectable disinfectant residual for purposes of determining compliance with this requirement. When analyzed, report HPC results on your monthly DEP Bacteriological Report.
V = ((c + d + e) / (a + b)) x 100 This Month % V = 0 Previous Month % V = 0 Is V > 5% for 2 months? [X] Yes or [] No

I certify under penalties of law that I am the person authorized 3/9/2022 William Cookley Chief Operator



Massachusetts Department of Environmental Protection - Drinking Water Program
 TURBIDITY DATA SHEET FOR FILTERED SYSTEMS

SWTR
F

PWS INFORMATION

PWSID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH
 Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period → Month: FEBRUARY Year: 2022

DETAILS REPORTING

Filtered Water Turbidity Measured: (check only one) Combined Filter Effluent Individual Filter Effluent Clearwell Plant Effluent

Filtration Technology: Conventional Direct Alternative Slow Sand Diatomaceous Earth
 Monthly Turbidity (95%) NTU Limit = 0.3 Max Day Turbidity NTU Limit = 1
 Monthly Turbidity (95%) NTU Limit = 1 Max Day Turbidity NTU Limit = 5

Day	Max Filtered Water Turbidity Results (NTU)	Number of Turbidity Measurements	Number of Turbidity Measurements Monthly (95%) NTU Limit	Number of Turbidity Measurements Max Day NTU Limit
	.06	6	6	0
	.03	6	6	0
	.05	6	6	0
	.07	6	6	0
	.03	6	6	0
	.06	6	6	0
	.07	6	6	0
	.04	6	6	0
	.04	6	6	0
	.04	6	6	0
	.04	6	6	0
	.04	6	6	0
	.06	6	6	0
	.04	6	6	0
	.06	6	6	0
	.03	6	6	0
	.05	6	6	0
	.03	6	6	0
	.05	6	6	0
	.03	6	6	0
	.05	6	6	0
	.04	6	6	0
	.05	6	6	0
	.04	6	6	0
	.04	6	6	0
	.07	6	6	0
	.04	6	6	0
	.07	6	6	0
Totals		168	168	0

% Turbidity Meeting 95% Limit
 B/A = 100%
 (Enter on SWTR - Form G)

May be used by systems serving less than 10,000 persons, subject to DEP approval.
 Enter the Maximum Filtered Water Turbidity Result recorded each day, at the 4th hour or other approved interval.
 Enter the Total # of Turbidity measurements taken for each day. Measurements must be taken at a minimum of 4-hour intervals (i.e. 6 readings per day).
 For continuous monitors count each 4-hour period as 1 measurement. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. If DEP approved, 15-minute readings (i.e. 96 readings per day) may be submitted. Filtered turbidity data must be kept on file for DEP review.
 Out of the # of turbidity measurements taken and recorded in the previous column, enter the number of turbidity measurements that were less than or equal to the Monthly (95%) NTU Limit for the filtration technology used.
 If at any time the filtered turbidity Max Day NTU Limit is exceeded, the DEP must be notified no later than the end of the next business day. For each exceedance, record the turbidity value(s) and date(s) on SWTR - Form G

PWS Authorized Signature: William Cookerly
 Date: 3-1-2022 Title: Chief Plant Operator



Massachusetts Department of Environmental Protection - Drinking Water Program
CT Determination for Filtered Systems

SWTR
 I

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph-Holliston Joint Water PWS Town: Randolph
 Treatment Plant Name: Randolph Water Plant Reporting Period → Month: February Year: 2022
 Disinfectant¹: Chlorine Dioxide/Filter Eff. Sequence of Application: 1st 2nd 3rd 4th 5 6th

II. DAILY REPORTING: All measurements taken during peak hourly flow.

Day	Peak Hourly Flow ² (gpm)	Disinfectant Concentration ³ C (mg/L)	Disinfectant Contact Time ⁴ T (min.)	CT calc (= C x T)	pH ⁵	Water Temp ⁶ (°C)	CT ⁷ 99.9	Inactivation Ratio ⁸ (CT calc / CT 99.9)	Inactivation Ratio ⁹ < 1.0
1	2,400	1.75	50	87.5	5.90	4.6	17	5.2	<input type="checkbox"/> Yes
2	2,400	2.06	50	103	6.10	4.8	17	6.1	<input type="checkbox"/> Yes
3	2,400	2.05	50	102.5	6.10	4.2	17	6.0	<input type="checkbox"/> Yes
4	2,400	2.03	50	101.5	6.00	4.0	17	6.0	<input type="checkbox"/> Yes
5	2,400	1.77	50	88.5	6.15	4.0	17	5.2	<input type="checkbox"/> Yes
6	2,400	1.63	50	81.5	5.90	3.9	17	4.8	<input type="checkbox"/> Yes
7	2,400	1.52	50	76	6.15	4.3	17	4.5	<input type="checkbox"/> Yes
8	2,400	1.79	50	89.5	6.00	4.2	17	5.3	<input type="checkbox"/> Yes
9	2,400	1.86	50	93	6.20	3.8	17	5.5	<input type="checkbox"/> Yes
10	2,400	1.77	50	88.5	6.10	3.8	17	5.2	<input type="checkbox"/> Yes
11	2,400	2.05	50	102.5	6.10	4.1	17	6.0	<input type="checkbox"/> Yes
12	2,400	1.70	50	85	6.05	4.0	17	5.0	<input type="checkbox"/> Yes
13	2,400	1.83	50	91.5	6.20	4.4	17	5.4	<input type="checkbox"/> Yes
14	2,400	1.78	50	89	6.20	5.0	17	5.2	<input type="checkbox"/> Yes
15	2,400	1.80	50	90	6.25	4.3	17	5.3	<input type="checkbox"/> Yes
16	2,400	1.66	50	83	6.05	4.9	17	4.9	<input type="checkbox"/> Yes
17	2,400	1.89	50	94.5	6.10	5.0	17	5.6	<input type="checkbox"/> Yes
18	2,400	1.96	50	98	6.10	4.0	17	5.8	<input type="checkbox"/> Yes
19	2,400	2.01	50	100.5	6.00	3.6	17	5.9	<input type="checkbox"/> Yes
20	2,400	1.58	50	79	6.00	3.8	17	4.7	<input type="checkbox"/> Yes
21	2,400	1.70	50	85	6.10	3.8	17	5.0	<input type="checkbox"/> Yes
22	2,400	1.89	50	94.5	6.00	3.9	17	5.6	<input type="checkbox"/> Yes
23	2,400	1.63	50	81.5	6.00	4.0	17	4.8	<input type="checkbox"/> Yes
24	2,400	1.99	50	99.5	6.20	3.7	17	5.9	<input type="checkbox"/> Yes
25	2,400	1.89	50	94.5	6.15	4.1	17	5.6	<input type="checkbox"/> Yes
26	2,400	1.86	50	93	6.20	4.0	17	5.5	<input type="checkbox"/> Yes
27	2,400	1.78	50	89	6.10	4.4	17	5.2	<input type="checkbox"/> Yes
28	2,400	1.91	50	95.5	5.90	4.8	17	5.6	<input type="checkbox"/> Yes
29									<input type="checkbox"/> Yes
30									<input type="checkbox"/> Yes
31									<input type="checkbox"/> Yes

1. Use a separate form for each disinfectant/sampling point. Enter disinfectant and sequence position, e.g. "ozone/1st" or "ClO₂/3rd". If more than one disinfectant sampling point, you must also complete SWTR Form H and calculate the cumulative inactivation ratio SUM (CTcalc/CT99.9) to determine compliance.
2. Peak hourly flow means the highest pumpage *hour* during the day, not the absolute peak flow at any instant.
3. The residual disinfectant concentration(s) ("C") of the water before or at the first customer must be measured each day during peak hourly flow.
4. The disinfectant contact time(s) ("T") must be determined for each day during peak hourly flow. The time T used in calculating CT, is the time it takes the water, during peak hourly flow, to move between the point of disinfection application and the point at which the residual is measured.
5. If the system uses free chlorine, the pH of the disinfected water must be measured at least once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
6. The temperature of the disinfected water must be measured at least once per day at each residual disinfectant concentration sampling point during peak hourly flow.
7. Use Inactivation Tables at 310 CMR 22.20A Tables 1.1 – 1.6, 2.1 and/or 3.1
8. The inactivation ratio (CTcalc/CT99.9) is determined before or at the first customer during peak hourly flow and if the (CTcalc/CT99.9) is < 1.0, the 99.9% *Giardia lamblia* inactivation requirement has not been achieved.
9. More than one "Yes" response above may indicate a SWTR Treatment Technique violation (Tier 2).

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Costello
 Date: 3-1-2022 Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information - Refer to MassDEP Chemical Addition Report Guidance and Instructions for details.					
PWS Name ¹ :	RANDOLPH-HOLBROOK JW	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-01T	Reporting Period ³ :	FEBRUARY 2022
			Month	Year	

II. Chemical & Operational Information						
Chemical Name ⁴ :	POLYALUMINUM CHLORIDE		Purchased Strength ⁵ :	1.0	Target Range/min ¹² :	14
Manufacturer ⁵ :	HOLLAND COMPANY		Purchased Density (lbs/gal) ⁹ :	10.3	Target Dose ¹³ :	18
Product Name ⁶ :	PCH-180		Dilution Factor or Mix Ratio ¹⁰ :	NA	Alarm Setting (low) ¹⁴ :	NA
Reason for Adding Chemical ⁷ :	COAGULATION		NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	NA
			Date of last anti-siphon valve inspection/replacement ¹⁵ :			NA

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁸	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured ²⁰ , Results, Units and Method ²¹ - (G) Grab or Continuous (A) Analyzer ²¹			O&M Notes/Comments ²²
	<input type="checkbox"/> Gallons	<input checked="" type="checkbox"/> MG	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. RAW PH DAILY AVG	b.	c.	
1		2.8	98		1,009	14	7.00	<input checked="" type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	
2		2.9	181		1,864	25	6.95			
3		2.9	172		1,772	24	6.90			
4		2.8	110		1,133	16	7.10			
5		2.8	110		1,133	16	7.05			
6		2.9	110		1,133	16	6.90			
7		2.8	115		1,185	17	6.95			
8		1.8	70		721	16	7.00			PLANT DOWN FOR BASIN CLEANING
9		2.9	108		1,112	15	6.85			
10		2.9	122		1,257	17	6.90			
11		2.7	125		1,288	19	6.95			
12		2.9	130		1,339	18	6.85			
13		2.8	120		1,236	18	6.85			
14		2.8	105		1,082	15	6.80			
15		2.7	105		1,082	16	6.90			
16		2.7	107		1,102	16	6.85			
17		2.8	124		1,277	18	6.85			
18		2.8	131		1,349	19	6.90			
19		2.9	128		1,318	18	6.90			
20		2.8	130		1,339	19	6.80			
21		2.8	130		1,339	19	7.00			
22		2.8	115		1,185	17	7.00			
23		2.7	120		1,236	18	6.90			
24		2.8	126		1,298	18	6.95			
25		2.8	136		1,401	20	6.80			
26		2.8	130		1,339	19	6.85			
27		2.7	120		1,236	18	6.95			
28		2.8	125		1,288	18	7.00			
29										
30										
31										
Total	Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ :									

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

a. Raw Ph, Daily Average, Test Kit

PWS Authorized Person - Signature & Date²⁴:
 William Cookery 3-1-2022
 Print Name: William Cookery, Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JOINT WATER	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-DIT	Reporting Period ² :	FEBRUARY 2022 Month Year

II. Chemical & Operational Information

Chemical Name ⁴ :	CHLORINE	Purchased Strength ⁴ :	1.0	Target Range/min ¹² :	0.20
Manufacturer ⁴ :	AXIALI, LLC	Purchased Density (lbs/gal) ⁹ :	12.3	Target Dose ¹³ :	NA
Product Name ⁴ :	CHLORINE	Dilution Factor or Mix Ratio ¹⁰ :	NA	Alarm Setting (low) ¹⁴ :	1.0
Reason for Adding Chemical ⁷ :	DISINFECTANT	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	3.0
		Date of last anti-siphon valve inspection/replacement ¹⁵ :	NA		

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁸	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured ⁸ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²²	
	<input checked="" type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)	Chemical Dosage ¹⁹ (mg/L)			a. FREE CL ₂ DAILY AVE	b. FREE CL ₂ DAILY MAXIMUM	c.		
								<input checked="" type="checkbox"/> G <input type="checkbox"/> A			
1	2.8		86		3.7	2.13	1.75				
2	2.9		83		3.4	2.31	2.06				
3	2.9		93		4.0	2.25	2.05				
4	2.8		94		4.0	2.17	2.03				
5	2.8		89		3.8	2.12	1.77				
6	2.9		98		4.1	2.11	1.63				
7	2.8		83		3.6	2.03	1.52				
8	1.8		50		3.3	2.13	1.79				PLANT DOWN - BASIN CLEANING
9	2.9		89		3.7	2.36	1.86				
10	2.9		89		3.7	2.20	1.77				
11	2.7		89		4.0	2.32	2.05				
12	2.9		98		4.1	2.22	1.70				
13	2.8		98		4.2	2.25	1.83				
14	2.8		96		4.1	2.15	1.78				
15	2.7		87		3.7	2.13	1.80				
16	2.7		85		3.8	2.05	1.66				
17	2.8		89		3.8	2.05	1.89				
18	2.8		87		3.7	2.18	1.96				
19	2.9		84		3.6	2.28	2.01				
20	2.8		92		3.9	2.15	1.58				
21	2.8		96		4.1	2.27	1.70				
22	2.8		89		3.8	2.20	1.89				
23	2.7		86		3.8	2.16	1.63				
24	2.8		86		3.7	2.26	1.99				
25	2.8		88		3.8	2.24	1.89				
26	2.8		87		3.7	2.17	1.86				
27	2.7		92		4.1	2.22	1.78				
28	2.8		91		3.9	2.39	1.91				
29											
30											
31											
Total	Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ :										

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

a. Daily Average, Free Chlorine, Finished Water, Grab Sample
 b. Daily Maximum, Free Chlorine, Finished Water, Test Kit
 c.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.
 PWS Authorized Person - Signature & Date²⁴:
 William Cookery 3-1-2022
 Print Name: William Cookery Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JW	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-01T	Reporting Period ² :	FEBRUARY 2022 Month Year

II. Chemical & Operational Information

Chemical Name ⁴ :	CALCIUM HYDROXIDE	Purchased Strength ⁸ :	0.85	Target Range/min ¹² :	NA
Manufacturer ⁶ :	CARMEUSE LIME & STONE	Purchased Density (lbs/gal) ⁸ :	18.7	Target Dose ¹² :	NA
Product Name ⁶ :	HYDRATED LIME	Dilution Factor or Mix Ratio ¹⁰ :	NA	Alarm Setting (low) ¹⁴ :	NA
Reason for Adding Chemical ⁷ :	PH ADJUSTMENT	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	NA
		Date of last anti-siphon valve inspection/replacement ¹⁵ :	NA		

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁸		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁹	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured ²⁰ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²²	
	<input type="checkbox"/> Gallons	<input checked="" type="checkbox"/> MG	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. FINISHED PH	b.	c.		
1			2.7	100		4.4	7.10	<input checked="" type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	
2			2.8	100		4.3	7.00				
3			2.8	100		4.3	7.00				
4			2.8	100		4.3	7.05				
5			2.8	100		4.3	6.95				
6			2.9	100		4.1	7.05				
7			2.7	100		4.4	7.05				
8			1.6	60		4.5	6.90				PLANT DOWN - BASIN CLEANING
9			2.9	100		4.1	6.95				
10			2.9	100		4.1	7.05				
11			2.7	100		4.4	7.10				
12			2.8	100		4.3	7.15				
13			2.8	100		4.3	7.10				
14			2.8	100		4.3	7.10				
15			2.7	100		4.4	7.05				
16			2.7	100		4.4	7.10				
17			2.8	100		4.3	7.10				
18			2.8	100		4.3	7.00				
19			2.8	100		4.3	6.95				
20			2.8	100		4.3	7.00				
21			2.8	100		4.3	7.05				
22			2.8	100		4.3	7.00				
23			2.7	100		4.4	7.05				
24			2.8	100		4.3	7.10				
25			2.8	100		4.3	7.05				
26			2.8	100		4.3	6.90				
27			2.7	100		4.4	6.90				
28			2.8	100		4.3	7.10				
29											
30											
31											

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:

²³Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:
²⁴I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

a. *Finished Water Ph, Daily Average Test Kit*
 b. *William Cookery 3-1-2022*
 c. *William Cookery Chief Operator*



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information – Refer to MassDEP “Chemical Addition Report Guidance and Instructions” for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JW	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-01T	Reporting Period ² :	FEBRUARY 2022
				Month	Year

II. Chemical & Operational Information

Chemical Name ⁴ :	SODIUM BISULFATE	Purchased Strength ⁸ :	10-15	Target Range/min ¹² :	NA
Manufacturer ⁶ :	CARUS CORPORATION	Purchased Density (lbs/gal) ⁹ :	12.03	Target Dose ¹³ :	NA
Product Name ⁵ :	CARUS 3350	Dilution Factor or Mix Ratio ¹⁰ :	0.33	Alarm Setting (low) ¹⁴ :	NA
Reason for Adding Chemical ⁷ :	CORROSION INHIBITOR	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	NA
				Date of last anti-siphon valve inspection/replacement ¹⁵ :	NA

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶	Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁵	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured ¹⁷ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²²
	<input type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. FINISHED PH <input checked="" type="checkbox"/> G <input type="checkbox"/> A	b. <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A	
1	2.7		50	2.2	7.10				
2	2.8		50	2.1	7.00				
3	2.8		50	2.1	7.00				
4	2.8		50	2.1	7.05				
5	2.8		50	2.1	6.95				
6	2.9		50	2.1	7.05				
7	2.7		50	2.2	7.05				
8	1.6		35	2.6	6.90				PLANT DOWN - BASIN CLEANING
9	2.9		50	2.1	6.95				
10	2.9		50	2.1	7.05				
11	2.7		50	2.2	7.10				
12	2.8		50	2.1	7.15				
13	2.8		50	2.1	7.10				
14	2.8		50	2.1	7.10				
15	2.7		50	2.2	7.05				
16	2.7		50	2.2	7.10				
17	2.8		50	2.1	7.10				
18	2.8		50	2.1	7.00				
19	2.8		50	2.1	6.95				
20	2.8		50	2.1	7.00				
21	2.8		50	2.1	7.05				
22	2.8		50	2.1	7.00				
23	2.7		50	2.2	7.05				
24	2.8		50	2.2	7.10				
25	2.8		50	2.1	7.05				
26	2.8		50	2.1	6.90				
27	2.7		50	2.2	6.90				
28	2.8		50	2.1	7.10				
29									
30									
31									

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:
 I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

a. Finished PH, Daily Average, Test Kit
 b.
 c.
 PWS Authorized Person - Signature & Date²⁴:
 William Coakley 3-1-2022
 Print Name: William Coakley Title: Chief Operator



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
For Conventional or Direct Filtered Systems

SWTR
J

III. DAILY REPORTING

Day	Filter Number 1		Filter Number 2		Filter Number 3		Filter Number 4	
	⁵ Max Day NTU	⁴ Max after 4 Hours NTU	⁵ Max Day NTU	⁴ Max after 4 Hours NTU	⁵ Max Day NTU	⁴ Max after 4 Hours NTU	⁵ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.072000	0.122000	0.103000	0.101000	0.092000	0.137000	0.116000	0.067000
2	0.064000	0.115000	0.065000	0.140000	0.028000	0.058000	0.040000	0.104000
3	0.063000	0.156000	0.069000	0.164000	0.036000	0.115000	0.071000	0.101000
4	0.063000	0.126000	0.072000	0.091000	0.105000	0.064000	0.186000	0.156000
5	0.067000	0.150000	0.076000	0.153000	0.180000	0.180000	0.152000	0.137000
6	0.071000	0.191000	0.093000	0.162000	0.044000	0.121000	0.093000	0.102000
7	0.074000	0.189000	0.095000	0.170000	0.077000	0.128000	0.235000	0.060000
8	0.188000	0.115000	0.079000	0.112000	0.124000	0.051000	0.172000	0.072000
9	0.086000	0.149000	0.285000	0.134000	0.236000	0.033000	0.250000	0.042000
10	0.082000	0.147000	0.095000	0.150000	0.041000	0.076000	0.151000	0.055000
11	0.080000	0.117000	0.098000	0.127000	0.061000	0.049000	0.063000	0.103000
12	0.081000	0.145000	0.095000	0.178000	0.031000		0.042000	
13	0.085000		0.103000		0.027000	0.082000	0.051000	0.136000
14	0.084000	0.252000	0.103000	0.247000	0.058000	0.072000	0.059000	0.076000
15	0.094000	0.131000	0.108000	0.149000	0.056000	0.037000	0.054000	0.098000
16	0.091000	0.176000	0.099000	0.179000	0.030000		0.048000	
17	0.098000		0.102000		0.024000	0.085000	0.043000	0.105000
18	0.092000	0.167000	0.095000	0.161000	0.057000	0.040000	0.054000	0.088000
19	0.093000	0.168000	0.092000	0.178000	0.026000	0.089000	0.058000	0.096000
20	0.095000	0.171000	0.093000	0.172000	0.023000		0.046000	
21	0.098000		0.099000		0.020000	0.098000	0.084000	0.251000
22	0.096000	0.169000	0.095000	0.273000	0.092000	0.097000	0.105000	0.085000
23	0.098000	0.136000	0.099000	0.183000	0.028000	0.062000	0.048000	0.121000
24	0.099000	0.177000	0.095000	0.169000	0.023000		0.045000	
25	0.104000		0.101000		0.024000	0.095000	0.049000	0.118000
26	0.101000	0.194000	0.097000	0.185000	0.028000	0.102000	0.071000	0.062000
27	0.106000	0.176000	0.107000	0.202000	0.044000	0.102000	0.093000	0.121000
28	0.105000	0.133000	0.103000	0.176000	0.084000		0.058000	
29								
30								
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature:

William Costello

Date: 3/8/2022

Title: Chief Plant Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program
 TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
 J

DAILY REPORTING

Day	Filter Number 5		Filter Number 6		Filter Number 7		Filter Number 8	
	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU	Max Day NTU	Max after 4 Hours NTU
1	0.086000	0.141000	0.113000	0.071000	0.032000	0.079000	0.089000	0.109000
2	0.073000	0.121000	0.134000	0.074000	0.035000	0.123000	0.170000	0.172000
3	0.053000	0.107000	0.138000	0.102000	0.029000	0.125000	0.075000	0.189000
4	0.078000	0.101000	0.192000	0.116000	0.029000	0.105000	0.080000	0.146000
5	0.066000	0.129000	0.168000	0.111000	0.031000	0.112000	0.191000	0.146000
6	0.054000	0.155000	0.255000	0.243000	0.032000	0.179000	0.084000	0.181000
7	0.047000	0.119000	0.112000	0.095000	0.039000	0.166000	0.097000	0.199000
8	0.231000	0.070000	0.253000	0.070000	0.031000	0.080000	0.148000	0.107000
9	0.328000	0.115000	0.059000	0.101000	0.030000	0.111000	0.393000	0.150000
10	0.050000	0.169000	0.041000	0.110000	0.038000		0.100000	
11	0.056000		0.045000		0.037000	0.097000	0.098000	0.126000
12	0.050000	0.150000	0.053000	0.132000	0.036000	0.099000	0.099000	0.128000
13	0.053000	0.116000	0.047000	0.105000	0.037000	0.120000	0.101000	0.269000
14	0.060000	0.076000	0.063000	0.066000	0.054000		0.121000	
15	0.063000		0.046000		0.045000	0.073000	0.113000	0.140000
16	0.059000	0.145000	0.051000	0.170000	0.046000	0.147000	0.112000	0.217000
17	0.141000	0.108000	0.046000	0.105000	0.042000	0.111000	0.113000	0.172000
18	0.057000	0.136000	0.038000	0.111000	0.046000		0.119000	
19	0.061000		0.039000		0.043000	0.117000	0.111000	0.200000
20	0.061000	0.128000	0.059000	0.106000	0.044000	0.118000	0.113000	0.154000
21	0.062000	0.140000	0.062000	0.107000	0.044000	0.121000	0.115000	0.197000
22	0.063000	0.111000	0.047000	0.075000	0.048000		0.123000	
23	0.065000		0.039000		0.046000	0.072000	0.118000	0.138000
24	0.063000	0.142000	0.045000	0.106000	0.045000	0.119000	0.117000	0.176000
25	0.062000	0.150000	0.055000	0.136000	0.047000	0.134000	0.118000	0.200000
26	0.065000	0.154000	0.049000	0.121000	0.051000		0.127000	
27	0.072000		0.047000		0.049000	0.145000	0.122000	0.286000
28	0.069000	0.243000	0.152000	0.097000	0.051000	0.078000	0.231000	0.149000
29								
30								
31								

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: *William Cookerly*
 Date: 3/8/2022 Title: Chief Plant Operator

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



DBPR TT Compliance Report

I. PWS INFORMATION:

PWS ID #: 4244001 City/Town: RANDOLPH
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM NTNC TNC

DEP LOCATION (LOC) ID#	DEP Location Name	Date Collected	Collected By
<u>015/10300</u>	<u>RAW WATER/COMBINED FILTER EFFLUENT</u>	<u>2-14-2022</u>	<u>B. L. Coker</u>
SAMPLE NOTES:			

II. COMPLIANCE CALCULATIONS:

Month	# of Paired Samples	A: % Removal of TOC ¹	B: Required % Removal of TOC ²	Met Alternative Compliance Criteria	Alternative Criteria Result(s) ³ (See Below)	A ÷ B ⁴
3-21	1	38	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.09
4-21	1	35	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.00
5-21	1	42	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.20
6-21	1	38	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.09
7-21	1	42	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.20
8-21	1	46	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.31
9-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
10-21	1	45	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.29
11-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
12-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
1-22	1	39	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.17
2-22	1	36	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.03
Sum of Past 12 Months:						14.07
Compliance Value (Sum of Past 12 Months/ 12):						1.17

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Coker
 Date: 3-9-2022

Mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

¹ Percent Removal: $(1 - (\text{Treated Water TOC} \div \text{Raw Water TOC})) \times 100$. If > 1 paired sample sets in any month report the average of all individual percent TOC removals (Example: % TOC Removal = $(\text{Average of Set 1} + \text{Average of Set 2}) \div 2$).

² From table at 310 CMR 22.07E(10)(b)2.

³ As listed at 310 CMR 22.07E(10)(a)2 and 310 CMR 22.07E(10)(a)3, summarized as follows:

Alternative Compliance Criteria	Code Value	Result(s) to Report (RAA - Running Annual Average)
Source Water TOC < 2.0 mg/L	SWTOC	RAA of source water TOC
Treated Water < 2.0 mg/L	TWTOC	RAA of treated water TOC
Source Water TOC < 4.0 mg/L AND Alkalinity > 60 mg/L (as CaCO ₃) AND TTHM/HAA5 ≤ 0.040/0.030 mg/L	COMBO	RAA of source water TOC, RAA of source water alkalinity, RAA of TTHM and HAA5
TTHM/HAA5 ≤ 0.040/0.030 mg/L AND only using chlorine	TTHM/HAA5	RAA of TTHM and HAA5
Source Water SUVA ≤ 2.0 L/mg-m	SWSUVA	RAA of treated water SUVA
Treated Water SUVA ≤ 2.0 L/mg-m	TWSUVA	RAA of treated water SUVA
Softening that lowers alkalinity to < 60 mg/L (as CaCO ₃)	SOFT60	RAA of treated water alkalinity
Softening that removes ≥ 10 mg/L (as CaCO ₃) of hardness	SOFT10	RAA of hardness (as CaCO ₃) removal

Note: All supplemental measurements and calculations used to meet the alternative criteria must be attached to this report.

⁴ For any month where the system met an alternative compliance criteria a value of 1.0 may be inserted.

DEP REVIEW STATUS (Initial & Date)	Review Comments
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved _____	



Total Organic Carbon (TOC) Report doc rev 12/2020

PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: 4244001 City / Town: RANDOLPH
PWS Name: RANDOLPH HOLBROOK WATER BOARD PWS Class: COM [x] NTNC [] TNC []

Table with columns: DEP LOCATION (LOC) ID#, DEP Location Name, Sample Information, Date Collected, Collected By. Includes rows for Great Pond WTP - Raw Water and Combined Filter Effluent.

II. ANALYTICAL LABORATORY INFORMATION

Primary Lab MA Cert. #: M-MA022 Primary Lab Name: Analytical Balance
Analysis Lab MA Cert. #: M-MA022 Analysis Lab Name: Analytical Balance Subcontracted?(Y/N) N

Table for TOC Analyzed by (check one): PWS or Lab. Columns include TOC Result (mg/L), MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

Surface or GWUDI systems >= 500 persons. Monthly source (raw) water TOC sampling is required at each surface/GWUDI source to qualify for and remain on reduced THM/HAA5 monitoring.

Surface or GWUDI sources using conventional filtration shall each month (unless monitoring is reduced): take one TOC sample at each treatment plant no later than the point of combined filter effluent turbidity monitoring representative of the treated (finished) water.

Table for Alkalinity Analyzed by (check one): PWS or Lab. Columns include Alkalinity Result (mg/L as CaCO3), MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

Using conventional filtration - Raw water alkalinity must be measured at the same time as the raw water TOC sample is collected.

Table for LAB SAMPLE COMMENTS. Columns: LAB SAMPLE COMMENTS, Result Qualifier, Result Qualifier Description.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator or Primary Lab Director Signature: Laurel Stoddard Date: 2/25/2022

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner.

DEP REVIEW STATUS (Initial & Date)
[] Accepted [] Disapproved
Review Comments
[] WQTS Data Entered



CERTIFICATE OF ANALYSIS

Chris Pelleteri
 Randolph - Holbrook Joint Water Board
 50 North Franklin Street
 Holbrook, MA 02343

Project Name: DOC SUVA
 Work Order Number: A2B0345
 Date Received: 02/14/2022

Sampled By: Bill Cookerly
 Location: Raw Water

Date Sampled: 2/14/22 9:00
 Matrix: Surface Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Detection Limit	DW MCL/ Recommended Limit #	Result
<i>Test Parameters</i>				LAB-ID#: A2B0345-01		
Dissolved Organic Carbon (Average)	5310B	2/15/2022	mg/L	0.500	—	2.39
SUVA	4153	2/15/2022	/100 ml	N/A	—	0.0389
UV 254	5910B	2/15/2022	abs/cm	0.002	—	0.093

Sampled By: Bill Cookerly
 Location: Combined Filter Effluent

Date Sampled: 2/14/22 9:00
 Matrix: Drinking Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Detection Limit	DW MCL/ Recommended Limit #	Result
<i>Test Parameters</i>				LAB-ID#: A2B0345-02		
Dissolved Organic Carbon (Average)	5310B	2/15/2022	mg/L	0.500	—	1.49
SUVA	4153	2/15/2022	/100 ml	N/A	—	0.0362
UV 254	5910B	2/15/2022	abs/cm	0.002	—	0.054

NA = Not Applicable
 ND = Not Detected
 <= Less Than
 >= Greater Than

Approved By: *Samuel*

Work Order Narrative:

No unusual observations noted.

REVIEWED
 By SLawler at 11:35 am, Feb 25, 2022

Subcontracted Analyses:

ESS Laboratory - Cranston, RI (M-RI002)

Dissolved Organic Carbon 5310B; UVA.254



Massachusetts Department of Environmental Protection - Drinking Water Program
CHLORINE/CHLORAMINES - MONTHLY REPORT

I. PWS INFORMATION:

PWS ID #: **4133000** PWS Name: **TOWN OF HOLBROOK** City/Town: **HOLBROOK** Class: COM NTNC TNC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine
 Analytical Method: SM 4500-Cl D E F G H I ASTM D1253-86

Notes:

DEP APPROVED SAMPLE SITE INFORMATION ¹		CHLORINE RESULT ² (mg/L)	COLLECTION AND ANALYSIS ³		COLLECTED AND ANALYZED BY:
DEP Sample Type ⁴	DEP Location Code # ¹		DATE	TIME	
RS	001	1.48	2/17/2022	07:20	J. MacLaine
RS	004	1.61	2/17/2022	08:00	J. MacLaine
RS	008E	0.02	2/17/2022	08:40	J. MacLaine
RS	006	.69	2/17/2022	08:40	J. MacLaine
RS	001	1.56	2/14/2022	07:30	J. MacLaine
RS	004	1.69	2/14/2022	08:10	J. MacLaine
RS	008E	.04	2/14/2022	08:30	J. MacLaine
RS	006	.85	2/14/2022	07:50	J. MacLaine
RS	001	1.12	2/23/2022	07:20	J. MacLaine
RS	004	1.41	2/23/2022	07:40	J. MacLaine
RS	008E	.03	2/23/2022	08:10	J. MacLaine
RS	006	.89	2/23/2022	09:00	J. MacLaine
RS	001	1.61	2/28/2022	07:12	T. Duggan
RS	004	1.66	2/28/2022	08:17	T. Duggan
RS	008E	.03	2/28/2022	08:55	T. Duggan
RS	006	1.17	2/28/2022	08:55	T. Duggan

¹DEP Sample Type, Location Code#, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan.
²SWTR systems: HPC must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form.
³Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record ND values as 0 (zero).
⁴Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP).
⁵All DISTRIBUTION samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month⁶: **65** Average Chlorine Result of All Samples For Month⁶ (mg/L): **1.48**

I hereby under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature and Date: *William Foster 3-9-2022*

DEP Review Status: Accepted Disapproved Review Comments:



Massachusetts Department of Environmental Protection - Drinking Water Program
Disinfection Byproducts Rule Compliance Report

DBPR

I. PWS INFORMATION Please refer to your DBPR Monitoring Plan to help complete this form.

PWS ID #: 4244001 City / Town: RANDOLPH
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM NTNC TNC
 Monitoring Period (YEAR): 2022 Monitoring Period (QUARTER): Q1 (Jan-Mar) Q2 (Apr-Jun) Q3 (Jul-Sep) Q4 (Oct-Dec)

II. FOR SYSTEMS USING CHLORINATION

A. Trihalomethanes (THM)
 Total Number of THM Samples: _____ Quarterly Average: _____ µg/L
 Was the Running Annual Average MCL (80 µg/L) exceeded? Yes No Running Annual Average: _____ µg/L

B. Haloacetic Acids (HAA5)
 Total Number of HAA5 Samples: _____ Quarterly Average: _____ µg/L
 Was the Running Annual Average MCL (60 µg/L) exceeded? Yes No Running Annual Average: _____ µg/L

C. Chlorine/Chloramines

Total Number of Samples:	Month 1:	<u>69</u> JAN	Monthly Averages: (report all 3 months per quarter)	<u>1.42</u> mg/L	Quarterly Average:	<u>1.45</u> mg/L
	Month 2:	<u>65</u> FEB		<u>1.48</u> mg/L		
	Month 3:			_____ mg/L		

 Was the Running Annual Average MRDL (4.0 mg/L) exceeded? Yes No Running Annual Average: 1.19 mg/L

D. Total Organic Carbon - raw (TOC) (Required for SW or GWUDI Plant Name: _____)
systems >499 seeking or approved to reduce THM/HAA5 monitoring
 (Attach additional sheet(s) to report more than 1 plant)

Total Number of Samples:	Month 1:	_____	Monthly Averages: (report all 3 months per quarter)	_____ mg/L	Quarterly Average:	_____ mg/L
	Month 2:	_____		_____ mg/L		
	Month 3:	_____		_____ mg/L		

 Was the (4.0 mg/L) threshold exceeded? Yes No Running Annual Average: _____ mg/L

III. FOR SYSTEMS USING OZONATION

E. Bromate (treated) Plant Name: _____

Total Number of Samples:	Month 1:	_____	Monthly Averages: (report all 3 months per quarter)	_____ mg/L	Quarterly Average:	_____ mg/L
	Month 2:	_____		_____ mg/L		
	Month 3:	_____		_____ mg/L		

 Was the Running Annual Average MCL (0.010 ug/l) exceeded? Yes No Running Annual Average: _____ mg/L

F. Bromide (raw) Plant Name: _____
Required for systems seeking or approved to reduce Bromate monitoring

Total Number of Samples:	Month 1:	_____	Monthly Averages: (report all 3 months per quarter)	_____ mg/L	Quarterly Average:	_____ mg/L
	Month 2:	_____		_____ mg/L		
	Month 3:	_____		_____ mg/L		

 Was the (0.05 mg/l) threshold exceeded? Yes No Running Annual Average: _____ mg/L

IV. FOR SYSTEMS USING CHLORINE DIOXIDE

I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge.

Primary Certified Operator Signature: William Conerty Date: 3-9-2022

DEFINITIONS

MONTHLY AVERAGE:	Monthly average = average of all results within the current month.
QUARTERLY AVERAGE:	Quarterly Average = average result of all locations sampled during monitoring period
RUNNING ANNUAL AVERAGE:	Running Annual Average = Average of 4 quarters. Average of this quarter and three prior consecutive quarterly averages (for systems on quarterly monitoring)
TOTAL NUMBER OF SAMPLES:	Total number of samples collected during the monitoring period.

NOTE: Record and calculate all ND or <MDL results as the number zero (0).

Submit one copy of this form each quarter to your DEP regional office (by Jan 10th, April 10th, July 10th, and Oct 10th of each year)

DEP REVIEW STATUS (Initial & Date)

<input type="checkbox"/> Accepted	<input type="checkbox"/> Disapproved	Review Comments: _____
-----------------------------------	--------------------------------------	------------------------