



Town of Holbrook
Office of Joint Superintendent
(781) 767-1800

RANDOLPH-HOLBROOK JOINT WATER BOARD

50 North Franklin Street
Holbrook, MA 02343



Town of Randolph

January 10, 2021

Commonwealth of Massachusetts
Department of Environmental Protection
Southeast Regional Office
20 Riverside Drive
Lakeville, MA 02374

Monthly Reports Filtered System Forms
Forms F, G, I, J, TT
Analysis for TOC, DOC, SUVA
Chemical Addition Reports
DBPR Compliance Report
December, 2021 Randolph/Holbrook
Joint Water System, PWS #424001

Gentlemen:

Enclosed please find all reports as referenced above for the month of December, 2021 along with the SUVA's for October and November. Should there be any questions, please do not hesitate to call me.

Sincerely,

William Cookerly
Chief Plant Operator

Enclosures

Cc: Board of Health Holbrook
Board of Health Randolph
Brian Howard, Town Manager, Randolph
Ryan Allgrove, EPG



Compliance Determination for Filtered Systems - Monthly Report

PWS INFORMATION:

PWSID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH
Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period -> Month: DECEMBER Year: 2021

TURBIDITY PERFORMANCE CRITERIA:

1. Monthly Turbidity (95%) NTU Limit - The turbidity level of a system's filtered water must be less than or equal to the Monthly Turbidity NTU Limit in at least 95% of the measurements taken each month for the filtration technology used, otherwise SWTR TT Violation (Tier 2).
186 = A Total # of filtered water turbidity measurements for month (SWTR - Form F)
186 = B Total # of filtered water turbidity measurements less than or equal to the specified limits for the filtration technology used.
100 = (B / A) x 100 The percentage of turbidity measurements meeting the Monthly Turbidity 95% NTU Limit.
2. Max Day NTU Limit - The turbidity level of a system's filtered water must at no time exceed the Max Day NTU Limit for the filtration technology used, otherwise SWTR TT Violation (Tier 2).

DISINFECTION PERFORMANCE CRITERIA:

1. Point-of-Entry Minimum Disinfectant Residual Criteria - Residual Disinfectant concentration cannot be < 0.2 mg/L for more than 4 hours.
Table with columns: Day, Cl2 mg/l, Day, Cl2 mg/l.
Residual Measured: Free Cl2, Total Cl2, Combined Cl2.
If at any time the residual falls below 0.2 mg/l in the water entering the distribution system, the supplier of water must notify the Department as soon as possible, but no later than by the end of the next business day.

2. Distribution System Disinfectant Residual Criteria - Residual Disinfectant concentration (V) cannot be undetectable in greater than 5% of samples in a month, for any two consecutive months.
Total # of HPC samples taken during month: 62 # HPC sites > 500/mL: 0 # HPC sites <= 500/mL: 62
66 = a # of sites where Cl2 residual measurements were made, whether a residual was detected or not
0 = b # of sites HPC samples were analyzed instead of Cl2 residual measurements
0 = c # of sites where no Cl2 residual was detected and no HPC sample was analyzed
0 = d # of sites where no Cl2 residual was detected and HPC > 500 CFU/mL
0 = e # of sites where no Cl2 residual measurement was made and HPC > 500 CFU/mL
Water in the distribution system with a heterotrophic bacteria concentration (HPC) less than or equal to 500/mL, is deemed to have a detectable disinfectant residual for purposes of determining compliance with this requirement.
V = (c+d+e) / (a+b) x 100 This Month % V = 0 Previous Month % V = 0 Is V > 5% for 2 months? Yes or No

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true.

PWS Authorized Signature: William Anderson, Chief Operator 1-11-2025



Massachusetts Department of Environmental Protection - Drinking Water Program SWTR
TURBIDITY DATA SHEET FOR FILTERED SYSTEMS F

PWS INFORMATION

PWSID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH
Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period → Month: DECEMBER Year: 2021

DAILY REPORTING

Filtered Water Turbidity Measured: (check only one) Combined Filter Effluent Individual Filter Effluent Clearwell Plant Effluent
Filtration Technology: Conventional Direct Alternative Slow Sand Diatomaceous Earth
Monthly Turbidity (95%) NTU Limit = 0.3 Max Day Turbidity NTU Limit = 1
Monthly Turbidity (95%) NTU Limit = 1 Max Day Turbidity NTU Limit = 5

Day	Max Filtered Water Turbidity Result (NTU)	Number of Turbidity Measurements	Number of Turbidity Measurements Monthly (95%) NTU Limit	Number of Turbidity Measurements Max Day NTU Limit
	.08	6	6	0
	.08	6	6	0
	.10	6	6	0
	.10	6	6	0
	.11	6	6	0
	.09	6	6	0
	.09	6	6	0
	.08	6	6	0
	.07	6	6	0
	.04	6	6	0
	.04	6	6	0
	.08	6	6	0
	.08	6	6	0
	.03	6	6	0
	.03	6	6	0
	.04	6	6	0
	.07	6	6	0
	.08	6	6	0
	.04	6	6	0
	.05	6	6	0
	.05	6	6	0
	.04	6	6	0
	.04	6	6	0
	.03	6	6	0
	.03	6	6	0
	.03	6	6	0
	.03	6	6	0
	.04	6	6	0
	.03	6	6	0
	.03	6	6	0
	.03	6	6	0
Totals:		186	186	0

May be used by systems serving less than 10,000 persons, subject to DEP approval.
Enter the Maximum Filtered Water Turbidity Result recorded each day, at the 4th hour or other approved interval.
Enter the Total # of Turbidity measurements taken for each day. Measurements must be taken at a minimum of 4-hour intervals (i.e. 6 readings per day).
For continuous monitors count each 4-hour period as 1 measurement. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. If DEP approved, 15-minute readings (i.e. 96 readings per day) may be submitted. Filtered turbidity data must be kept on file for DEP review.
Out of the # of turbidity measurements taken and recorded in the previous column, enter the number of turbidity measurements that were less than or equal to the Monthly (95%) NTU Limit for the filtration technology used.
If at any time the filtered turbidity Max Day NTU Limit is exceeded, the DEP must be notified no later than the end of the next business day. For each exceedance, record the turbidity value(s) and date(s) on SWTR - Form G

PWS Authorized Signature: William Cook
Date: 1-3-2022 Title: Chief Plant Operator



Massachusetts Department of Environmental Protection - Drinking Water Program **SWTR**
CT Determination for Filtered Systems **I**

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph Hillbrook Junior Water PWS Town: Randolph
 Treatment Plant Name: Randolph Water Plant Reporting Period → Month: DECEMBER Year: 2021
 Disinfectant: Chlorine Gas/Ester Eff. Sequence of Application: 1st 2nd 3rd 4th 5 6th

II. DAILY REPORTING: All measurements taken during peak hourly flow.

Day	Peak Hourly Flow ² (gpm)	Disinfectant Concentration ³ C (mg/L)	Disinfectant Contact Time ⁴ T (min.)	CT calc (= C x T)	pH ⁵	Water Temp ⁶ (°C)	CT ⁷ 99.9	Inactivation Ratio ⁸ (CT calc / CT 99.9)	Inactivation Ratio ⁹ < 1.0
1	2,400	1.64	50	82	6.25	5.8	17	4.8	<input type="checkbox"/> Yes
2	2,400	1.81	50	90.5	6.10	6.0	17	5.3	<input type="checkbox"/> Yes
3	2,400	1.88	50	94	6.10	6.0	17	5.5	<input type="checkbox"/> Yes
4	2,400	1.84	50	92	6.25	6.0	17	5.4	<input type="checkbox"/> Yes
5	2,400	1.70	50	85	6.10	5.7	17	5.0	<input type="checkbox"/> Yes
6	2,400	1.70	50	85	6.15	5.5	17	5.0	<input type="checkbox"/> Yes
7	2,400	1.92	50	96	6.15	5.8	17	5.7	<input type="checkbox"/> Yes
8	2,400	1.73	50	86.5	6.05	5.3	17	5.1	<input type="checkbox"/> Yes
9	2,400	2.14	50	107	6.20	5.2	17	6.3	<input type="checkbox"/> Yes
10	2,400	1.63	50	81.5	6.20	5.2	17	4.8	<input type="checkbox"/> Yes
11	2,400	1.81	50	90.5	6.10	5.0	17	5.3	<input type="checkbox"/> Yes
12	2,400	1.94	50	97	6.15	4.8	17	5.7	<input type="checkbox"/> Yes
13	2,400	1.74	50	87	6.15	4.9	17	5.1	<input type="checkbox"/> Yes
14	2,400	1.57	50	78.5	6.10	5.1	17	4.6	<input type="checkbox"/> Yes
15	2,400	1.82	50	91	6.10	5.1	17	5.4	<input type="checkbox"/> Yes
16	2,400	1.92	50	96	6.00	5.2	17	5.7	<input type="checkbox"/> Yes
17	2,400	1.87	50	93.5	6.05	4.8	17	5.5	<input type="checkbox"/> Yes
18	2,400	1.97	50	98.5	5.90	4.8	17	5.8	<input type="checkbox"/> Yes
19	2,400	1.90	50	95	6.10	5.0	17	5.6	<input type="checkbox"/> Yes
20	2,400	1.96	50	98	6.15	5.4	17	5.8	<input type="checkbox"/> Yes
21	2,400	1.76	50	88	6.00	5.4	17	5.2	<input type="checkbox"/> Yes
22	2,400	1.77	50	88.5	6.05	5.9	17	5.2	<input type="checkbox"/> Yes
23	2,400	1.91	50	95.5	5.95	5.9	17	5.6	<input type="checkbox"/> Yes
24	2,400	1.83	50	91.5	6.15	5.3	17	5.4	<input type="checkbox"/> Yes
25	2,400	1.77	50	88.5	6.15	5.3	17	5.2	<input type="checkbox"/> Yes
26	2,400	1.68	50	84	6.20	5.7	17	4.9	<input type="checkbox"/> Yes
27	2,400	1.43	50	71.5	6.20	5.7	17	4.2	<input type="checkbox"/> Yes
28	2,400	1.51	50	75.5	6.10	5.8	17	4.4	<input type="checkbox"/> Yes
29	2,400	1.81	50	90.5	6.15	5.0	17	5.3	<input type="checkbox"/> Yes
30	2,400	1.99	50	99.5	6.20	5.0	17	5.9	<input type="checkbox"/> Yes
31	2,400	1.96	50	98	6.15	5.2	17	5.8	<input type="checkbox"/> Yes

1. Use a separate form for each disinfectant/sampling point. Enter disinfectant and sequence position, e.g. "ozone/1st" or "ClO₂/3rd". If more than one disinfectant sampling point, you must also complete SWTR Form H and calculate the cumulative inactivation ratio SUM (CTcalc/CT99.9) to determine compliance.
2. Peak hourly flow means the highest pumpage hour during the day, not the absolute peak flow at any instant.
3. The residual disinfectant concentration(s) ("C") of the water before or at the first customer must be measured each day during peak hourly flow.
4. The disinfectant contact time(s) ("T") must be determined for each day during peak hourly flow. The time T used in calculating CT, is the time it takes the water, during peak hourly flow, to move between the point of disinfection application and the point at which the residual is measured.
5. If the system uses free chlorine, the pH of the disinfected water must be measured at least once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
6. The temperature of the disinfected water must be measured at least once per day at each residual disinfectant concentration sampling point during peak hourly flow.
7. Use Inactivation Tables at 310 CMR 22.20A Tables 1.1 – 1.6, 2.1 and/or 3.1
8. The inactivation ratio (CTcalc/CT99.9) is determined before or at the first customer during peak hourly flow and if the (CTcalc/CT99.9) is < 1.0, the 99.9% *Giardia lamblia* inactivation requirement has not been achieved.
9. More than one "Yes" response above may indicate a SWTR Treatment Technique violation (Tier 2).

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: _____

Date: 1-3-2022 Title: Chief Operator



I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JW	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-DIT	Reporting Period ³ :	DECEMBER 2021 Month Year

II. Chemical & Operational Information

Chemical Name ⁴ :	POLYALUMINUM CHLORIDE	Purchased Strength ⁵ :	1.0	Target Range/min ¹² :	>14
Manufacturer ⁶ :	HOLLAND COMPANY	Purchased Density (lbs/gal) ⁵ :	10.3	Target Dose ¹³ :	6.18
Product Name ⁶ :	PCH-180	Dilution Factor or Mix Ratio ¹⁰ :	NA	Alarm Setting (low) ¹⁴ :	NA
Reason for Adding Chemical ⁷ :	COAGULATION	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	NA
		Date of last anti-siphon valve inspection/replacement ¹⁵ :			

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁸	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured ²⁰ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹			O&M Notes/Comments ²²
	Gallons	Mg	Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. RAW Ph Daily Avg <input type="checkbox"/> G <input type="checkbox"/> A	b. <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A	
1	2.8		120		1,236	18	6.90			
2	2.8		133		1,370	19	6.90			
3	2.9		137		1,411	19	7.05			
4	2.8		130		1,339	19	7.00			
5	2.7		145		1,494	22	7.10			
6	2.8		135		1,391	20	7.00			
7	2.9		125		1,288	18	6.95			
8	2.8		133		1,370	19	6.90			
9	2.8		163		1,679	24	6.85			
10	2.8		145		1,494	21	6.95			
11	2.8		160		1,648	23	6.90			
12	2.8		130		1,339	19	6.85			
13	2.8		145		1,494	21	6.80			
14	2.8		155		1,597	23	6.95			
15	2.7		139		1,432	21	7.05			
16	2.9		167		1,720	23	7.00			
17	2.8		124		1,277	18	7.00			
18	2.7		140		1,442	21	7.05			
19	2.9		110		1,133	16	7.00			
20	2.8		105		1,082	15	6.90			
21	2.8		120		1,236	18	6.90			
22	2.7		134		1,380	20	6.80			
23	2.8		106		1,092	15	6.85			
24	2.8		110		1,133	16	6.80			
25	2.8		120		1,236	18	7.00			
26	2.7		120		1,236	18	7.00			
27	2.8		110		1,133	16	6.95			
28	2.8		125		1,288	18	6.90			
29	2.7		120		1,236	18	6.95			
30	2.8		118		1,215	17	6.85			
31	2.8		130		1,339	19	6.90			

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰.

a. *Raw Ph Daily Average Test Kit*

b. *William Cookery 1-3-2022*

c. *William Cookery* Print Name: Title²⁴

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person - Signature & Date²⁴:



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information – Refer to MassDEP “Chemical Addition Report Guidance and Instructions” for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JOINT WATER	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	424400-01T	Reporting Period ² :	DECEMBER 2021
				Month	Year

II. Chemical & Operational Information

Chemical Name ⁴ :	CHLORINE	Purchased Strength ⁵ :	1.0	Target Range/min ¹² :	0.20
Manufacturer ⁵ :	AXIALI, LLC	Purchased Density (lbs/gal) ⁶ :	12.3	Target Dose ¹³ :	NA
Product Name ⁵ :	CHLORINE	Dilution Factor or Mix Ratio ¹⁰ :	NA	Alarm Setting (low) ¹⁴ :	1.0
Reason for Adding Chemical ⁷ :	DISINFECTANT	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	3.0
		Date of last anti-siphon valve inspection/replacement ¹⁵ :		NA	

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶		Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁷	Chemical Dosage ¹⁸ (mg/l)	Parameters Measured ¹⁹ ; Results, Units and Method ²⁰ - (G)rab or Continuous - (A)nalyzer ²¹			O&M Notes/Comments ²²
	<input type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG	Volume ¹⁶ (gal/day)	Weight ¹⁷ (lbs/day)	a. FREE Cl ₂ b. FREE Cl ₂ c.						
				DAILY AVG			DAILY MIN/MAX	<input type="checkbox"/> G <input type="checkbox"/> A	<input type="checkbox"/> G <input type="checkbox"/> A	
1	2.8		81		3.5	2.03	1.64			
2	2.8		87		3.7	2.08	1.81			
3	2.9		88		3.6	2.22	1.88			
4	2.8		88		3.8	2.23	1.84			
5	2.7		90		4.0	2.27	1.70			
6	2.8		93		4.0	2.30	1.70			
7	2.9		90		3.7	2.28	1.92			
8	2.8		81		3.5	2.43	1.73			
9	2.8		82		3.5	2.52	2.14			
10	2.8		83		3.6	2.07	1.63			
11	2.8		80		3.4	2.44	1.81			
12	2.8		80		3.4	2.20	1.94			
13	2.8		81		3.5	2.18	1.74			
14	2.8		80		3.4	2.33	1.57			
15	2.7		97		4.3	2.45	1.82			
16	2.9		88		3.6	2.28	1.92			
17	2.8		86		3.7	2.25	1.87			
18	2.7		92		4.1	2.30	1.97			
19	2.9		97		4.0	2.34	1.90			
20	2.8		99		4.2	2.46	1.96			
21	2.8		95		4.1	2.24	1.76			
22	2.7		78		3.5	2.22	1.77			
23	2.8		82		3.5	2.19	1.91			
24	2.8		85		3.6	2.30	1.83			
25	2.8		92		3.9	2.10	1.77			
26	2.7		87		3.9	2.05	1.68			
27	2.8		88		3.8	2.06	1.43			
28	2.8		90		3.9	2.38	1.51			
29	2.7		92		4.1	2.40	1.81			
30	2.8		91		3.9	2.47	1.99			
31	2.8		91		3.9	2.43	1.96			
Total						Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ :				

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

a. Daily Average Free Chlorine, Finished Water, Grab Sample, Test Kit

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person - Signature & Date²⁴:

Print Name: William Cookery Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information - Refer to MassDEP's Chemical Addition Report Guidance and Instructions* for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JW	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-01T	Reporting Period ³ :	DECEMBER 2021 Month Year

II. Chemical & Operational Information

Chemical Name ⁴ :	CALCIUM HYDROXIDE	Purchased Strength ⁵ :	0.85	Target Range/min ¹² :	NA
Manufacturer ⁶ :	CARMEUSE LIME & STONE	Purchased Density (lbs/gal) ⁹ :	18.7	Target Dose ¹³ :	NA
Product Name ⁷ :	HYDRATED LIME	Dilution Factor or Mix Ratio ¹⁰ :	NA	Alarm Setting (low) ¹⁴ :	NA
Reason for Adding Chemical ⁸ :	PH ADJUSTMENT	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	NA
		Date of last anti-siphon valve inspection/replacement ¹⁵ :			
		NA			

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ¹⁶ <input type="checkbox"/> Gallons <input type="checkbox"/> MG	Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁸	Chemical Dosage ¹⁹ (mg/l)	Parameters Measured ²⁰ , Results, Units and Method ²⁰ - (G) Grab or Continuous (A) Analyzer ²¹			O&M Notes/Comments ²² PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
		Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. FINISHED PH <input checked="" type="checkbox"/> G <input type="checkbox"/> A	b. <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A	
1	2.5		100		4.8	7.10			
2	2.5		100		4.8	7.00			
3	2.5		100		4.8	7.00			
4	2.5		100		4.8	7.10			
5	2.5		100		4.8	6.95			
6	2.6		100		4.6	6.95			
7	2.7		100		4.4	6.90			
8	2.6		100		4.6	6.90			
9	2.6		100		4.6	6.95			
10	2.5		100		4.8	6.95			
11	2.6		100		4.6	7.00			
12	2.6		100		4.6	6.90			
13	2.7		100		4.4	7.00			
14	2.8		100		4.3	7.00			
15	2.7		100		4.4	7.05			
16	2.8		100		4.3	6.90			
17	2.7		100		4.4	7.05			
18	2.6		100		4.6	6.90			
19	2.8		100		4.3	6.95			
20	2.7		100		4.4	7.00			
21	2.7		100		4.4	6.95			
22	2.6		100		4.6	7.05			
23	2.7		100		4.4	7.05			
24	2.7		100		4.4	7.00			
25	2.8		100		4.3	7.00			
26	2.7		100		4.4	7.05			
27	2.7		100		4.4	6.95			
28	2.8		100		4.3	6.95			
29	2.7		100		4.4	6.95			
30	2.8		100		4.3	7.10			
31	2.6		100		4.6	7.00			

Total Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³:

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

a. Finished Water Ph, Daily Average, Test Kit

b.

c.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person - Signature & Date²⁴:
 William Coakley 1-3-2022
 Print Name: William Coakley Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information – Refer to MassDEP “Chemical Addition Report Guidance and Instructions” for details.

PWS Name ¹ :	RANDOLPH-HOLBROOK JW	Town ¹ :	RANDOLPH-HOLBROOK	PWSID ¹ :	424001
Treatment Plant Name ² :	RANDOLPH WATER PLANT	Treatment Plant ID# ² :	4244001-01T	Reporting Period ³ :	DECEMBER 2021 Month Year

II. Chemical & Operational Information

Chemical Name ⁴ :	SODIUM BISULFATE	Purchased Strength ⁵ :	10 - 15	Target Range/min ¹² :	NA
Manufacturer ⁵ :	CARUS CORPORATION	Purchased Density (lbs/gal) ⁶ :	12.03	Target Dose ¹³ :	NA
Product Name ⁶ :	CARUS 3350	Dilution Factor or Mix Ratio ¹⁰ :	0.33	Alarm Setting (low) ¹⁴ :	NA
Reason for Adding Chemical ⁷ :	CORROSION INHIBITOR	NSF Approved (Y/N) ¹¹ :	Y	Alarm Setting (high) ¹⁴ :	NA
		Date of last anti-siphon valve inspection/replacement ¹⁵ :		NA	

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

Day	Treated Water ⁸ <input type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG	Measured Chemical Used		Calculated Chemical Used (lbs) ¹⁶	Chemical Dosage ¹⁹ (mg/L)	Parameters Measured ⁹ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²³			O&M Notes/Comments ²² PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.
		Volume ¹⁷ (gal/day)	Weight ¹⁷ (lbs/day)			a. FINISHED PH <input checked="" type="checkbox"/> G <input type="checkbox"/> A	b. <input type="checkbox"/> G <input type="checkbox"/> A	c. <input type="checkbox"/> G <input type="checkbox"/> A	
1	2.5		50	2.4	7.10				
2	2.5		50	2.4	7.00				
3	2.5		50	2.4	7.00				
4	2.5		50	2.4	7.10				
5	2.5		50	2.4	6.95				
6	2.6		50	2.3	6.95				
7	2.7		50	2.2	6.90				
8	2.6		50	2.3	6.90				
9	2.6		50	2.3	6.95				
10	2.5		50	2.4	6.95				
11	2.6		50	2.3	7.00				
12	2.6		50	2.3	6.90				
13	2.7		50	2.2	7.00				
14	2.8		50	2.1	7.00				
15	2.7		50	2.2	7.05				
16	2.8		50	2.1	6.90				
17	2.7		50	2.2	7.05				
18	2.6		50	2.3	6.90				
19	2.8		50	2.1	6.95				
20	2.7		50	2.2	7.00				
21	2.7		50	2.2	6.95				
22	2.6		50	2.3	7.05				
23	2.7		50	2.2	7.05				
24	2.7		50	2.2	7.00				
25	2.8		50	2.1	7.00				
26	2.7		50	2.2	7.05				
27	2.7		50	2.2	6.95				
28	2.8		50	2.1	6.95				
29	2.7		50	2.2	6.95				
30	2.8		50	2.1	7.10				
31	2.6		50	2.3	7.00				
Total			50						Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ :

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

a. Finished PH Daily Coverage, Test Kit

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person - Signature & Date²⁴:
William Cookery 1-3-2022

Print Name: *William Cookery* Title: *Chief Operator*



DBPR TT Compliance Report

I. PWS INFORMATION

PWS ID #: 4244001 City/Town: RANDOLPH
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM NTNC TNC

DEP LOCATION (LOC) ID#	DEP Location Name	Date Collected	Collected By
<u>015/10300</u>	<u>RAW WATER/COMBINED FILTER EFFLUENT</u>	<u>12-6-2021</u>	<u>Bill Cookerly</u>

SAMPLE NOTES:

II. COMPLIANCE CALCULATIONS

Month	# of Paired Samples	A: % Removal of TOC ¹	B: Required % Removal of TOC ²	Met Alternative Compliance Criteria	Alternative Criteria Result(s) ³ (See Below)	A + B ⁴
1-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
2-21	1	38	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.09
3-21	1	38	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.09
4-21	1	35	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.00
5-21	1	42	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.20
6-21	1	38	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.09
7-21	1	42	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.20
8-21	1	46	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.31
9-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
10-21	1	45	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.29
11-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
12-21	1	43	35	<input type="checkbox"/> YES <input type="checkbox"/> NO		1.23
				<input type="checkbox"/> YES <input type="checkbox"/> NO		
Sum of Past 12 Months:						14.19
Compliance Value (Sum of Past 12 Months/ 12):						1.18

I hereby certify under penalties of law that I am the person authorized to sign this form and the information contained therein is accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Cookerly
 Date: 1-6-2022

Mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

¹ Percent Removal: $(1 - (\text{Treated Water TOC} \div \text{Raw Water TOC})) \times 100$. If > 1 paired sample sets in any month report the average of all individual percent TOC removals (Example: % TOC Removal = (Average of Set 1 + Average of Set 2) ÷ 2).
² From table at 310-CMR 22.07E(10)(b)2.
³ As listed at 310 CMR 22.07E(10)(a)2 and 310 CMR 22.07E(10)(a)3, summarized as follows:

Alternative Compliance Criteria	Code Value	Result(s) to Report (RAA - Running Annual Average)
Source Water TOC < 2.0 mg/L	SWTOC	RAA of source water TOC
Treated Water < 2.0 mg/L	TWTOC	RAA of treated water TOC
Source Water TOC < 4.0 mg/L AND Alkalinity > 60 mg/L (as CaCO ₃) AND TTHM/HAA5 ≤ 0.040/0.030 mg/L	COMBO	RAA of source water TOC, RAA of source water alkalinity, RAA of TTHM and HAA5
TTHM/HAA5 ≤ 0.040/0.030 mg/L AND only using chlorine	TTHM/HAA5	RAA of TTHM and HAA5
Source Water SUVA ≤ 2.0 L/mg-m	SWSUVA	RAA of treated water SUVA
Treated Water SUVA ≤ 2.0 L/mg-m	TWSUVA	RAA of treated water SUVA
Softening that lowers alkalinity to < 60 mg/L (as CaCO ₃)	SOFT60	RAA of treated water alkalinity
Softening that removes ≥ 10 mg/L (as CaCO ₃) of hardness	SOFT10	RAA of hardness (as CaCO ₃) removal

Note: All supplemental measurements and calculations used to meet the alternative criteria must be attached to this report.

⁴ For any month where the system met an alternative compliance criteria a value of 1.0 may be inserted.

DEP REVIEW STATUS (Initial & Date)	Review Comments
<input type="checkbox"/> Accepted _____ <input type="checkbox"/> Disapproved _____	



Total Organic Carbon (TOC) Report doc rev 12/2020

PWS INFORMATION: Please refer to your DEP Water Quality Sampling Schedule (WQSS) to help complete this form.

PWS ID #: 4244001 City / Town: RANDOLPH

PWS Name: RANDOLPH HOLBROOK WATER BOARD PWS Class: COM [x] NTNC [] TNC []

Table with columns: DEP LOCATION (LOC) ID#, DEP Location Name, Sample Information, Date Collected (Date, Time), Collected By. Includes rows for A (01S) and B (10300).

ANALYTICAL LABORATORY INFORMATION

Primary Lab MA Cert. #: M-MA022 Primary Lab Name: Analytical Balance Subcontracted?(Y/N) Y
Analysis Lab MA Cert. #: M-RI002 Analysis Lab Name: ESS Lab

Table with columns: TOC Analyzed by (check one), Samples Acidified?, TOC Result (mg/L), Result Qualifier, MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

Surface or GWUDI systems >= 500 persons. Monthly source (raw) water TOC sampling is required at each surface/GWUDI source to qualify for and remain on reduced THM/HAA5 monitoring.
Surface or GWUDI sources using conventional filtration shall each month (unless monitoring is reduced): take one TOC sample at each treatment plant no later than the point of combined filter effluent turbidity monitoring representative of the treated (finished) water, one TOC source (raw) sample prior to any treatment, and one alkalinity source (raw) water sample - at a time representative of normal

Table with columns: Alkalinity Analyzed by (check one), Alkalinity Result (mg/L as CaCO3), Result Qualifier, MDL (mg/L), MRL (mg/L), Dilution Factor, Lab Method, Date Analyzed, Primary Lab Sample ID#, Analytical Lab or PWS Sample ID#.

If using conventional filtration - Raw water alkalinity must be measured at the same time as the raw water TOC sample is collected. Alkalinity analysis does not require the use of a Massachusetts or EPA certified laboratory

Table with columns: LAB SAMPLE COMMENTS, Result Qualifier, Result Qualifier Description. Includes rows for A and B.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge. Primary Certified Operator or Primary Lab Director Signature: Laurel Stoddard Date: 12/22/2021

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same

Table with columns: DEP REVIEW STATUS (Initial & Date), Review Comments, WQTS Data Entered. Includes checkboxes for Accepted and Disapproved.



CERTIFICATE OF ANALYSIS

Chris Pelletieri
Randolph - Holbrook Joint Water Board
50 North Franklin Street
Holbrook, MA 02343

Project Name: DOC SUVA
Work Order Number: AIL0179
Date Received: 12/06/2021

Sampled By: Bill Cookerly
Location: Raw Water

Date Sampled: 12/6/21 9:00
Matrix: Surface Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL/Rec Limit#	Result
<i>Test Parameters</i>				LAB-ID#: <u>AIL0179-01</u>		
Dissolved Organic Carbon (Average)	5310B	12/8/2021	mg/L	0.500	—	5.22
SUVA	4153	12/8/2021	/100 ml	N/A	—	0.0208
UV 254	5910B	12/7/2021	abs/cm	0.002	—	0.108

Sampled By: Bill Cookerly
Location: Combined Filter Effluent

Date Sampled: 12/6/21 9:00
Matrix: Drinking Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL/Rec Limit#	Result
<i>Test Parameters</i>				LAB-ID#: <u>AIL0179-02</u>		
Dissolved Organic Carbon (Average)	5310B	12/8/2021	mg/L	0.500	—	5.38
SUVA	4153	12/8/2021	/100 ml	N/A	—	0.0170
UV 254	5910B	12/7/2021	abs/cm	0.002	—	0.058

NA = Not Applicable
ND = Not Detected
< = Less Than
> = Greater Than
* = Detection Limit
Rec Limit# = Recommended Limit

Approved By: *Lanely H. Hall*

Work Order Narrative:

No unusual observations noted.

REVIEWED
By SLawler at 11:39 am, Dec 17, 2021



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
J

(Page 1 of 2)

I. PWS INFORMATION

PWS ID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: Randolph
 Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period: Month: Dec Year: 2022
 Total # of Filters at Treatment Plant¹: 8

II. MONTHLY REPORTING

Filtered Water Turbidity Measured: Individual Filter Effluent (IFE) or Combined Filter Effluent (CFE)²
 Analytical Method: SM 2130B EPA 180.1 GLI Method 2 (Great Lakes)

1.	Was each filter monitored continuously? If continuous monitoring equipment is installed and if it functioned continuously throughout the month, the correct answer is "yes". If continuous monitoring equipment is not installed or did not function continuously throughout the month, the correct answer is "no".	Yes
2.	Were measurements recorded every 15 minutes? If measurements on each filter were performed throughout the month and the measurements were recorded every 15 minutes when water was being filtered, the correct answer is "yes". If there was a failure in any continuous monitor, the correct answer is "no".	Yes
3.	Was there a failure of continuous turbidity monitoring equipment? If grab samples were obtained due to an equipment failure, the correct answer is "yes". If there was no equipment failure during the month, the correct answer is "no". Systems serving a population of at least 10,000 must conduct grab samples every 4 hours in lieu of continuous monitoring, but for no more than 5 working days following the failure of equipment. Systems serving a population less than 10,000 may use grab samples for up to 14 working days. List filter # and date(s) grab samples collected: _____ Comment: _____	No
4.	Were individual filter levels greater than 1.0 NTU in two consecutive measurements? If "yes", systems serving a population of at least 10,000 must produce a filter profile within 7 days of the exceedance or report the obvious reason for the exceedance in the table below. The filter profile is not required to be submitted unless requested, only report that the filter profile has been done. Systems serving a population less than 10,000 shall report exceedance information in the table below. List date(s) a filter profile was produced: _____	No
5.	Were individual filter levels greater than 0.5 NTU in two consecutive measurements after the filter has been online for more than 4 hours? If "yes", systems serving a population of at least 10,000 must produce a filter profile within 7 days of the exceedance or report the obvious reason for the exceedance in the table below. The filter profile is not required to be submitted unless requested, only report that the filter profile has been done. <i>Systems that serve a population less than 10,000 have no required action.</i> List date(s) a filter profile was produced: _____	Yes
6.	Were individual filter levels greater than 1.0 NTU in two consecutive measurements in three consecutive months? If "yes", the system must conduct a self-assessment of the filter within 14 days of the exceedance. The system is to report that a self-assessment has been completed. Systems with 2 filters that monitor CFE in lieu of IFE must do both filters. Refer to 310 CMR 22.20D(6)(b)(2) and 310 CMR 22.20F(7)(d)(2) for required filter self-assessment report content. List date(s) a filter self-assessment was triggered: _____ Report(s) completed: _____	No
7.	Were individual filter levels greater than 2.0 NTU in two consecutive measurements in two consecutive months? If "yes", systems serving a population of at least 10,000 must schedule a Comprehensive Performance Evaluation (CPE) within 30 days of the exceedance and submit the report within 90 days. A system serving a population less than 10,000 must schedule a CPE within 60 days of the exceedance and submit the report within 120 days. List date(s) the CPE was triggered: _____	No

For each "Yes" response to question #4, #5, or #7 above: Report the following information in the table below.

Filter #	Turbidity Result (NTU)	Date	Reason for Exceedance (if known) Attach additional documents as necessary for detailed explanations.
# 3	1.1, .90, .70, .62	12-5-2021	Beginning to get some Floc carryover from sedimentation basin. Backwashing as much as possible. Plant shut down for basin cleaning 12-7-2021. AS A SIDE NOTE - WOULD GIVE ANYTHING TO HAVE ALL FILTERS REDONE ENTIRELY TOP TO BOTTOM. WE'RE STUCK WITH THE SED. BASIN WE HAVE. MANY THANKS - Bill Gorkley
# 4	.84, .72, .66	12-5-2021	
FILTER Profiles INCLUDED.			



Massachusetts Department of Environmental Protection - Drinking Water Program
 TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
J

(Page 2 of 2)

III. DAILY REPORTING

Day	Filter Number 1		Filter Number 2		Filter Number 3		Filter Number 4	
	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.061000	0.287000	0.053000	0.157000	0.075000	0.202000	0.061000	0.256000
2	0.054000	0.142000	0.022000	0.065000	0.129000	0.070000	0.035000	0.052000
3	0.056000	0.114000	0.030000	0.075000	0.151000	0.175000	0.085000	0.081000
4	0.059000	0.107000	0.031000	0.047000	0.135000	0.196000	0.115000	0.210000
5	0.056000	0.115000	0.123000	0.092000	0.544000	0.201000	0.721000	0.191000
6	0.157000	0.181000	0.176000	0.164000	0.316000	0.304000	0.390000	0.315000
7	0.177000	0.156000	0.168000	0.122000	0.222000		0.280000	0.249000
8	0.057000	0.083000	0.378000		0.086000	0.177000	0.227000	0.062000
9	0.083000		0.054000	0.057000	0.031000	0.056000	0.032000	0.071000
10	0.056000	0.109000	0.026000	0.214000	0.024000	0.068000	0.028000	0.053000
11	0.064000	0.106000	0.031000	0.095000	0.026000		0.030000	
12	0.067000		0.037000		0.025000	0.139000	0.030000	0.153000
13	0.066000	0.143000	0.034000	0.166000	0.028000	0.087000	0.039000	0.080000
14	0.061000	0.134000	0.031000	0.093000	0.034000	0.065000	0.042000	0.069000
15	0.069000	0.110000	0.040000	0.094000	0.035000		0.036000	
16	0.077000		0.046000		0.032000	0.117000	0.030000	0.102000
17	0.068000	0.132000	0.037000	0.122000	0.023000	0.038000	0.031000	0.085000
18	0.056000	0.124000	0.043000	0.089000	0.028000	0.091000	0.034000	
19	0.059000		0.048000		0.035000		0.033000	0.087000
20	0.057000	0.123000	0.043000	0.119000	0.031000	0.083000	0.040000	0.103000
21	0.050000	0.098000	0.042000	0.066000	0.027000	0.034000	0.055000	
22	0.053000		0.045000		0.031000		0.060000	0.089000
23	0.050000	0.105000	0.042000	0.113000	0.030000	0.055000	0.051000	0.065000
24	0.049000	0.132000	0.043000	0.105000	0.053000	0.071000	0.037000	
25	0.055000		0.048000		0.037000		0.042000	0.067000
26	0.050000	0.109000	0.050000	0.156000	0.101000	0.066000	0.112000	0.104000
27	0.049000	0.119000	0.051000	0.096000	0.162000	0.081000	0.194000	
28	0.098000		0.051000		0.060000		0.186000	0.068000
29	0.053000	0.150000	0.053000	0.204000	0.135000	0.070000	0.054000	0.048000
30	0.051000	0.098000	0.050000	0.227000	0.126000	0.126000	0.164000	
31	0.063000		0.054000		0.029000		0.133000	0.051000

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature:

Melissa Gault
Chief Operator

Date: 1/5/2022

Title:

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Massachusetts Department of Environmental Protection - Drinking Water Program
 TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
J

(Page 2 of 2)

III. DAILY REPORTING

Day	Filter Number 5		Filter Number 6		Filter Number 7		Filter Number 8	
	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU	³ Max Day NTU	⁴ Max after 4 Hours NTU
1	0.046000	0.122000	0.049000	0.083000	0.034000	0.143000	0.057000	0.212000
2	0.103000	0.169000	0.130000	0.103000	0.027000	0.142000	0.024000	0.100000
3	0.056000	0.094000	0.118000	0.076000	0.024000	0.100000	0.023000	0.113000
4	0.099000	0.133000	0.066000	0.089000	0.055000	0.087000	0.057000	0.094000
5	0.077000	0.145000	0.188000	0.070000	0.050000	0.088000	0.100000	0.088000
6	0.079000	0.125000	0.112000	0.101000	0.035000	0.093000	0.155000	0.112000
7	0.081000	0.105000	0.135000	0.133000	0.061000	0.062000	0.148000	0.080000
8	0.218000	0.073000	0.215000	0.061000	0.028000	0.071000	0.215000	0.051000
9	0.032000	0.065000	0.026000		0.032000		0.031000	
10	0.039000		0.023000	0.077000	0.028000	0.069000	0.026000	0.072000
11	0.034000	0.169000	0.024000	0.189000	0.029000	0.096000	0.030000	0.104000
12	0.034000	0.121000	0.027000	0.087000	0.031000	0.079000	0.035000	0.113000
13	0.036000	0.206000	0.024000	0.103000	0.036000		0.042000	
14	0.036000		0.028000		0.028000	0.111000	0.032000	0.082000
15	0.034000	0.131000	0.023000	0.145000	0.029000	0.119000	0.039000	0.122000
16	0.038000	0.150000	0.029000	0.098000	0.027000	0.101000	0.039000	0.085000
17	0.037000	0.085000	0.026000		0.031000		0.044000	
18	0.041000		0.025000	0.085000	0.030000	0.084000	0.043000	0.104000
19	0.038000	0.115000	0.027000	0.113000	0.031000	0.120000	0.050000	0.076000
20	0.040000	0.115000	0.037000		0.041000		0.060000	
21	0.038000		0.026000	0.091000	0.031000	0.106000	0.047000	0.209000
22	0.240000	0.086000	0.023000	0.050000	0.027000	0.056000	0.046000	0.084000
23	0.033000	0.088000	0.025000		0.031000		0.051000	
24	0.034000		0.027000	0.079000	0.027000	0.091000	0.046000	0.127000
25	0.032000	0.120000	0.043000	0.086000	0.030000	0.098000	0.049000	0.105000
26	0.035000	0.124000	0.050000		0.031000		0.053000	
27	0.036000		0.053000	0.127000	0.028000	0.207000	0.047000	0.120000
28	0.038000	0.083000	0.049000	0.078000	0.028000	0.105000	0.047000	0.075000
29	0.037000	0.187000	0.044000	0.079000	0.031000		0.054000	
30	0.038000		0.033000		0.029000	0.082000	0.049000	0.105000
31	0.038000	0.106000	0.058000	0.087000	0.028000	0.287000	0.053000	0.142000

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature:

William Coakley
 Chief Operator

Date: 1/5/2022

Title:

In accordance with 310 CMR 22.15(2), if mailing paper reports, TWO copies of this report must be received by your MassDEP Regional Office no later than 10 days after the end of the month in which the results are received or no later than 10 days after the end of the monitoring period, whichever is sooner. Please note: Electronic reporting (eDEP) deadline is the same as above.



Filter #3		Filter #4	
12/5/2021	0.032	12/5/2021	0.147
12/5/2021 0:15	0.032	12/5/2021 0:15	0.154
12/5/2021 0:30	0.031	12/5/2021 0:30	0.159
12/5/2021 0:45	0.031	12/5/2021 0:45	0.166
12/5/2021 1:00	0.03	12/5/2021 1:00	0.161
12/5/2021 1:15	0.03	12/5/2021 1:15	0.141
12/5/2021 1:30	0.03	12/5/2021 1:30	0.095
12/5/2021 1:45	0.03	12/5/2021 1:45	0.182
12/5/2021 2:00	0.029	12/5/2021 2:00	0.103
12/5/2021 2:15	0.029	12/5/2021 2:15	0.075
12/5/2021 2:30	0.029	12/5/2021 2:30	0.072
12/5/2021 2:45	0.029	12/5/2021 2:45	0.06
12/5/2021 3:00	0.029	12/5/2021 3:00	0.049
12/5/2021 3:15	0.029	12/5/2021 3:15	0.042
12/5/2021 3:30	0.029	12/5/2021 3:30	0.038
12/5/2021 3:45	0.029	12/5/2021 3:45	0.036
12/5/2021 4:00	0.029	12/5/2021 4:00	0.035
12/5/2021 4:15	0.029	12/5/2021 4:15	0.035
12/5/2021 4:30	0.029	12/5/2021 4:30	0.035
12/5/2021 4:45	0.029	12/5/2021 4:45	0.035
12/5/2021 5:00	0.028	12/5/2021 5:00	0.035
12/5/2021 5:15	0.028	12/5/2021 5:15	0.035
12/5/2021 5:30	0.03	12/5/2021 5:30	0.035
12/5/2021 5:45	0.03	12/5/2021 5:45	0.035
12/5/2021 6:00	0.03	12/5/2021 6:00	0.034
12/5/2021 6:15	0.03	12/5/2021 6:15	0.034
12/5/2021 6:30	0.03	12/5/2021 6:30	0.034
12/5/2021 6:45	0.03	12/5/2021 6:45	0.034
12/5/2021 7:00	0.031	12/5/2021 7:00	0.034
12/5/2021 7:15	0.03	12/5/2021 7:15	0.033
12/5/2021 7:30	0.031	12/5/2021 7:30	0.038
12/5/2021 7:45	0.032	12/5/2021 7:45	0.035
12/5/2021 8:00	0.032	12/5/2021 8:00	0.034
12/5/2021 8:15	0.032	12/5/2021 8:15	0.034
12/5/2021 8:30	0.033	12/5/2021 8:30	0.034
12/5/2021 8:45	0.032	12/5/2021 8:45	0.033
12/5/2021 9:00	0.032	12/5/2021 9:00	0.033
12/5/2021 9:15	0.033	12/5/2021 9:15	0.033
12/5/2021 9:30	0.032	12/5/2021 9:30	0.032
12/5/2021 9:45	0.032	12/5/2021 9:45	0.032
12/5/2021 10:00	0.032	12/5/2021 10:00	0.033
12/5/2021 10:15	0.033	12/5/2021 10:15	0.032
12/5/2021 10:30	0.033	12/5/2021 10:30	0.032
12/5/2021 10:45	0.036	12/5/2021 10:45	0.032
12/5/2021 11:00	0.04	12/5/2021 11:00	0.033
12/5/2021 11:15	0.043	12/5/2021 11:15	0.034
12/5/2021 11:30	0.05	12/5/2021 11:30	0.034
12/5/2021 11:45	0.05	12/5/2021 11:45	0.035
12/5/2021 12:00	0.061	12/5/2021 12:00	0.036
12/5/2021 12:15	0.064	12/5/2021 12:15	0.037
12/5/2021 12:30	0.068	12/5/2021 12:30	0.036

FILTER #3

FILTER #4

12/5/2021 12:45	0.074	12/5/2021 12:45	0.04
12/5/2021 13:00	0.081	12/5/2021 13:00	0.041
12/5/2021 13:15	0.095	12/5/2021 13:15	0.042
12/5/2021 13:30	0.095	12/5/2021 13:30	0.042
12/5/2021 13:45	0.094	12/5/2021 13:45	0.042
12/5/2021 14:00	0.099	12/5/2021 14:00	0.044
12/5/2021 14:15	0.103	12/5/2021 14:15	0.046
12/5/2021 14:30	0.122	12/5/2021 14:30	0.049
12/5/2021 14:45	0.144	12/5/2021 14:45	0.053
12/5/2021 15:00	0.147	12/5/2021 15:00	0.061
12/5/2021 15:15	0.17	12/5/2021 15:15	0.07
12/5/2021 15:30	0.187	12/5/2021 15:30	0.076
12/5/2021 15:45	0.201	12/5/2021 15:45	0.085
12/5/2021 16:00	0.219	12/5/2021 16:00	0.102
12/5/2021 16:15	0.236	12/5/2021 16:15	0.115
12/5/2021 16:30	0.223	12/5/2021 16:30	0.122
12/5/2021 16:45	0.244	12/5/2021 16:45	0.142
12/5/2021 17:00	0.261	12/5/2021 17:00	0.15
12/5/2021 17:15	0.297	12/5/2021 17:15	0.168
12/5/2021 17:30	0.307	12/5/2021 17:30	0.19
12/5/2021 17:45	0.332	12/5/2021 17:45	0.214
12/5/2021 18:00	0.384	12/5/2021 18:00	0.25
12/5/2021 18:15	0.429	12/5/2021 18:15	0.284
12/5/2021 18:30	0.509	12/5/2021 18:30	0.29
12/5/2021 18:45	0.473	12/5/2021 18:45	0.306
12/5/2021 19:00	0.467	12/5/2021 19:00	0.277
12/5/2021 19:15	0.544	12/5/2021 19:15	0.282
12/5/2021 19:30	0.46	12/5/2021 19:30	0.286
12/5/2021 19:45	0.484	12/5/2021 19:45	0.314
12/5/2021 20:00	0.463	12/5/2021 20:00	0.318
12/5/2021 20:15	0.465	12/5/2021 20:15	0.327
12/5/2021 20:30	0.442	12/5/2021 20:30	0.313
12/5/2021 20:45	0.585	12/5/2021 20:45	0.347
12/5/2021 21:00	1.09	12/5/2021 21:00	0.622
12/5/2021 21:15	0.879	12/5/2021 21:15	0.596
12/5/2021 21:30	0.713	12/5/2021 21:30	0.484
12/5/2021 21:45	0.622	12/5/2021 21:45	0.415
12/5/2021 22:00	0.558	12/5/2021 22:00	0.375
12/5/2021 22:15	0.201	12/5/2021 22:15	0.392
12/5/2021 22:30	0.289	12/5/2021 22:30	0.344
12/5/2021 22:45	0.258	12/5/2021 22:45	0.841
12/5/2021 23:00	0.12	12/5/2021 23:00	0.715
12/5/2021 23:15	0.07	12/5/2021 23:15	0.66
12/5/2021 23:30	0.045	12/5/2021 23:30	0.721
12/5/2021 23:45	0.038	12/5/2021 23:45	0.455

10:00 PM backwash

1:00 AM backwash



Massachusetts Department of Environmental Protection - Drinking Water Program
CHLORINE/CHLORAMINES - MONTHLY REPORT

I. PWS INFORMATION:

PWS ID #: **4133000** PWS Name: **TOWN OF HOLBROOK** City/Town: **HOLBROOK** Class: COM NTNC TNC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl: D E F G H I ASTM D1253-86

Notes:

DEP Sample Type ^{1,4}	DEP Location Code # ¹	DEP Approved SAMPLE LOCATION ¹	CHLORINE (RESUL T ²) (mg/L)	COLLECTION AND ANALYSIS ³ DATE	TIME	COLLECTED AND ANALYZED BY:
RS	001	TOWN HALL	1.62	12/6/2021	07:08	T. Duggan
RS	004	COTTAGE VARIETY	1.68	12/6/2021	07:57	T. Duggan
RS	008E	STEWARTS POWER EQUIPMENT	.04	12/6/2021	07:35	T. Duggan
RS	006	COMMUNITY CENTER	.30	12/6/2021	09:08	T. Duggan
RS	001	TOWN HALL	1.59	12/13/2021	07:08	T. Duggan
RS	004	COTTAGE VARIETY	1.63	12/13/2021	08:02	T. Duggan
RS	008E	STEWARTS POWER EQUIPMENT	.03	12/13/2021	08:40	T. Duggan
RS	006	COMMUNITY CENTER	.93	12/13/2021	07:35	T. Duggan
RS	001	TOWN HALL	1.50	12/20/2021	07:08	T. Duggan
RS	004	COTTAGE VARIETY	1.69	12/20/2021	08:05	T. Duggan
RS	008E	STEWARTS POWER EQUIPMENT	.03	12/20/2021	08:42	T. Duggan
RS	006	COMMUNITY CENTER	.40	12/20/2021	07:40	T. Duggan
RS	001	TOWN HALL	1.28	12/27/2021	07:20	J. Maclane
RS	004	COTTAGE VARIETY	1.41	12/27/2021	07:40	J. Maclane
RS	008E	STEWARTS POWER EQUIPMENT	.02	12/27/2021	07:55	J. Maclane
RS	006	COMMUNITY CENTER	.73	12/27/2021	08:30	J. Maclane

¹ DEP Sample Type, Location Code# and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan.
² SWTR systems: HPC must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form.
³ Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record ND values as 0 (zero).
⁴ Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP).
⁵ All DISTRIBUTION samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month⁵: **66** Average Chlorine Result of All Samples For Month⁵ (mg/L): **1.36**

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.
 Primary Certified Operator Signature and Date: *[Signature]* 1-6-2022

DEP Review Status: Accepted Disapproved Review Comments:

CHLORINE CHLORAMINES - MONTHLY REPORT

5. PUMP INFORMATION:

Pumps ID #: 4244000 PUMP Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: CM TNG

4. ANALYTICAL INFORMATION: Refer to your Massdep Coliform Sampling Plan and/or DEP's monitoring plan to help complete this section.

Type: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl D E F G H ASTM D1219-06

Notes:

DEP Sample Type	DEP Approved Sample Site Information	DEP Approved Sample Location	CHLORINE RESULT (mg/L)	COLLECTION AND ANALYSIS DATE	TIME	COLLECTED AND ANALYZED BY
RS	003	TOWNER HILL SCHOOL... ADAMS STREET	1.53	12-6-21	10:40	RS
RS	004	JFK SCHOOL... DU HURLEY DRIVE	1.89		8:30	
RS	008	MARTIN E. YOUNG SCHOOL... COURTNEY DRIVE	1.92		7:45	
RS	009	CAMPBELL INN... 1924 NORTH MAIN STREET	1.93		11:10	
RS	008	NORTH MIDDLE SCHOOL... HIGH STREET	1.75		10:50	
RS	011	MOBIL STATION... 83 MARZEO DRIVE	1.66		10:15	
RS	012	7... 11 FOOD SHOP... 678 NORTH STREET	.70		8:00	
RS	014	6... 11... 1125... 1125 NORTH MAIN STREET	NO ACCESS		COVID - 19	
RS	016	OAK GROVE STANDBY	1.30		11:45 AM	
RS	017	SOUTH MAIN STREET STANDBY	1.11		10:50 AM	

1. DEP Sample Type Location Code, and DEP Approved Sample Site Location must correspond to the sample information on your Total Coliform Sampling Plan. A DEP Sample Type Code must be collected at the location and with the appropriate equipment. If you collect representative samples with the chlorination system during the month you must also provide for a detectable chlorine residual at the repeat site and include these samples. DO NOT include any other samples in your submission.

2. DEP Sample Type Location Code, and DEP Approved Sample Site Location must correspond to the sample information on your Total Coliform Sampling Plan. A DEP Sample Type Code must be collected at the location and with the appropriate equipment. If you collect representative samples with the chlorination system during the month you must also provide for a detectable chlorine residual at the repeat site and include these samples. DO NOT include any other samples in your submission.

3. DEP Sample Type Location Code, and DEP Approved Sample Site Location must correspond to the sample information on your Total Coliform Sampling Plan. A DEP Sample Type Code must be collected at the location and with the appropriate equipment. If you collect representative samples with the chlorination system during the month you must also provide for a detectable chlorine residual at the repeat site and include these samples. DO NOT include any other samples in your submission.

4. DEP Sample Type Location Code, and DEP Approved Sample Site Location must correspond to the sample information on your Total Coliform Sampling Plan. A DEP Sample Type Code must be collected at the location and with the appropriate equipment. If you collect representative samples with the chlorination system during the month you must also provide for a detectable chlorine residual at the repeat site and include these samples. DO NOT include any other samples in your submission.

I verify under penalty of law that I am the person authorized to fill out this report and the information provided herein is true, accurate and complete to the best extent of my knowledge.

Physician Certified Operator Signature: [Signature] Date: 12/6/21

Reviewer Signature: [Signature] Reviewer Title: 1-6-2022

CHILDREN'S CHEMICAL EXAMINER - MONTHLY REPORT

5. PUMP INFORMATION:

PUMP ID #: 4244000 PUMP Name: RANDOLPH WATER DEPARTMENT CITY/Town: RANDOLPH Class: NTNG TNG

II. ANALYTICAL INFORMATION: Refer to your MassDPS Collection Sampling Plan and/or DEP's monitoring plan to help complete this section.

Type MassDPS: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl-1D ClE ClF ClM ClN ClP ClS ClT ClV ClW ClX ClY ClZ ClAA ClAB ClAC ClAD ClAE ClAF ClAG ClAH ClAI ClAJ ClAK ClAL ClAM ClAN ClAO ClAP ClAQ ClAR ClAS ClAT ClAU ClAV ClAW ClAX ClAY ClAZ ClBA ClBB ClBC ClBD ClBE ClBF ClBG ClBH ClBI ClBJ ClBK ClBL ClBM ClBN ClBO ClBP ClBQ ClBR ClBS ClBT ClBU ClBV ClBW ClBX ClBY ClBZ ClCA ClCB ClCC ClCD ClCE ClCF ClCG ClCH ClCI ClCJ ClCK ClCL ClCM ClCN ClCO ClCP ClCQ ClCR ClCS ClCT ClCU ClCV ClCW ClCX ClCY ClCZ ClDA ClDB ClDC ClDD ClDE ClDF ClDG ClDH ClDI ClDJ ClDK ClDL ClDM ClDN ClDO ClDP ClDQ ClDR ClDS ClDT ClDU ClDV ClDW ClDX ClDY ClDZ ClEA ClEB ClEC ClED ClEE ClEF ClEG ClEH ClEI ClEJ ClEK ClEL ClEM ClEN ClEO ClEP ClEQ ClER ClES ClET ClEU ClEV ClEW ClEX ClEY ClEZ ClFA ClFB ClFC ClFD ClFE ClFF ClFG ClFH ClFI ClFJ ClFK ClFL ClFM ClFN ClFO ClFP ClFQ ClFR ClFS ClFT ClFU ClFV ClFW ClFX ClFY ClFZ ClGA ClGB ClGC ClGD ClGE ClGF ClGG ClGH ClGI ClGJ ClGK ClGL ClGM ClGN ClGO ClGP ClGQ ClGR ClGS ClGT ClGU ClGV ClGW ClGX ClGY ClGZ ClHA ClHB ClHC ClHD ClHE ClHF ClHG ClHH ClHI ClHJ ClHK ClHL ClHM ClHN ClHO ClHP ClHQ ClHR ClHS ClHT ClHU ClHV ClHW ClHX ClHY ClHZ ClIA ClIB ClIC ClID ClIE ClIF ClIG ClIH ClII ClIJ ClIK ClIL ClIM ClIN ClIO ClIP ClIQ ClIR ClIS ClIT ClIU ClIV ClIW ClIX ClIY ClIZ ClJA ClJB ClJC ClJD ClJE ClJF ClJG ClJH ClJI ClJJ ClJK ClJL ClJM ClJN ClJO ClJP ClJQ ClJR ClJS ClJT ClJU ClJV ClJW ClJX ClJY ClJZ ClKA ClKB ClKC ClKD ClKE ClKF ClKG ClKH ClKI ClKJ ClKL ClKM ClKN ClKO ClKP ClKQ ClKR ClKS ClKT ClKU ClKV ClKW ClKX ClKY ClKZ ClLA ClLB ClLC ClLD ClLE ClLF ClLG ClLH ClLI ClLJ ClLK ClLL ClLM ClLN ClLO ClLP ClLQ ClLR ClLS ClLT ClLU ClLV ClLW ClLX ClLY ClLZ ClMA ClMB ClMC ClMD ClME ClMF ClMG ClMH ClMI ClMJ ClMK ClML ClMN ClMO ClMP ClMQ ClMR ClMS ClMT ClMU ClMV ClMW ClMX ClMY ClMZ ClNA ClNB ClNC ClND ClNE ClNF ClNG ClNH ClNI ClNJ ClNK ClNL ClNM ClNN ClNO ClNP ClNQ ClNR ClNS ClNT ClNU ClNV ClNW ClNX ClNY ClNZ ClOA ClOB ClOC ClOD ClOE ClOF ClOG ClOH ClOI ClOJ ClOK ClOL ClOM ClON ClOO ClOP ClOQ ClOR ClOS ClOT ClOU ClOV ClOW ClOX ClOY ClOZ ClPA ClPB ClPC ClPD ClPE ClPF ClPG ClPH ClPI ClPJ ClPK ClPL ClPM ClPN ClPO ClPP ClPQ ClPR ClPS ClPT ClPU ClPV ClPW ClPX ClPY ClPZ ClQA ClQB ClQC ClQD ClQE ClQF ClQG ClQH ClQI ClQJ ClQK ClQL ClQM ClQN ClQO ClQP ClQQ ClQR ClQS ClQT ClQU ClQV ClQW ClQX ClQY ClQZ ClRA ClRB ClRC ClRD ClRE ClRF ClRG ClRH ClRI ClRJ ClRK ClRL ClRM ClRN ClRO ClRP ClRQ ClRR ClRS ClRT ClRU ClRV ClRW ClRX ClRY ClRZ ClSA ClSB ClSC ClSD ClSE ClSF ClSG ClSH ClSI ClSJ ClSK ClSL ClSM ClSN ClSO ClSP ClSQ ClSR ClSS ClST ClSU ClSV ClSW ClSX ClSY ClSZ ClTA ClTB ClTC ClTD ClTE ClTF ClTG ClTH ClTI ClTJ ClTK ClTL ClTM ClTN ClTO ClTP ClTQ ClTR ClTS ClTT ClTU ClTV ClTW ClTX ClTY ClTZ ClUA ClUB ClUC ClUD ClUE ClUF ClUG ClUH ClUI ClUJ ClUK ClUL ClUM ClUN ClUO ClUP ClUQ ClUR ClUS ClUT ClUU ClUV ClUW ClUX ClUY ClUZ ClVA ClVB ClVC ClVD ClVE ClVF ClVG ClVH ClVI ClVJ ClVK ClVL ClVM ClVN ClVO ClVP ClVQ ClVR ClVS ClVT ClVU ClVV ClVW ClVX ClVY ClVZ ClWA ClWB ClWC ClWD ClWE ClWF ClWG ClWH ClWI ClWJ ClWK ClWL ClWM ClWN ClWO ClWP ClWQ ClWR ClWS ClWT ClWU ClWV ClWW ClWX ClWY ClWZ ClXA ClXB ClXC ClXD ClXE ClXF ClXG ClXH ClXI ClXJ ClXK ClXL ClXM ClXN ClXO ClXP ClXQ ClXR ClXS ClXT ClXU ClXV ClXW ClXX ClXY ClXZ ClYA ClYB ClYC ClYD ClYE ClYF ClYG ClYH ClYI ClYJ ClYK ClYL ClYM ClYN ClYO ClYP ClYQ ClYR ClYS ClYT ClYU ClYV ClYW ClYX ClYY ClYZ ClZA ClZB ClZC ClZD ClZE ClZF ClZG ClZH ClZI ClZJ ClZK ClZL ClZM ClZN ClZO ClZP ClZQ ClZR ClZS ClZT ClZU ClZV ClZW ClZX ClZY ClZZ

Notes:

DEP Sample Type	DEP Location Code	DEP Approved Sample Location	CHILDLINE RESULT (uM/L)	COLLECTION AND ANALYSIS		COLLECTED AND ANALYZED BY
				DATE	TIME	
RS	000	TOWHER HILL SCHOOL, ADVANCE STREET	1.51	12/13/21	10:30 AM	A. PIERRE-LOUIS
RS	004	JFK SCHOOL, 20 HURLEY DRIVE	1.68		7:30 AM	
RS	008	MARTIN L. YOUNG SCHOOL, COURTNEY DRIVE	1.40		9:00 AM	
RS	009	CAMPBELL INN, 1374 NORTH MAIN STREET	1.88		11:30 AM	
RS	008	NORTH MIDDLE SCHOOL, HIGH STREET	1.56		11:00 AM	
RS	011	MOBILE STATION, 83 MAZZEO DRIVE	1.55		9:30 AM	
RS	012	7001 FOOD SHOP, 676 NORTH STREET	.99		8:30 AM	
RS	014	2100 WALKER, 220 NORTH MAIN STREET	NO ACCESS	DVE	TO	CAVIO-19
RS	016	DAK GROVE STANFORD	1.43		8:00 AM 10:15 AM	
RS	017	SOUTH MAIN STREET STANFORD	1.29		9:15 AM	

1. DEP Sample Type, Location Code, and DEP Approved Sample Site Location must be reported to the same information on your DEP Total Chlorine Sampling Plan. 2. SWTR systems may be collected at different sites with each of the locations and results reported on the DEP Total Chlorine Sampling Plan. 3. Collection and Analysis Sites must be reported in the DEP Total Chlorine Sampling Plan. 4. Sample Type, Location Code, and DEP Approved Sample Site Location must be reported on the DEP Total Chlorine Sampling Plan. 5. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 6. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 7. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 8. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 9. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 10. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 11. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 12. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 13. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 14. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 15. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 16. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 17. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 18. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 19. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 20. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 21. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 22. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 23. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 24. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 25. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 26. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 27. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 28. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 29. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 30. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 31. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 32. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 33. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 34. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 35. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 36. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 37. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 38. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 39. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 40. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 41. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 42. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 43. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 44. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 45. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 46. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 47. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 48. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 49. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 50. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 51. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 52. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 53. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 54. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 55. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 56. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 57. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 58. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 59. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 60. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 61. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 62. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 63. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 64. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 65. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 66. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 67. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 68. All sample results must be reported to the DEP Total Chlorine Sampling Plan. 69. All sample results must be reported to

CHILDREN'S CHLORINE EXAMINATIONS - MONTHLY REPORT

3. PUMP INFORMATION:

PUMP ID: 4224000 PUMP Name: FRANCO, PH WATER DEPARTMENT CITY/TOWN: FRANCO, PH CLASS: TNG

4. ANALYTICAL INFORMATION: Refer to your Mass Chlorine Collection Plan and/or Chlorine Monitoring Plan to help complete this section.
 Type Measured: Free Chlorine Total Chlorine Combined Chlorine
 Analytical Method: SM 4500-Cl ASTM D1249-05

Notes:

PUMP Sample Type	PUMP Location Details	PUMP APPROVED SAMPLE LOCATION?	CHLORINE RESULT (mg/L)	COLLECTION AND ANALYSIS		COLLECTED AND ANALYZED BY
				DATE	TIME	
RS	000	TOWER HILL, BONDIOL, ... ADAMS STREET	1.71	12-20-21	10:00 AM	A. PIERRE-LOUIS
RS	004	JFK SCHOOL, ... 20 HURLEY DRIVE	1.80		9:30 AM	
RS	000	MARTIN E. YOUNG SCHOOL, COURTNEY DRIVE	1.41		9:00 AM	
RS	000	CAMPBELL INN, ... 1824 NORTH MAIN STREET	1.87		11:00 AM	
RS	000	NORTH MIDDLE SCHOOL, ... HIGH STREET	1.89		10:30 AM	
RS	011	MOBIL STATION, ... 89 MARZEO DRIVE	1.75		9:30 AM	
RS	012	7-11 FOOD SHOP, ... 670 NORTH STREET	.90		8:30 AM	
RS	014 A	SPRINGWOOD, ... 279 NORTH MAIN STREET	NO ACCESS	DVE	TS	COVERED - 19
RS	014E	MAP AUTO - 317 NORTH MAIN ST.	1.87		8:00 AM	
RS	016	OAK GROVE STANDPIPE	1.44		9:45 AM	
RS	017	ECOUTA MAIN STREET STANDPIPE	1.24		9:15 AM	

1. PUMP OPERATOR: YVES KAMONDIOL and PUMP APPROVED SAMPLE LOCATION: ADAMS STREET are your Chlorine Collection Sampling Plan. If you have any questions, please contact the person listed below. If you have any questions, please contact the person listed below. If you have any questions, please contact the person listed below.

2. CHLORINE MONITORING REPORT: YVES KAMONDIOL (PUMP ID: 4224000)
 Average Chlorine Residual at All Standpipes: 1.36
 Average Chlorine Residual at All Standpipes: 1.36
 I certify under penalty of law that I am the person authorized to fill out this report and the information contained herein is true, accurate and complete to the best of my knowledge.

DATE REVIEWED: 1-6-2022
 REVIEWER: [Signature]
 REVIEW COMMENTS: [Blank]



Massachusetts Department of Environmental Protection - Drinking Water Program Disinfection Byproducts Rule Compliance Report

DBPR

I. PWS INFORMATION - Please refer to your DBPR Monitoring Plan to help complete this form.

PWS ID #: 4244001 City / Town: RANDOLPH
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM NTNC TNC
 Monitoring Period (YEAR): 2021 Monitoring Period (QUARTER): Q1 (Jan-Mar) Q2 (Apr-Jun) Q3 (Jul-Sep) Q4 (Oct-Dec)

II. FOR SYSTEMS USING CHLORINATION

A. Trihalomethanes (TTHM)
 Total Number of TTHM Samples: _____ Quarterly Average: _____ µg/L
 Was the Running Annual Average MCL (80 µg/L) exceeded? Yes No Running Annual Average: _____ µg/L

B. Haloacetic Acids (HAA5)
 Total Number of HAA5 Samples: _____ Quarterly Average: _____ µg/L
 Was the Running Annual Average MCL (60 µg/L) exceeded? Yes No Running Annual Average: _____ µg/L

C. Chlorine/Chloramines
 Total Number of Samples:

Month 1:	<u>66</u> <u>OCT</u>	Monthly Averages:	<u>1.06</u> mg/L	Quarterly Average: <u>1.23</u> mg/L
Month 2:	<u>70</u> <u>NOV</u>	(report all 3 months per quarter)	<u>1.27</u> mg/L	
Month 3:	<u>66</u> <u>DEC</u>		<u>1.36</u> mg/L	

 Running Annual Average: 1.16 mg/L
 Was the Running Annual Average MRDL (4.0 mg/L) exceeded? Yes No

D. Total Organic Carbon - raw (TOC) (Required for SW or GWUDI systems >499 seeking or approved to reduce TTHM/HAA5 monitoring.) Plant Name: _____
 (Attach additional sheet(s) to report more than 1 plant)
 Total Number of Samples:

Month 1:		Monthly Averages:	_____ mg/L	Quarterly Average: _____ mg/L
Month 2:		(report all 3 months per quarter)	_____ mg/L	
Month 3:			_____ mg/L	

 Running Annual Average: _____ mg/L
 Was the (4.0 mg/L) threshold exceeded? Yes No

III. FOR SYSTEMS USING OZONATION - Attach additional sheet(s) to report more than 1 plant.

E. Bromate (treated) Plant Name: _____
 Total Number of Samples:

Month 1:		Monthly Averages:	_____ mg/L	Quarterly Average: _____ mg/L
Month 2:		(report all 3 months per quarter)	_____ mg/L	
Month 3:			_____ mg/L	

 Running Annual Average: _____ mg/L
 Was the Running Annual Average MCL (0.010 ug/l) exceeded? Yes No

F. Bromide (raw) Plant Name: _____
 Required for systems seeking or approved to reduce Bromate monitoring
 Total Number of Samples:

Month 1:		Monthly Averages:	_____ mg/L	Quarterly Average: _____ mg/L
Month 2:		(report all 3 months per quarter)	_____ mg/L	
Month 3:			_____ mg/L	

 Running Annual Average: _____ mg/L
 Was the (0.05 mg/l) threshold exceeded? Yes No

IV. FOR SYSTEMS USING CHLORINE DIOXIDE - Report compliance information on your Chlorine/Chlorine Dioxide (Daily Samples) Report.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature: William Corbett Date: 1-6-2022

DEFINITIONS	
MONTHLY AVERAGE:	Monthly average = average of all results within the current month.
QUARTERLY AVERAGE:	Quarterly Average = average result of all locations sampled during monitoring period
RUNNING ANNUAL AVERAGE:	Running Annual Average = Average of 4 quarters. Average of this quarter and three prior consecutive quarterly averages (for systems on quarterly monitoring)
TOTAL NUMBER OF SAMPLES:	Total number of samples collected during the monitoring period.

NOTE: Record and calculate all ND or <MDL results as the number zero (0).

Submit one copy of this form each quarter to your DEP regional office (by Jan 10th, April 10th, July 10th, and Oct 10th of each year)

DEP REVIEW STATUS (Initial & Date)
 Accepted _____ Disapproved _____
 Review Comments: _____



CERTIFICATE OF ANALYSIS

Chris Pelleteri
Randolph - Holbrook Joint Water Board
50 North Franklin Street
Holbrook, MA 02343

Project Name: DOC SUVA
Work Order Number: A1J0064
Date Received: 10/04/2021

Sampled By: Bill Cookerly
Location: Raw Water

Date Sampled: 10/4/21 9:00
Matrix: Drinking Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL/ Rec.Limit#	Result
<i>Test Parameters</i>				LAB-ID#: <u>A1J0064-01</u>		
Dissolved Organic Carbon (Average)	5310B	10/5/2021	mg/L	0.500	—	5.63
SUVA	4153	10/5/2021	/100 ml	N/A	—	0.0196
UV 254	5910B	10/5/2021	abs/cm	0.002	—	0.109

Sampled By: Bill Cookerly
Location: Combined Filter Effluent Grab

Date Sampled: 10/4/21 9:00
Matrix: Drinking Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL/ Rec.Limit#	Result
<i>Test Parameters</i>				LAB-ID#: <u>A1J0064-02</u>		
Dissolved Organic Carbon (Average)	5310B	10/5/2021	mg/L	0.500	—	3.17
SUVA	4153	10/5/2021	/100 ml	N/A	—	0.0166
UV 254	5910B	10/5/2021	abs/cm	0.002	—	0.052

NA = Not Applicable
ND = Not Detected
<= Less Than
>= Greater Than
* = Detection Limit
Rec Limit# = Recommended Limit

Approved By: *Laurie H. Hood*

Work Order Narrative:

No unusual observations noted.

REVIEWED
By Amanda Cronin at 7:32 am, Nov 18, 2021



CERTIFICATE OF ANALYSIS

Chris Pelletieri
Randolph - Holbrook Joint Water Board
50 North Franklin Street
Holbrook, MA 02343

Project Name: DOC SUVA
Work Order Number: AIK0297
Date Received: 11/08/2021

Sampled By: Bill Cookerly
Location: Raw Water

Date Sampled: 11/8/21 9:00
Matrix: Surface Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det Limit	MCL/Rec Limit#	Result
<i>Test Parameters</i>				LAB-ID#: <u>AIK0297-01</u>		
Dissolved Organic Carbon (Average)	5310B	11/10/2021	mg/L	0.500	—	5.25
SUVA	415S	11/10/2021	/100 ml	N/A	—	0.0251
UV 254	5910B	11/9/2021	abs/cm	0.002	—	0.121

Sampled By: Bill Cookerly
Location: Combined Filter Effluent Grab

Date Sampled: 11/8/21 9:00
Matrix: Drinking Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det Limit	MCL/Rec Limit#	Result
<i>Test Parameters</i>				LAB-ID#: <u>AIK0297-02</u>		
Dissolved Organic Carbon (Average)	5310B	11/10/2021	mg/L	0.500	—	5.49
SUVA	415S	11/10/2021	/100 ml	N/A	—	0.0140
UV 254	5910B	11/9/2021	abs/cm	0.002	—	0.049

NA = Not Applicable
ND = Not Detected
<= Less Than
>= Greater Than
* = Detection Limit
Rec Limit# = Recommended Limit

Approved By: *Lance Stoddard*

Work Order Narrative:

No unusual observations noted.

REVIEWED
By mgargasz at 1:20 pm, Nov 18, 2021