



Town of Holbrook

Office of Joint Superintendent
(781) 767-1800
Fax (781) 767-0705

**RANDOLPH-HOLBROOK
JOINT WATER BOARD**

50 North Franklin Street
Holbrook, MA 02343



Town of Randolph

February 13, 2020

Commonwealth of Massachusetts
Department of Environmental Protection
Southeast Regional Office
20 Riverside Drive
Lakeville, MA 02374

Monthly Reports Filtered System Forms
Forms F, G, I, J, TT
Analysis for TOC, DOC and SUVA
Chemical Addition Reports
DBPR Compliance Report
January, 2020 Randolph/Holbrook
Joint Water System, PWS #424001

Gentlemen:

Enclosed please find all reports as referenced above for the month of January, 2020. Should there be any questions, please do not hesitate to call.

Sincerely,

William Cookerly
Chief Plant Operator

Enclosures

Cc: Board of Health
Ryan Allgrove, EPG



Compliance Determination for Filtered Systems - Monthly Report

I. PWS INFORMATION

PWSID#: 4244001 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Town: RANDOLPH
Treatment Plant Name: RANDOLPH WATER PLANT Reporting Period -> Month: JANUARY Year: 2020

II. TURBIDITY PERFORMANCE CRITERIA

1. Monthly Turbidity (95%) NTU Limit - The turbidity level of a system's filtered water must be less than or equal to the Monthly Turbidity NTU Limit in at least 95% of the measurements taken each month for the filtration technology used, otherwise SWTR TT Violation (Tier 2).
186 = A Total # of filtered water turbidity measurements for month (SWTR - Form F)
186 = B Total # of filtered water turbidity measurements less than or equal to the specified limits for the filtration technology used.
100 = (B/A) x 100 The percentage of turbidity measurements meeting the Monthly Turbidity 95% NTU Limit.
2. Max Day NTU Limit - The turbidity level of a system's filtered water must at no time exceed the Max Day NTU Limit for the filtration technology used, otherwise SWTR TT Violation (Tier 2).
Record the date and turbidity value for any measurements exceeding the Max Day NTU. Check box [X] if "None"
Table with columns: Date, Value, Date Reported to DEP.
For each day the Max Day NTU limit is exceeded, the DEP must be notified by the end of the next business day. SWTR TT Violation (Tier 2). If DEP is not consulted within 24 hours then it is a SWTR TT (Tier 1) violation requiring public notification within 24 hours.

III. DISINFECTION PERFORMANCE CRITERIA

1. Point-of-Entry Minimum Disinfectant Residual Criteria - Residual Disinfectant concentration cannot be < 0.2 mg/L for more than 4 hours. SWTR TT Violation (Tier 2).
Minimum Disinfectant Residual at Point-of-Entry to Distribution System.
Table with columns: Day, Cl2 mg/l.
If at any time the residual falls below 0.2 mg/l in the water entering the distribution system, the supplier of water must notify the Department as soon as possible, but no later than by the end of the next business day. The supplier of water also must notify the Department by the end of the next business day whether or not the residual was restored to at least 0.2 mg/l within four hours.
Table with columns: Date(s) Residual < 0.2 mg/l, Duration of Low Level (hrs.), Date Reported to DEP.

2. Distribution System Disinfectant Residual Criteria - Residual Disinfectant concentration (V) cannot be undetectable in greater than 5% of samples in a month, for any two consecutive months. SWTR TT Violation (Tier 2). Chlorine residuals must be measured at the same time and location as total coliform distribution routine & repeat samples. If no residual is detected, an HPC sample must be collected and analyzed.
Total # of HPC samples taken during month: 63 # HPC sites > 500/mL: 0 # HPC sites <= 500/mL: 63
66 = a # of sites where Cl2 residual measurements were made, whether a residual was detected or not (should be the same # of sites reported on your monthly DBPR Cl2 residual report)
0 = b # of sites HPC samples were analyzed instead of Cl2 residual measurements
0 = c # of sites where no Cl2 residual was detected and no HPC sample was analyzed
0 = d # of sites where no Cl2 residual was detected and HPC > 500 CFU/mL
0 = e # of sites where no Cl2 residual measurement was made and HPC > 500 CFU/mL
Water in the distribution system with a heterotrophic bacteria concentration (HPC) less than or equal to 500/mL, is deemed to have a detectable disinfectant residual for purposes of determining compliance with this requirement. When analyzed, report HPC results on your monthly DEP Bacteriological Report.
V = (c+d+e) / (a+b) x 100 This Month % V = 0 Previous Month % V = Is V > 5% for 2 months? [X] No

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true.

PWS Authorized Signature: William C. [Signature] Chief Plant Operator
2-13-2020



Massachusetts Department of Environmental Protection - Drinking Water Program **SWTR**
CT Determination for Filtered Systems **I**

I. PWS INFORMATION:

PWSID#: 4244001 PWS Name: Randolph-Hillbrook Joint Water PWS Town: Randolph
 Treatment Plant Name: Randolph Water Plant Reporting Period → Month: JANUARY Year: 2020
 Disinfectant¹: Chlorine Gas/Ester Eff. Sequence of Application: 1st 2nd 3rd 4th 5 6th

II. DAILY REPORTING: All measurements taken during peak hourly flow.

| Day | Peak Hourly Flow ² (gpm) | Disinfectant Concentration ³ C (mg/L) | Disinfectant Contact Time ⁴ T (min.) | CT calc (= C x T) | pH ⁵ | Water Temp ⁶ (°C) | CT ⁷ 99.9 | Inactivation Ratio ⁸ (CT calc / CT 99.9) | Inactivation Ratio ⁹ < 1.0 |
|-----|-------------------------------------|--|---|-------------------|-----------------|------------------------------|----------------------|---|---------------------------------------|
| 1 | 2,400 | 1.92 | 50 | 96 | 6.00 | 7.0 | 11 | 8.7 | <input type="checkbox"/> Yes |
| 2 | 2,400 | 1.85 | 50 | 92.5 | 5.85 | 6.0 | 11 | 8.4 | <input type="checkbox"/> Yes |
| 3 | 2,400 | 1.93 | 50 | 96.5 | 6.05 | 6.2 | 11 | 8.8 | <input type="checkbox"/> Yes |
| 4 | 2,400 | 1.79 | 50 | 89.5 | 5.90 | 6.0 | 11 | 8.1 | <input type="checkbox"/> Yes |
| 5 | 2,400 | 1.94 | 50 | 97 | 6.10 | 5.8 | 11 | 8.8 | <input type="checkbox"/> Yes |
| 6 | 2,400 | 1.82 | 50 | 91 | 5.85 | 4.9 | 11 | 8.3 | <input type="checkbox"/> Yes |
| 7 | 2,400 | 1.43 | 50 | 71.5 | 6.10 | 4.6 | 11 | 6.5 | <input type="checkbox"/> Yes |
| 8 | 2,400 | 1.97 | 50 | 92.5 | 6.05 | 5.0 | 11 | 9.0 | <input type="checkbox"/> Yes |
| 9 | 2,400 | 2.12 | 50 | 108.5 | 6.15 | 5.3 | 11 | 9.9 | <input type="checkbox"/> Yes |
| 10 | 2,400 | 2.15 | 50 | 107.5 | 6.00 | 5.9 | 11 | 9.8 | <input type="checkbox"/> Yes |
| 11 | 2,400 | 1.98 | 50 | 99 | 5.90 | 7.2 | 11 | 9.0 | <input type="checkbox"/> Yes |
| 12 | 2,400 | 2.04 | 50 | 102 | 5.95 | 6.8 | 11 | 9.3 | <input type="checkbox"/> Yes |
| 13 | 2,400 | 1.18 | 50 | 59 | 6.05 | 6.8 | 11 | 5.4 | <input type="checkbox"/> Yes |
| 14 | 2,400 | 2.22 | 50 | 111 | 6.00 | 6.00 | 11 | 10.1 | <input type="checkbox"/> Yes |
| 15 | 2,400 | 2.20 | 50 | 110 | 6.10 | 4.8 | 11 | 10.0 | <input type="checkbox"/> Yes |
| 16 | 2,400 | 2.03 | 50 | 101.5 | 6.05 | 4.6 | 11 | 9.2 | <input type="checkbox"/> Yes |
| 17 | 2,400 | 2.06 | 50 | 103 | 5.90 | 4.0 | 11 | 9.4 | <input type="checkbox"/> Yes |
| 18 | 2,400 | 2.09 | 50 | 104.5 | 6.05 | 3.9 | 11 | 9.5 | <input type="checkbox"/> Yes |
| 19 | 2,400 | 1.89 | 50 | 94.5 | 5.95 | 3.2 | 11 | 8.6 | <input type="checkbox"/> Yes |
| 20 | 2,400 | 2.03 | 50 | 101.5 | 5.95 | 3.7 | 11 | 9.2 | <input type="checkbox"/> Yes |
| 21 | 2,400 | 2.02 | 50 | 101 | 6.10 | 3.8 | 11 | 9.2 | <input type="checkbox"/> Yes |
| 22 | 2,400 | 2.07 | 50 | 103.5 | 6.15 | 4.7 | 11 | 9.4 | <input type="checkbox"/> Yes |
| 23 | 2,400 | 2.11 | 50 | 105.5 | 6.05 | 5.2 | 11 | 9.6 | <input type="checkbox"/> Yes |
| 24 | 2,400 | 2.12 | 50 | 106 | 5.90 | 4.8 | 11 | 9.6 | <input type="checkbox"/> Yes |
| 25 | 2,400 | 2.09 | 50 | 104.5 | 6.15 | 4.9 | 11 | 9.5 | <input type="checkbox"/> Yes |
| 26 | 2,400 | 2.00 | 50 | 100 | 6.20 | 5.5 | 11 | 9.1 | <input type="checkbox"/> Yes |
| 27 | 2,400 | 2.04 | 50 | 102 | 6.15 | 5.0 | 11 | 9.3 | <input type="checkbox"/> Yes |
| 28 | 2,400 | 2.00 | 50 | 100 | 6.00 | 5.0 | 11 | 9.1 | <input type="checkbox"/> Yes |
| 29 | 2,400 | 1.99 | 50 | 99.5 | 6.05 | 4.1 | 11 | 9.1 | <input type="checkbox"/> Yes |
| 30 | 2,400 | 1.98 | 50 | 99 | 6.10 | 4.7 | 11 | 9.0 | <input type="checkbox"/> Yes |
| 31 | 2,400 | 2.01 | 50 | 100.5 | 5.90 | 4.3 | 11 | 9.1 | <input type="checkbox"/> Yes |

1. Use a separate form for each disinfectant/sampling point. Enter disinfectant and sequence position, e.g. "ozone/1st" or "ClO₂/3rd". If more than one disinfectant sampling point, you must also complete SWTR Form H and calculate the cumulative inactivation ratio SUM (CTcalc/CT99.9) to determine compliance.
2. Peak hourly flow means the highest pumpage hour during the day, not the absolute peak flow at any instant.
3. The residual disinfectant concentration(s) ("C") of the water before or at the first customer must be measured each day during peak hourly flow.
4. The disinfectant contact time(s) ("T") must be determined for each day during peak hourly flow. The time T used in calculating CT, is the time it takes the water, during peak hourly flow, to move between the point of disinfection application and the point at which the residual is measured.
5. If the system uses free chlorine, the pH of the disinfected water must be measured at least once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
6. The temperature of the disinfected water must be measured at least once per day at each residual disinfectant concentration sampling point during peak hourly flow.
7. Use Inactivation Tables at 310 CMR 22.20A Tables 1.1 – 1.6, 2.1 and/or 3.1
8. The inactivation ratio (CTcalc/CT99.9) is determined before or at the first customer during peak hourly flow and if the (CTcalc/CT99.9) is < 1.0, the 99.9% *Giardia lamblia* inactivation requirement has not been achieved.
9. More than one "Yes" response above may indicate a SWTR Treatment Technique violation (Tier 2).

certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Conkerly

Date: 2-4-2020 Title: Chief Operator



I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details

| | | | | | |
|-------------------------------------|----------------------|------------------------------------|-------------------|---------------------------------|-----------------------------|
| PWS Name ¹ : | RANDOLPH-HOLBROOK JW | Town ¹ : | RANDOLPH-HOLBROOK | PWSID ¹ : | 424001 |
| Treatment Plant Name ² : | RANDOLPH WATER PLANT | Treatment Plant ID# ² : | 4244001-01T | Reporting Period ³ : | JANUARY, 2020 Month Year |

II. Chemical & Operational Information

| | | | | | |
|---|------------------------|---|------|--------------------------------------|------|
| Chemical Name ⁴ : | POLYALUMINIUM CHLORIDE | Purchased Strength ⁸ : | 1.0 | Target Range/min ¹² : | > 18 |
| Manufacturer ⁵ : | HOLLAND COMPANY | Purchased Density (lbs/gal) ⁹ : | 10.3 | Target Dose ¹³ : | 2.35 |
| Product Name ⁶ : | PCH-180 | Dilution Factor or Mix Ratio ¹⁰ : | NA | Alarm Setting (low) ¹⁴ : | NA |
| Reason for Adding Chemical ⁷ : | COAGULATION | NSF Approved (Y/N) ¹¹ : | Y | Alarm Setting (high) ¹⁴ : | NA |
| | | Date of last anti-siphon valve inspection/replacement ¹⁵ : | | NA | |

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

| Day | Treated Water ¹⁶ <input type="checkbox"/> Gallons. <input checked="" type="checkbox"/> MG | Measured Chemical Used | | Calculated Chemical Used (lbs) ¹⁸ | Chemical Dosage ¹⁹ (mg/L) | Parameters Measured*, Results, Units and Method ²⁰ - (G)rab or Continuous (A)alyzer ²¹ | | | O&M Notes/Comments ²² PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc. | |
|--------|--|--------------------------------|--------------------------------|--|--------------------------------------|---|---|---|--|--|
| | | Volume ¹⁷ (gal/day) | Weight ¹⁷ (lbs/day) | | | a. RAW Ph DAILY AVG | b. . | c. | | |
| | | | | | | <input type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | | |
| 1 | 2.8 | 145 | | 1,494 | 21 | 7.15 | | | | |
| 2 | 2.8 | 164 | | 1,689 | 24 | 7.15 | | | | |
| 3 | 2.7 | 135 | | 1,391 | 20 | 7.05 | | | | |
| 4 | 2.8 | 140 | | 1,442 | 20 | 7.10 | | | | |
| 5 | 2.7 | 120 | | 1,236 | 18 | 7.10 | | | | |
| 6 | 2.4 | 120 | | 1,236 | 20 | 7.05 | | | | |
| 7 | 2.5 | 160 | | 1,648 | 26 | 7.15 | | | | |
| 8 | 2.8 | 161 | | 1,658 | 23 | 7.10 | | | | |
| 9 | 2.8 | 147 | | 1,574 | 21 | 7.15 | | | | |
| 10 | 3.5 | 155 | | 1,597 | 18 | 7.20 | | | | |
| 11 | 2.9 | 200 | | 2,060 | 28 | 7.20 | | | | |
| 12 | 2.4 | 140 | | 1,442 | 24 | 7.15 | | | | |
| 13 | 3.4 | 150 | | 1,545 | 18 | 7.15 | | | | |
| 14 | 2.8 | 150 | | 1,545 | 22 | 7.20 | | | | |
| 15 | 2.8 | 158 | | 1,627 | 23 | 7.15 | | | | |
| 16 | 2.9 | 191 | | 1,967 | 27 | 7.10 | | | | |
| 17 | 2.7 | 159 | | 1,638 | 24 | 7.00 | | | | |
| 18 | 2.7 | 134 | | 1,380 | 20 | 7.15 | | | | |
| 19 | 2.8 | 120 | | 1,236 | 18 | 7.00 | | | | |
| 20 | 2.7 | 125 | | 1,288 | 19 | 7.15 | | | | |
| 21 | 2.8 | 125 | | 1,288 | 18 | 7.05 | | | | |
| 22 | 2.8 | 151 | | 1,555 | 22 | 7.05 | | | | |
| 23 | 3.0 | 166 | | 1,710 | 23 | 7.00 | | | | |
| 24 | 2.7 | 135 | | 1,391 | 20 | 7.00 | | | | |
| 25 | 3.0 | 165 | | 1,700 | 22 | 7.20 | | | | |
| 26 | 2.8 | 180 | | 1,854 | 26 | 7.15 | | | | |
| 27 | 2.8 | 155 | | 1,597 | 23 | 7.10 | | | | |
| 28 | 2.7 | 160 | | 1,648 | 24 | 7.15 | | | | |
| 29 | 2.8 | 170 | | 1,751 | 25 | 7.05 | | | | |
| 30 | 2.8 | 142 | | 1,463 | 21 | 7.20 | | | | |
| 31 | 2.7 | 140 | | 1,442 | 21 | 7.20 | | | | |
| Total: | | | | | | Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ : | | | | |

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

a. Raw Ph, Daily Average, Test Kit
 b.
 c.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person - Signature & Date²⁴:
 William Coakley 2-4-2020
 Print Name: William Coakley Title: Chief Operator



Massachusetts Department of Environmental Protection – Drinking Water Program
CHEMICAL ADDITION REPORT – 310 CMR 11.15(4) Chemical Addition Reporting Requirements

C-ADD

I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

| | | | | | |
|-------------------------------------|-------------------------------|------------------------------------|-------------------|---------------------------------|----------------------------|
| PWS Name ¹ : | RANDOLPH-HOLBROOK JOINT WATER | Town ¹ : | RANDOLPH-HOLBROOK | PWSID ¹ : | 424001 |
| Treatment Plant Name ² : | RANDOLPH WATER PLANT | Treatment Plant ID# ² : | 4244001-01T | Reporting Period ³ : | JANUARY 2020 Month Year |

II. Chemical & Operational Information

| | | | | | |
|---|--------------|---|------|--------------------------------------|------|
| Chemical Name ⁴ : | CHLORINE | Purchased Strength ⁸ : | 1.0 | Target Range/min ¹² : | 0.20 |
| Manufacturer ⁵ : | AXIALL, LLC | Purchased Density (lbs/gal) ⁹ : | 12.3 | Target Dose ¹³ : | NA |
| Product Name ⁶ : | CHLORINE | Dilution Factor or Mix Ratio ¹⁰ : | NA | Alarm Setting (low) ¹⁴ : | 1.0 |
| Reason for Adding Chemical ⁷ : | DISINFECTANT | NSF Approved (Y/N) ¹¹ : | Y | Alarm Setting (high) ¹⁴ : | 3.0 |
| | | Date of last anti-siphon valve inspection/replacement ¹⁵ : | NA | | |

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

| Day | Treated Water ¹⁶ <input type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG | Measured Chemical Used | | Calculated Chemical Used (lbs) ¹⁸ | Chemical Dosage ¹⁹ (mg/L) | Parameters Measured*, Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹ | | | O&M Notes/Comments ²² PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc. |
|-------|---|--------------------------------|--------------------------------|--|---|---|--|---|--|
| | | Volume ¹⁷ (gal/day) | Weight ¹⁷ (lbs/day) | | | a. FREE Cl ₂ Finished | b. FREE Cl ₂ Finished | c. | |
| | | | | | | <input checked="" type="checkbox"/> G <input type="checkbox"/> A | <input checked="" type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | |
| 1 | 2.8 | | 74 | | 3.2 | 2.04 | 1.92 | | |
| 2 | 2.8 | | 70 | | 3.0 | 2.00 | 1.85 | | |
| 3 | 2.7 | | 71 | | 3.2 | 2.02 | 1.93 | | |
| 4 | 2.8 | | 70 | | 3.0 | 2.00 | 1.79 | | |
| 5 | 2.7 | | 71 | | 3.2 | 2.00 | 1.94 | | |
| 6 | 2.4 | | 79 | | 4.0 | 1.95 | 1.82 | | |
| 7 | 2.5 | | 66 | | 3.2 | 2.21 | 1.43 | | |
| 8 | 2.8 | | 73 | | 3.1 | 2.24 | 1.97 | | |
| 9 | 2.8 | | 70 | | 3.0 | 2.29 | 2.17 | | |
| 10 | 3.5 | | 78 | | 2.7 | 2.36 | 2.15 | | |
| 11 | 2.9 | | 64 | | 2.7 | 2.29 | 1.98 | | |
| 12 | 2.4 | | 48 | | 2.4 | 2.27 | 2.04 | | |
| 13 | 3.4 | | 85 | | 3.0 | 2.14 | 1.18 | | |
| 14 | 2.8 | | 85 | | 3.6 | 2.36 | 2.22 | | |
| 15 | 2.8 | | 85 | | 3.6 | 2.30 | 2.20 | | |
| 16 | 2.9 | | 78 | | 3.2 | 2.18 | 2.03 | | |
| 17 | 2.7 | | 74 | | 3.3 | 2.18 | 2.06 | | |
| 18 | 2.7 | | 77 | | 3.4 | 2.22 | 2.09 | | |
| 19 | 2.8 | | 76 | | 3.3 | 2.11 | 1.89 | | |
| 20 | 2.7 | | 79 | | 3.5 | 2.13 | 2.03 | | |
| 21 | 2.8 | | 77 | | 3.3 | 2.20 | 2.02 | | |
| 22 | 2.8 | | 82 | | 3.5 | 2.22 | 2.07 | | |
| 23 | 3.0 | | 73 | | 2.9 | 2.29 | 2.11 | | |
| 24 | 2.7 | | 77 | | 3.4 | 2.21 | 2.12 | | |
| 25 | 3.0 | | 77 | | 3.1 | 2.29 | 2.09 | | |
| 26 | 2.8 | | 68 | | 2.9 | 2.16 | 2.00 | | |
| 27 | 2.8 | | 71 | | 3.0 | 2.18 | 2.04 | | |
| 28 | 2.7 | | 67 | | 3.0 | 2.13 | 2.00 | | |
| 29 | 2.8 | | 68 | | 2.9 | 2.14 | 1.99 | | |
| 30 | 2.8 | | 70 | | 3.0 | 2.16 | 1.98 | | |
| 31 | 2.7 | | 69 | | 3.1 | 2.19 | 2.01 | | |
| Total | | | | | Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary ²³ : | | | | |

*Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

a. Daily Average, Free Chlorine, Finished Water, Grab Sample, Test Kit
 b. Daily Minimum, Free Chlorine, Finished Water, Grab Sample, Test Kit
 c.

PWS Authorized Person - Signature & Date²⁴:
 William Coakley 2-4-2020
 Print Name: William Coakley Title: Chief Operator



| | | | | | |
|--|----------------------|--|-----------------------------------|-------------------|--|
| I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details. | | | | | |
| PWS Name ¹ : | RANDOLPH-HOLBROOK JW | | Town ¹ : | RANDOLPH-HOLBROOK | |
| PWSID ¹ : | 424001 | | | | |
| Treatment Plant Name ² : | RANDOLPH WATER PLANT | | Treatment Plant ID ² : | 424001-01T | |
| Reporting Period ³ : | JANUARY | | Month | 2020 | |
| | | | Year | | |

| | | | | | |
|---|------------------------|--|---|------|--|
| II. Chemical & Operational Information | | | | | |
| Chemical Name ⁴ : | CALCIUM HYDROXIDE | | Purchased Strength ⁸ : | 0.85 | |
| Manufacturer ⁵ : | CARMELUSE LIME & STONE | | Purchased Density (lbs/gal) ⁹ : | 18.7 | |
| Product Name ⁶ : | HYDRATED LIME | | Dilution Factor or Mix Ratio ¹⁰ : | NA | |
| Reason for Adding Chemical ⁷ : | PH ADJUSTMENT | | NSF Approved (Y/N) ¹¹ : | Y | |
| | | | Target Range/min ¹² : | NA | |
| | | | Target Dose ¹³ : | NA | |
| | | | Alarm Setting (low) ¹⁴ : | NA | |
| | | | Alarm Setting (high) ¹⁴ : | NA | |
| | | | Date of last anti-siphon valve inspection/replacement ¹⁵ : | NA | |

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

| Day | Treated Water ¹⁶ | | Measured Chemical Used | | Calculated Chemical Used (lbs) ¹⁸ | Chemical Dosage ¹⁹ (mg/L) | Parameters Measured ⁴ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹ | | | O&M Notes/Comments ²² |
|--------------|----------------------------------|--|--------------------------------|--------------------------------|--|--|--|---|----|--|
| | <input type="checkbox"/> Gallons | <input checked="" type="checkbox"/> MG | Volume ¹⁷ (gal/day) | Weight ¹⁷ (lbs/day) | | | a. <i>Finished Ph</i> | b. | c. | |
| | | | | | | <input checked="" type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | | |
| 1 | | 2.5 | | 100 | | 4.8 | 7.10 | | | |
| 2 | | 2.4 | | 100 | | 5.0 | 7.00 | | | |
| 3 | | 2.3 | | 100 | | 5.2 | 7.05 | | | |
| 4 | | 2.3 | | 100 | | 5.2 | 7.15 | | | |
| 5 | | 2.4 | | 100 | | 5.0 | 7.10 | | | |
| 6 | | 2.2 | | 100 | | 5.5 | 7.00 | | | |
| 7 | | 2.0 | | 100 | | 6.0 | 7.15 | | | |
| 8 | | 2.4 | | 100 | | 5.0 | 7.20 | | | |
| 9 | | 2.3 | | 100 | | 5.2 | 7.10 | | | |
| 10 | | 2.4 | | 100 | | 5.0 | 7.05 | | | |
| 11 | | 2.3 | | 100 | | 5.2 | 7.15 | | | |
| 12 | | 1.5 | | 100 | | 6.0 | 7.00 | | | |
| 13 | | 2.8 | | 100 | | 4.3 | 7.05 | | | |
| 14 | | 2.7 | | 100 | | 4.4 | 7.15 | | | |
| 15 | | 3.0 | | 100 | | 4.0 | 7.10 | | | |
| 16 | | 2.7 | | 100 | | 4.4 | 7.05 | | | |
| 17 | | 2.9 | | 100 | | 4.8 | 7.15 | | | |
| 18 | | 2.5 | | 100 | | 4.8 | 7.00 | | | |
| 19 | | 2.6 | | 100 | | 4.6 | 7.10 | | | |
| 20 | | 2.6 | | 100 | | 4.6 | 7.05 | | | |
| 21 | | 2.8 | | 100 | | 4.6 | 7.15 | | | |
| 22 | | 2.8 | | 100 | | 4.4 | 7.05 | | | |
| 23 | | 3.0 | | 100 | | 4.0 | 7.00 | | | |
| 24 | | 2.7 | | 100 | | 4.4 | 7.15 | | | |
| 25 | | 3.0 | | 100 | | 4.0 | 7.05 | | | |
| 26 | | 2.8 | | 100 | | 4.6 | 7.00 | | | |
| 27 | | 2.8 | | 100 | | 4.6 | 7.10 | | | |
| 28 | | 2.7 | | 100 | | 5.0 | 7.05 | | | |
| 29 | | 2.8 | | 100 | | 4.8 | 6.90 | | | |
| 30 | | 2.7 | | 100 | | 4.8 | 7.05 | | | |
| 31 | | 2.7 | | 100 | | 5.2 | 7.00 | | | |
| Total | | | | 100 | | | | | | Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³: |

| | | | |
|---|---|--|--|
| *Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.) ²⁰ : | | I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge. | |
| a. | <i>Finished Water Ph, Daily Average, Test Kit</i> | | PWS Authorized Person - Signature & Date ²⁴ : |
| b. | | | <i>William Cookerly 2-4-2020</i> |
| c. | | | Print Name: <i>William Cookerly</i> Title: <i>Chief Operator</i> |



I. PWS Information - Refer to MassDEP "Chemical Addition Report Guidance and Instructions" for details.

| | | | | | |
|-------------------------------------|-----------------------------|-----------------------------------|--------------------------|---------------------------------|---------------------|
| PWS Name ¹ : | <i>RANDOLPH-HOLBROOK JW</i> | Town ¹ : | <i>RANDOLPH-HOLBROOK</i> | PWSID ¹ : | <i>424001</i> |
| Treatment Plant Name ² : | <i>RANDOLPH WATER PLANT</i> | Treatment Plant ID ² : | <i>4244001-01T</i> | Reporting Period ³ : | <i>JANUARY 2020</i> |
| | | | | Month | Year |

II. Chemical & Operational Information

| | | | | | |
|---|----------------------------|---|--------------|--------------------------------------|-----------|
| Chemical Name ⁴ : | <i>SODIUM BISULFATE</i> | Purchased Strength ⁸ : | <i>10-15</i> | Target Range/min ¹² : | <i>NA</i> |
| Manufacturer ⁵ : | <i>CARUS CORPORATION</i> | Purchased Density (lbs/gal) ⁹ : | <i>12.03</i> | Target Dose ¹³ : | <i>NA</i> |
| Product Name ⁶ : | <i>CARUS 3350</i> | Dilution Factor or Mix Ratio ¹⁰ : | <i>0.33</i> | Alarm Setting (low) ¹⁴ : | <i>NA</i> |
| Reason for Adding Chemical ⁷ : | <i>CORROSION INHIBITOR</i> | NSF Approved (Y/N) ¹¹ : | <i>Y</i> | Alarm Setting (high) ¹⁴ : | <i>NA</i> |
| | | Date of last anti-siphon valve inspection/replacement ¹⁵ : | | | |

III. Daily Reporting Note: Water quality data reported on C-ADD form may be considered for compliance purposes.

| Day | Treated Water ¹⁶ <input type="checkbox"/> Gallons <input checked="" type="checkbox"/> MG | Measured Chemical Used | | Calculated Chemical Used (lbs) ¹⁸ | Chemical Dosage ¹⁹ (mg/L) | Parameters Measured ²⁰ , Results, Units and Method ²⁰ - (G)rab or Continuous (A)nalyzer ²¹ | | | O&M Notes/Comments ²² <small>PWS note any equipment breakdown, off-line status, changes in purchased product or batch mixing day, measured parameters or dosages that are out of target range, etc.</small> | |
|-------|---|--|--------------------------------|--|--------------------------------------|---|---|---|---|--|
| | | Volume ¹⁷ (gal/day) | Weight ¹⁷ (lbs/day) | | | a. <i>FINISHED</i> b. c. | | | | |
| | | | | | | <input checked="" type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | <input type="checkbox"/> G <input type="checkbox"/> A | | |
| 1 | <i>2.5</i> | | | | | <i>7.10</i> | | | | |
| 2 | <i>2.4</i> | | | | | <i>7.00</i> | | | | |
| 3 | <i>2.3</i> | | | | | <i>7.05</i> | | | | |
| 4 | <i>2.3</i> | | | | | <i>7.15</i> | | | | |
| 5 | <i>2.4</i> | | | | | <i>7.10</i> | | | | |
| 6 | <i>2.2</i> | | | | | <i>7.00</i> | | | | |
| 7 | <i>2.0</i> | | | | | <i>7.15</i> | | | | |
| 8 | <i>2.4</i> | | | | | <i>7.20</i> | | | | |
| 9 | <i>2.3</i> | | | | | <i>7.10</i> | | | | |
| 10 | <i>2.4</i> | | | | | <i>7.05</i> | | | | |
| 11 | <i>2.3</i> | | | | | <i>7.15</i> | | | | |
| 12 | <i>1.5</i> | | | | | <i>7.00</i> | | | | |
| 13 | <i>2.8</i> | | | | | <i>7.05</i> | | | | |
| 14 | <i>2.7</i> | | | | | <i>7.15</i> | | | | |
| 15 | <i>3.0</i> | | | | | <i>7.10</i> | | | | |
| 16 | <i>2.7</i> | | | | | <i>7.05</i> | | | | |
| 17 | <i>2.5</i> | | | | | <i>7.15</i> | | | | |
| 18 | <i>2.5</i> | | | | | <i>7.00</i> | | | | |
| 19 | <i>2.6</i> | | | | | <i>7.10</i> | | | | |
| 20 | <i>2.6</i> | | | | | <i>7.05</i> | | | | |
| 21 | <i>2.8</i> | | | | | <i>7.15</i> | | | | |
| 22 | <i>2.8</i> | | | | | <i>7.05</i> | | | | |
| 23 | <i>3.0</i> | | | | | <i>7.00</i> | | | | |
| 24 | <i>2.7</i> | | | | | <i>7.15</i> | | | | |
| 25 | <i>3.0</i> | | | | | <i>7.00</i> | | | | |
| 26 | <i>2.8</i> | | | | | <i>7.05</i> | | | | |
| 27 | <i>2.8</i> | | | | | <i>7.10</i> | | | | |
| 28 | <i>2.7</i> | | | | | <i>7.05</i> | | | | |
| 29 | <i>2.8</i> | | | | | <i>6.95</i> | | | | |
| 30 | <i>2.8</i> | | | | | <i>7.05</i> | | | | |
| 31 | <i>2.7</i> | | | | | <i>7.00</i> | | | | |
| Total | | Indicate total # of days the residual was off-target for the month (from Section II) Monthly Target Summary²³: | | | | | | | | |

¹Describe result (daily average, min/max, instantaneous reading, grab, etc), sample location (entry-point, before/after filters, tanks, etc.) and instrumentation used (SCADA, chart recorder, test kit, bench, etc.)²⁰:

a. *Finished Water Ph. Daily Average, Test Kit*

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Person, Signature & Date²⁴:
William Coakley *2-4-2020*
 Print Name: *William Coakley* Title: *Chief Operator*

Massachusetts Department of Environmental Protection - Drinking Water Program

TOC

Total Organic Carbon Report

PWS Information: Please refer to your DEP Water Sampling Schedule (WQSS) to help complete this form.

PWS ID #: 4244001

City/Town: Holbrook

PWS Name: Randolph-Holbrook Joint Water Board

PWS Class: COM X NTNC NC

| DEP location ID | DEP location name | Sample Information | | Collected | | Collected by |
|---------------------------|--|---|--|---|-------|------------------------------------|
| | | | | Date | Time | |
| A 01S | Raw Water | <input type="checkbox"/> Multiple <input checked="" type="checkbox"/> Single | <input checked="" type="checkbox"/> Raw <input type="checkbox"/> Finished | 01/06/2020 | 09:00 | B. Cookerly |
| B 10300 | Combined Filter Effluent | <input type="checkbox"/> Multiple <input checked="" type="checkbox"/> Single | <input type="checkbox"/> Raw <input checked="" type="checkbox"/> Finished | 01/06/2020 | 09:00 | B. Cookerly |
| Routine or Special Sample | | Original or Resubmitted or Confirmation Report | | If resubmitted report, list below: | | |
| | | | | Reason for resubmission: | | Collection date of original sample |
| A | <input checked="" type="checkbox"/> RS <input type="checkbox"/> SS | <input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted | | <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Corr. | | |
| B | <input checked="" type="checkbox"/> RS <input type="checkbox"/> SS | <input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted | | <input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Corr. | | |
| Lab sample notes: | | | | | | |
| A | | | | | | |
| B | | | | | | |

II. Analytical Laboratory Information:

Primary Lab MA Cert. # M-MA022

Primary Lab name: Analytical Balance Corp.

Subcontracted? Y N

| TOC analyzed by (check one): <input type="checkbox"/> PWS <input checked="" type="checkbox"/> Lab | | | Samples acidified? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | |
|---|------------|------------|--|-------------------------|-------------------|-----------------|
| TOC result (mg/L) | MDL (mg/L) | Lab Method | Date Analyzed | Analysis Lab MA Cert. # | Analysis Lab Name | Lab Sample ID # |
| A 5.56 | 0.5 | SM 5310B | 01/08/2020 | M-R1002 | ESS | 43650-01 |
| B 3.34 | 0.5 | SM 5310B | 01/08/2020 | M-R1002 | ESS | 43650-02 |

Surface water or GWUDI systems > 500 persons
 Monthly source (raw) water TOC samplings required at each surface/GWUDI source to qualify for and remain on reduced THM/HAA5 monitoring.
 Each source must maintain a running annual average source (raw) water TOC level of ≤ 4.0 mg/L (calculated quarterly).
 TOC analysis does not require the use of a Massachusetts or EPA certified laboratory.
 Surface or GWUDI sources using conventional filtration shall each month (unless monitoring is reduced): take one TOC sample at each treatment plant no later than the point of combined filter effluent turbidity monitoring representative of the treated (finished) water, one source (raw) sample prior to any treatment, and one alkalinity source (raw) water sample - at a time representative of normal operating conditions and influent water quality.
 The time between collection of raw and treated (finished) water must not exceed the time it takes to move through the plant.

| Alkalinity analyzed by (check one): <input type="checkbox"/> PWS <input checked="" type="checkbox"/> Lab | | | | | | |
|--|------------|------------|---------------|-------------------------|--------------------|-----------------|
| Alkalinity result (mg/L as CaCO ₃) | MDL (mg/L) | Lab Method | Date Analyzed | Analysis Lab MA Cert. # | Analysis Lab Name | Lab Sample ID # |
| A 23.0 | 4 | SM 2320B | 01/17/2020 | M-MA022 | Analytical Balance | 43650-01 |
| B — | — | — | — | — | — | — |

If using conventional filtration - raw water alkalinity must be measured at the same time as the raw water TOC sample is collected.
 Alkalinity analysis does not require the use of a Massachusetts or EPA certified laboratory.

| Lab sample notes: | | | | | | |
|-------------------|--|--|--|--|--|--|
| A | | | | | | |
| B | | | | | | |

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Robert E. Bentley

Digitally signed by Robert E. Bentley
 DN=Robert E. Bentley
 O=Analytical Balance Corp.
 E=rob@h2otest.net
 254414

Primary Lab Director Signature/Date: 01/27/2020

p. 1 of 1

If not submitting these results electronically, mail TWO copies of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

| DEP REVIEW/STATUS (Initial & date) | Review comments | WQTS data entered |
|------------------------------------|-----------------|-------------------|
| Accepted _____ Disapproved _____ | | |



Keith Nastasia
 Randolph-Holbrook Joint Water Board
 50 N. Franklin Street
 Holbrook, MA 02343
 COLLECTED BY: B. Cookerly
 TIME: 9:00
 LOCATION: Raw Water
 OIS

REPORTED: 01/16/2020
 ORDER #: G2043648
 SAMPLE DATE: 1/6/2020
 DATE RECEIVED: 1/6/2020
 SAMPLE ID: Special
 DESCRIPTION: DRINKING WATER

CERTIFICATE OF ANALYSIS

RESULTS OF ANALYSIS

| Parameter | Analytical Method | Date Analyzed | Units | Det. Limit* | MCL ¹ / Rec. Limit ² | Result |
|---------------------------------|-------------------|---------------|--------------|---------------------|--|--------|
| <i>Test Parameters</i> | | | | LAB-ID#: 2043648-01 | | |
| Carbon, Total Dissolved Organic | SM 5310B | 01/08/2020 | mg/L | 0.500 | --- | 5.57 |
| SUVA | Calculation | 01/15/2020 | # per 100 mL | 0 | 0 | 0.017 |
| UV 254 | SM 5910B | 01/07/2020 | Abs/cm | 0.002 | ----- | 0.097 |

DOC and UV254 analyzed by sub contract lab M-RI002.



CERTIFICATE OF ANALYSIS

Keith Nastasia
 Randolph-Holbrook Joint Water Board
 50 N. Franklin Street
 Holbrook, MA 02343

COLLECTED BY: B. Cookerly
 TIME: 9:00
 LOCATION: Combined Filter Effluent
 10300

REPORTED: 01/16/2020
 ORDER #: G2043648
 SAMPLE DATE: 1/6/2020
 DATE RECEIVED: 1/6/2020
 SAMPLE ID: Special
 DESCRIPTION: DRINKING WATER

RESULTS OF ANALYSIS

| Parameter | Analytical Method | Date Analyzed | Units | Det. Limit* | MCL ¹ / Rec. Limit ² | Result |
|---------------------------------|-------------------|---------------|--------------|-------------|--|--------------|
| LAB-ID#: 2043648-02 | | | | | | |
| <i>Test Parameters</i> | | | | | | |
| Carbon, Total Dissolved Organic | SM 5310B | 01/08/2020 | mg/L | 0.500 | ---- | 3.17 |
| SUVA | Calculation | 01/15/2020 | # per 100 mL | 0 | 0 | 0.011 |
| UV-254 | SM 5910B | 01/07/2020 | Abs/cm | 0.002 | ----- | 0.036 |

DOC and UV254 analyzed by sub contract lab M-RI002.

NA = Not Applicable
 ND = Not Detected
 < = Less Than
 * = Detection Limit

Approved By: Timothy A. Begley
 Lab Manager / Date

Digitally signed by Timothy A. Begley
 CN=Timothy A. Begley
 2.5.4.11=...
 Date: 2020.01.16 21:34:53

1. MCL = Maximum Contaminant Level as adopted by the Commonwealth of Massachusetts and represents the maximum acceptable level in drinking water.
2. Recommended limits are suggested levels of materials allowed in water. These may be for aesthetic reasons rather than for human health.
3. Currently there are no limits (recommended or mandated) for this parameter. This is merely presented for guidance.
4. If present, coliform values (in parentheses) are defined as estimated numbers.



DBPR TT Compliance Report

PWS INFORMATION

PWS ID #: 4244001 City/Town: RANDOLPH
PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM X NTNC TNC

Table with columns: DEP LOCATION/LOC ID, DEP Location Name, Date Collected, Collected By. Row 1: 015/10300 Raw Water/Combined Filter Effluent, 1-6-2020, Bill Cookerby

COMPLIANCE CALCULATIONS

Table with columns: Month, # of Paired Samples, A: % Removal of TOC, B: Required % Removal of TOC, Met Alternative Compliance Criteria, Alternative Criteria Result(s), A+B. Includes monthly data from 2-19 to 1-20 and a summary row for the past 12 months.

penalty under penalties... available in the... contained herein... complete the best extension available...

PWS Authorized Signature: [Signature] Date: 2-13-2020

Mail ONE copy of this report to your DEP Regional Office no later than 10 days after the end of the month in which you received this report or no later than 10 days after the end of the reporting period, whichever is sooner.

1 Percent Removal: (1 - (Treated Water TOC + Raw Water TOC)) x 100. If > 1 paired sample sets in any month report the average of all individual percent TOC removals... 2 From table at 310-CMR 22.07E(10)(b)2. 3 As listed at 310 CMR 22.07E(10)(a)2 and 310 CMR 22.07E(10)(a)3, summarized as follows:

Table with columns: Alternative Compliance Criteria, Code Value, Result(s) to Report (RAA - Running Annual Average). Rows include Source Water TOC, Treated Water TOC, Source Water TOC and Alkalinity, TTHM/HAA5, Source Water SUVA, Treated Water SUVA, Softening that lowers alkalinity, Softening that removes hardness.

For any month where the system met an alternative compliance criteria a value of 1.0 may be inserted.

DEP REVIEW STATUS (Initial & Date) Accepted [] Disapproved [] Review Comments



Massachusetts Department of Environmental Protection - Drinking Water Program
 TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR
 J.

(Page 2 of 2)

II. DAILY REPORTING

| Day | Filter Number: 1 | | Filter Number: 2 | | Filter Number: 3 | | Filter Number: 4 | |
|-----|------------------|-----------------------|------------------|-----------------------|------------------|-----------------------|------------------|-----------------------|
| | Max Day NTU | Max after 4 Hours NTU | Max Day NTU | Max after 4 Hours NTU | Max Day NTU | Max after 4 Hours NTU | Max Day NTU | Max after 4 Hours NTU |
| 1 | .13 | .06 | OUT OF SERVICE | | .08 | .04 | .06 | .05 |
| 2 | .20 | .17 | | | .10 | .06 | .18 | .06 |
| 3 | .17 | .05 | | | .08 | .05 | .16 | .05 |
| 4 | .12 | .05 | | | .13 | .06 | .24 | .10 |
| 5 | .22 | .06 | | | .23 | .08 | .07 | - |
| 6 | .14 | .08 | | | .20 | .06 | .12 | .06 |
| 7 | .20 | .09 | | | .15 | .05 | .17 | .05 |
| 8 | .18 | .05 | | | .08 | .05 | .07 | .05 |
| 9 | .12 | .07 | | | .10 | .05 | .11 | .06 |
| 10 | .16 | .07 | | | .15 | .06 | .21 | .07 |
| 11 | .13 | .08 | | | .16 | .08 | .24 | .09 |
| 12 | .05 | - | | | .06 | - | .06 | - |
| 13 | .11 | .06 | | | .16 | .05 | .09 | .07 |
| 14 | .10 | .05 | | | .09 | .07 | .12 | .06 |
| 15 | .09 | .05 | | | .10 | .04 | .09 | .05 |
| 16 | .07 | .05 | | | .06 | .05 | .08 | .05 |
| 17 | .12 | .06 | | | .08 | .05 | .07 | .04 |
| 18 | .06 | - | | | .07 | - | .10 | .06 |
| 19 | .14 | .07 | | | .10 | .05 | .14 | .08 |
| 20 | .12 | .07 | | | .13 | .08 | .11 | .08 |
| 21 | .11 | .07 | | | .12 | .08 | .10 | .05 |
| 22 | .12 | .06 | | | .09 | .05 | .09 | .05 |
| 23 | .15 | .05 | | | .16 | .07 | .06 | - |
| 24 | .16 | - | | | .08 | - | .14 | .07 |
| 25 | .16 | .06 | | | .17 | .05 | .27 | .07 |
| 26 | .19 | .06 | | | .14 | .08 | .08 | - |
| 27 | .14 | .06 | | | .07 | .04 | .14 | .06 |
| 28 | .12 | .06 | | | .12 | .05 | .17 | .06 |
| 29 | .07 | .06 | | | .07 | .05 | .07 | .04 |
| 30 | .05 | - | | | .08 | - | .15 | .07 |
| 31 | .08 | .05 | | | .13 | .07 | .07 | .05 |

- Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.
- Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.
- Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
- Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

I certify under penalties of law that I am the person authorized to put this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

PWS Authorized Signature: William Cooper
 Date: 2-4-2020 Title: Chief Plant Operator



Massachusetts Department of Environmental Protection - Drinking Water Program
TURBIDITY - INDIVIDUAL FILTER MONITORING
 For Conventional or Direct Filtered Systems

SWTR

J

(Page 2 of 2)

III. DAILY REPORTING

| Day | Filter Number: 5 | | Filter Number: 6 | | Filter Number: 7 | | Filter Number: 8 | |
|-----|------------------|-----------------------|------------------|-----------------------|------------------|-----------------------|------------------|-----------------------|
| | Max Day NTU | Max after 4 Hours NTU | Max Day NTU | Max after 4 Hours NTU | Max Day NTU | Max after 4 Hours NTU | Max Day NTU | Max after 4 Hours NTU |
| 1 | .05 | .04 | .05 | .04 | .15 | .07 | .10 | .05 |
| 2 | .10 | .06 | .11 | .08 | .11 | - | .12 | .05 |
| 3 | .13 | .04 | .18 | - | .12 | .06 | .08 | .04 |
| 4 | .08 | - | .14 | .05 | .15 | .07 | .08 | .04 |
| 5 | .10 | .05 | .16 | .05 | .11 | .07 | .15 | .07 |
| 6 | .11 | .06 | .17 | .08 | .14 | .09 | .07 | .04 |
| 7 | .15 | .07 | .26 | .05 | .11 | .06 | .06 | - |
| 8 | .07 | .05 | .23 | .06 | .11 | .06 | .09 | .04 |
| 9 | .10 | .05 | .22 | .06 | .06 | - | .12 | .04 |
| 10 | .13 | .05 | .24 | .09 | .15 | .07 | .10 | .07 |
| 11 | .16 | - | .13 | - | .15 | .07 | .14 | .08 |
| 12 | .16 | .05 | .18 | .08 | .09 | .07 | .07 | - |
| 13 | .22 | .08 | .13 | .08 | .06 | - | .13 | .05 |
| 14 | .09 | .06 | .13 | .06 | .16 | .08 | .08 | .05 |
| 15 | .11 | .07 | .13 | .07 | .13 | .08 | .08 | .04 |
| 16 | .12 | .06 | .06 | - | .12 | .06 | .07 | .04 |
| 17 | .04 | - | .17 | .08 | .12 | .08 | .06 | .04 |
| 18 | .15 | .07 | .14 | .08 | .13 | .08 | .14 | .08 |
| 19 | .12 | .07 | .16 | .09 | .07 | - | .04 | - |
| 20 | .11 | .08 | .08 | - | .13 | .07 | .13 | .04 |
| 21 | .12 | .06 | .19 | .08 | .14 | .07 | .11 | .05 |
| 22 | .08 | .05 | .11 | .06 | .15 | .07 | .11 | .06 |
| 23 | .06 | - | .17 | .07 | .14 | .06 | .13 | .06 |
| 24 | .14 | .06 | .13 | .07 | .10 | .06 | .08 | .05 |
| 25 | .19 | .06 | .09 | - | .06 | - | .04 | - |
| 26 | .05 | - | .13 | .06 | .11 | .06 | .10 | .04 |
| 27 | .09 | .05 | .21 | - | .10 | .07 | .07 | .05 |
| 28 | .08 | .05 | OUT OF SERVICE | | .12 | .09 | .06 | .04 |
| 29 | .07 | .04 | | | .13 | .08 | .10 | .05 |
| 30 | .14 | .06 | | | .10 | .07 | .09 | .05 |
| 31 | .07 | .04 | | | .09 | .06 | .05 | - |

Systems shall conduct continuous turbidity monitoring of the filter effluent for each individual filter at the filtration facility and record turbidity measurements every 15-minutes. Record the actual turbidity result at the specified interval of time. Do not average turbidity measurements. Individual filter turbidity records must be retained for 3 years and kept on file for MassDEP review.

Systems serving less than 10,000: If the treatment system has only one or two filters, the supplier may conduct continuous monitoring of the CFE turbidity in lieu of individual filter effluent (IFE) turbidity monitoring. If there are two filters, a continuous turbidity monitor can be installed on the combined filter effluent. If a CFE problem appears, follow-up action must then be completed on both filters.

Enter the highest daily 15-minute interval turbidity measurement recorded for the filter specified.
 Enter the highest daily 15-minute interval turbidity measurement recorded at the end of the first four hours of continuous filter operation after the filter has been backwashed or otherwise taken offline.

Under penalties of law that I am the person authorized to sign this form and the information contained herein is true, correct and complete to the best extent of my knowledge.

PWS Authorized Signature: William Coakley
 Date: 2-4-2020 Title: Chief Plant Operator



Massachusetts Department of Environmental Protection - Drinking Water Program
CHLORINE/CHLORAMINES - MONTHLY REPORT

CI

I. PWS INFORMATION:

PWS ID #: **4133000** PWS Name: **TOWN OF HOLBROOK** City/Town: **HOLBROOK** Class: COM NTNC TNC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DBPR monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl: D E F G H I ASTM D1253-86

Notes:

| DEP APPROVED SAMPLE SITE INFORMATION ¹ | | CHLORINE RESULT ² (mg/L) | COLLECTION AND ANALYSIS ³ | | COLLECTED AND ANALYZED BY: |
|---|---|-------------------------------------|--------------------------------------|-------|----------------------------|
| DEP Sample Type ⁴ | DEP Approved SAMPLE LOCATION ¹ | | DATE | TIME | |
| RS 001 | TOWN HALL | 0.7 | 1/6/2020 | 07:09 | T. Duggan |
| RS 004 | COTTAGE VARIETY | 0.7 | 1/6/2020 | 08:10 | T. Duggan |
| RS 005 | AGAPE INN | 0.6 | 1/6/2020 | 09:22 | T. Duggan |
| RS 006 | COMMUNITY CENTER | 0.2 | 1/6/2020 | 07:34 | T. Duggan |
| RS 001 | TOWN HALL | 0.7 | 1/13/2020 | 07:09 | T. Duggan |
| RS 004 | COTTAGE VARIETY | 1.3 | 1/13/2020 | 08:02 | T. Duggan |
| RS 005 | AGAPE INN | 0.6 | 1/13/2020 | 08:43 | T. Duggan |
| RS 006 | COMMUNITY CENTER | 0.2 | 1/13/2020 | 07:38 | T. Duggan |
| RS 001 | TOWN HALL | 0.7 | 1/22/2020 | 07:09 | T. Duggan |
| RS 004 | COTTAGE VARIETY | 0.9 | 1/22/2020 | 07:52 | T. Duggan |
| RS 005 | AGAPE INN | 0.7 | 1/22/2020 | 08:32 | T. Duggan |
| RS 006 | COMMUNITY CENTER | 0.2 | 1/22/2020 | 07:30 | T. Duggan |
| RS 001 | TOWN HALL | 0.7 | 1/27/2020 | 07:09 | T. Duggan |
| RS 004 | COTTAGE VARIETY | 0.9 | 1/27/2020 | 08:03 | T. Duggan |
| RS 005 | AGAPE INN | 0.7 | 1/27/2020 | 08:32 | T. Duggan |
| RS 006 | COMMUNITY CENTER | 0.3 | 1/27/2020 | 07:32 | T. Duggan |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

¹ DEP Sample Type, Location Code#, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan.
² SWTR systems: HPC must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form.
³ Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record ND values as 0 (zero).
⁴ Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP).
⁵ All DISTRIBUTION samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month⁵: **66** Average Chlorine Result of All Samples For Month⁵ (mg/L): **1.07**

I certify, under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature and Date: *William W. [Signature]* 2-13-2020

DEP Review Status: Accepted Disapproved Review Comments:

CHLORINE/CHLORAMINES - MONTHLY REPORT

1. PWS INFORMATION:

PWS ID #: 4244000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: COW NTNG TNG

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DEPR monitoring plan to help complete this section.
 Analytical Method: SM 4500-Cl D E F G H I ASTM D1253-06

Type Measured: Free Chlorine Total Chlorine Combined Chlorine

Notes:

| DEP Sample Type | DEP Location Code | DEP APPROVED SAMPLE SITE INFORMATION | | CHLORINE RESULT (mg/L) | COLLECTION AND ANALYSIS | | COLLECTED AND ANALYZED BY |
|-----------------|-------------------|--------------------------------------|------------------------------|------------------------|-------------------------|----------|---------------------------|
| | | DEP Approved Sample Location | DEP Approved Sample Location | | DATE | TIME | |
| RS | 000 | TOWER HILL SCHOOL | ADAMS STREET | 1.40 | 1-6-20 | 9:55 AM | A. PIERRE-LONIS |
| RS | 004 | JFK SCHOOL | 20 HURLEY DRIVE | 1.09 | 1-6-20 | 8:15 AM | |
| RS | 006 | MARTIN E. YOUNG SCHOOL | COURTNEY DRIVE | .80 | 1-6-20 | 7:45 AM | |
| RS | 006 | CAMPBELL INN | 1874 NORTH MAIN STREET | .05 | 1-6-20 | 10:45 AM | |
| RS | 008 | NORTH MIDDLE SCHOOL | HIGH STREET | 1.31 | 1-6-20 | 10:20 AM | |
| RS | 011 | MOBIL STATION | 93 MAZZEO DRIVE | 1.20 | 1-6-20 | 9:30 AM | |
| RS | 012 | 7-11 FOOD SHOP | 676 NORTH STREET | .75 | 1-6-20 | 8:40 AM | |
| RS | 014 | EXPERIENCE | 277 NORTH MAIN STREET | 1.40 | 1-6-20 | 9:10 AM | |
| RS | | OAK GROVE STANDPIPE | | 1.01 | 1-6-20 | 11:40 AM | |
| RS | | SOUTH MAIN STREET STANDPIPE | | 1.05 | 1-6-20 | 12:05 PM | |

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan.
 SWTR systems (PC) may be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form.
 Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record MD values as 0 (zero).
 Sample Type: RS-Routine Distribution Sample, RC-Original Site Repeat, UP-Untreated Repeat, AR-Additional Repeat, or SS-Special Sample (as determined by DEP).
 All electrical system samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect representative samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples, DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total Vol of Samples Collected for Month: 166 Average Chlorine Residual for Month: 1.07
 I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.
 Primary Certified Operator Signature and Date: William Corbett 2-10-2020

DEP Review Status: Accepted Disapproved Review Comments:

CHLORINE CHLORAMINES - MONTHLY REPORT

I. PWS INFORMATION:

PWS ID #: 4241000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: CCM NTNG TNG

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DEP's monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl: D E F G H I ASTM D1269-06

Notes:

| DEP Sample Type | DEP Location Code | DEP APPROVED SAMPLE SITE INFORMATION | | CHLORINE RESULT (mg/L) | COLLECTION AND ANALYSIS | | COLLECTED AND ANALYZED BY: |
|-----------------|-------------------|--------------------------------------|------------------------------|------------------------|-------------------------|----------|----------------------------|
| | | DEP Approved Sample Location | DEP Approved Sample Location | | DATE | TIME | |
| RS | 003 | TOWER HILL SCHOOL | ADAMS STREET | 1.46 | 1-13-20 | 10:00 AM | A. PIERRE-LOUIS |
| RS | 004 | JFK SCHOOL | 20 HURLEY DRIVE | 1.47 | 1-13-20 | 8:00 AM | |
| RS | 006 | MARTIN E. YOUNG SCHOOL | COURTNEY DRIVE | 0.72 | 1-13-20 | 7:30 AM | |
| RS | 006 | CHAMPLAIN INN | 1874 NORTH MAIN STREET | 0.88 | 1-13-20 | 11:00 AM | |
| RS | 008 | NORTH MIDDLE SCHOOL | HIGH STREET | 1.67 | 1-13-20 | 10:30 AM | |
| RS | 011 | MOBI. STATION | 83 MAZZEO DRIVE | 1.39 | 1-13-20 | 9:30 AM | |
| RS | 012 | 7-11 | FOOD SHOP 676 NORTH STREET | 1.00 | 1-13-20 | 8:30 AM | |
| RS | 014 | EVERYKING | 277 NORTH MAIN STREET | 1.62 | 1-13-20 | 9:00 AM | |
| RS | | OAK GROVE | STANDPIPE | 1.22 | 1-13-20 | 12:10 PM | |
| RS | | SOUTH MAIN STREET | STANDPIPE | 1.07 | 1-13-20 | 12:45 PM | |

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan. SWTR systems (PWS) must be collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form. Collection and Analysis: Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record MP values as 0 (zero). Sample Type: RS: Routine Distribution Sample, RO: Original Site Report, DT: Distribution Report, DT-Posttreatment Report, AT: Additional Report, or SS: Special Sample (as determined by DEP). All distribution samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect residual coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include these samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month: 66 Average Chlorine Result of All Samples for Month (mg/L): 1.07

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator's Signature and Date: William Carbery 2-10-2020

DEP Review Status: Disapproved Accepted Review Comments:

CHLORINE CHLORAMINES - MONTHLY REPORT

1. PWS INFORMATION:

PWS ID #: 424000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: COM NTNC TMC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DEP's monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl D E F G H I ASTM D1243-86

Notes:

| DEP Sample Type | DEP Location Code # | DEP APPROVED SAMPLE SITE INFORMATION | | CHLORINE RESULT (mg/L) | COLLECTION AND ANALYSIS ¹ | | COLLECTED AND ANALYZED BY |
|-----------------|---------------------|---|---|------------------------|--------------------------------------|----------|---------------------------|
| | | DEP Approved Sample Location ¹ | DEP Approved Sample Location ¹ | | DATE | TIME | |
| RS | 000 | TOWER HILL SCHOOL | ADAMS STREET | 1.37 | 1-15-20 | 9:50 AM | A. PIERRE - LOUIS |
| RS | 004 | JFK SCHOOL | 20 HURLEY DRIVE | 1.42 | 1-15-20 | 8:00 AM | |
| RS | 006 | MARTIN E. YOUNG SCHOOL | COURTNEY DRIVE | 1.06 | 1-15-20 | 7:40 AM | |
| RS | 008 | CLYDEMAN INN | 1874 NORTH MAIN STREET | 1.18 | 1-15-20 | 10:40 AM | |
| RS | 008 | NORTH MIDDLE SCHOOL | HIGH STREET | 1.49 | 1-15-20 | 10:15 AM | |
| RS | 011 | MOBIL STATION | 83 MAZZEO DRIVE | 1.29 | 1-15-20 | 9:30 AM | |
| RS | 012 | 7-11 | FOOD SHOP 876 NORTH STREET | .87 | 1-15-20 | 8:30 AM | |
| RS | 014 | EVERHASE | 277 NORTH MAIN STREET | 1.38 | 1-15-20 | 9:00 AM | |
| RS | | OAK GROVE | STANDPIPE | 1.41 | 1-15-20 | 12:00 PM | |
| RS | | SOUTH MAIN STREET | STANDPIPE | 1.37 | 1-15-20 | 12:20 PM | |

¹ DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan.
² SWTR systems that are not collected at distribution sites with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report form and on the appropriate SWTR Form.
³ Collection and Analytical Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record MD values as 0 (zero).
⁴ Sample Type: RS-Routine Distribution Sample, RO-Original Site Report, UR-Upstream Report, DR-Distribution Report, AR-Additional Report, or SS-Special Sample (as determined by DEP).
⁵ All BACTERIOLOGICAL samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect repeat coliform samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include those samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total # of Samples Collected for Month: 66 Average Chlorine Residual of All Samples for Month: (mg/L): 1.07

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Personnel Certified Operator Signature and Date: *William Carney* 2-10-2020

DEP Review Status: Accepted Disapproved Review Comments:



CHLORINE CHLORAMINES - MONTHLY REPORT

1. PWS INFORMATION:

PWS ID #: 42244000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: COW NTWC TWC

II. ANALYTICAL INFORMATION: Refer to your MassDEP Coliform Sampling Plan and/or DEPR monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SM 4500-Cl D E F G H I ASTM D1259-06

Notes:

| DEP Sample Type | DEP Location Code | DEP APPROVED SAMPLE SITE INFORMATION | | CHLORINE RESULT (mg/L) | COLLECTION AND ANALYSIS | | COLLECTED AND ANALYZED BY |
|-----------------|-------------------|--------------------------------------|------------------------------|------------------------|-------------------------|---------|---------------------------|
| | | DEP Approved Sample Location | DEP Approved Sample Location | | DATE | TIME | |
| RS | 003 | TOWER HILL SCHOOL | ADAMS STREET | 1.35 | 1-22-20 | 10:05AM | A. PIERRE-LOUIS |
| RS | 004 | JFK SCHOOL | 20 HURLEY DRIVE | 1.39 | 1-22-20 | 8:30AM | |
| RS | 006 | MARTIN E. YOUNG SCHOOL | COURTNEY DRIVE | 1.03 | 1-22-20 | 7:50AM | |
| RS | 009 | CHRYSLER INN | 1374 NORTH MAIN STREET | 1.36 | 1-22-20 | 11:00AM | |
| RS | 008 | NORTH MIDDLE SCHOOL | HIGH STREET | 1.55 | 1-22-20 | 10:30AM | |
| RS | 011 | MOBIL STATION | 83 MAZZEO DRIVE | 1.38 | 1-22-20 | 9:35AM | |
| RS | 012 | 7-11 | FOOD SHOP 678 NORTH STREET | 1.03 | 1-22-20 | 8:45AM | |
| RS | 014 | EXPERIENCE | 777 NORTH MAIN STREET | 1.52 | 1-22-20 | 9:10AM | |
| RS | | OAK GROVE STANDPIPE | | 1.19 | 1-22-20 | 12:50PM | |
| RS | | SOUTH MAIN STREET STANDPIPE | | 1.04 | 1-22-20 | 1:30PM | |

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site. DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site. DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site.

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site. DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site.

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site. DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site.

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site. DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system, or a DEP approved sampling site.

CHLORINE CHLORAMINES - MONTHLY REPORT

1. PWS INFORMATION:

PWS ID #: 424000 PWS Name: RANDOLPH WATER DEPARTMENT City/Town: RANDOLPH Class: NTNG TNG

II. ANALYTICAL INFORMATION: Refer to your Mass DEP Coliform Sampling Plan and/or DEPR monitoring plan to help complete this section.

Type Measured: Free Chlorine Total Chlorine Combined Chlorine Analytical Method: SW 4500-Cl D E G H I ASTM D1223-06

Notes:

| DEP Sample Type | DEP Location Code | DEP APPROVED SAMPLE SITE INFORMATION | | CHLORINE RESULT (mg/L) | COLLECTION AND ANALYSIS | | COLLECTED AND ANALYZED BY: |
|-----------------|-------------------|--------------------------------------|------------------------------|------------------------|-------------------------|-------|----------------------------|
| | | DEP Approved Sample Location | DEP Approved Sample Location | | DATE | TIME | |
| RS | 003 | TOWER HILL SCHOOL | ADAMS STREET | 1.47 | 1-27-20 | 9:30 | S |
| RS | 004 | JFK SCHOOL | 20 HURLEY DRIVE | 1.99 | | 8:20 | |
| RS | 005 | MARTIN E. YOUNG SCHOOL | COURTNEY DRIVE | .91 | | 7:40 | |
| RS | 006 | EMERALD INN | 1374 NORTH MAIN STREET | 1.47 | | 9:00 | |
| RS | 008 | NORTH MIDDLE SCHOOL | HIGH STREET | 1.43 | | 10:00 | |
| RS | 011 | MOBIL STATION | 83 MAZZEO DRIVE | 1.39 | | 9:40 | |
| RS | 012 | FOOD SHOP | 876 NORTH STREET | .88 | | 8:00 | |
| RS | 014 | EMERALD INN | 277 NORTH MAIN STREET | 1.45 | | 11:00 | |
| RS | | OAK GROVE STANDPIPE | | 1.16 | | 3:00 | |
| RS | | SOUTH MAIN STREET STANDPIPE | | .73 | | 2:30 | |

DEP Sample Type, Location Code, and DEP Approved Sample Site Location must correspond to the same information on your DEP Total Coliform Sampling Plan, a SWTR system. DEPRs must be collected at distribution also with zero chlorine residual and results reported on the DEP Bacteriological Monthly Report, form and on the appropriate SWTR Form.

Collection and Analytical Chlorine residual shall be measured in the field (immediately upon collection) at the same time and location in the distribution system as total coliforms are sampled. Record MD values as 0 (zero).

Sample Type: RS=Residual Chlorine Sample, FC=Original Site Report, DE=Disinfection Report, AD=Additional Report, or BS=Special Sample (as determined by DEPR).

All distribution samples taken and analyzed shall be included in determining compliance, even if that number is greater than the minimum required. If you collect representative samples within the distribution system during the month, you must also measure for a detectable chlorine residual at the repeat sites and include those samples. DO NOT include raw water (RW) or plant tap (PT) chlorine residual samples in your calculations.

III. COMPLIANCE REPORTING: Total % of Samples Collected for Month: 66 Average Chlorine Result of All Samples for Month: 1.07

I hereby certify that I am the person authorized to fill out this report and the information contained herein is true, accurate and complete to the best of my knowledge.

DEPR Review Status: Accepted Disapproved Review Comments:

Primary Certified Operator Signature and Date: William Carney 2-10-2020



Massachusetts Department of Environmental Protection - Drinking Water Program
Disinfection Byproducts Rule Compliance Report - DBPR

I. PWS INFORMATION: Please refer to your DBPR Monitoring Plan to help complete this form.

PWS ID #: 4244001 City / Town: RANDOLPH
 PWS Name: RANDOLPH-HOLBROOK JOINT WATER PWS Class: COM NTNC TNC
 Monitoring Period (YEAR): 2020 Monitoring Period (QUARTER): Q1 (Jan-Mar) Q2 (Apr-Jun) Q3 (Jul-Sep) Q4 (Oct-Dec)

II. FOR SYSTEMS USING CHLORINATION

A. Trihalomethanes (TTHM)
 Total Number of TTHM Samples: _____ Quarterly Average: _____ µg/L
 Was the Running Annual Average MCL (80 µg/L) exceeded? Yes No Running Annual Average: _____ µg/L

B. Haloacetic Acids (HAA5)
 Total Number of HAA5 Samples: _____ Quarterly Average: _____ µg/L
 Was the Running Annual Average MCL (60 µg/L) exceeded? Yes No Running Annual Average: _____ µg/L

C. Chlorine/Chloramines
 Total Number of Samples: _____ Monthly Averages: _____ mg/L
 Month 1: 106 JAN _____ mg/L
 Month 2: _____ FEB (report all 3 months per quarter) _____ mg/L
 Month 3: _____ MARCH _____ mg/L
 Quarterly Average: 1.07 mg/L
 Was the Running Annual Average MRDL (4.0 mg/L) exceeded? Yes No Running Annual Average: 0.88 mg/L

D. Total Organic Carbon - raw (TOC) (Required for SW or GWUDI Plant Name: _____
 systems >499 seeking or approved to reduce THM/HAA5 monitoring.)
 (Attach additional sheet(s) to report more than 1 plant)
 Total Number of Samples: _____ Monthly Averages: _____ mg/L
 Month 1: _____ (report all 3 months per quarter) _____ mg/L
 Month 2: _____ _____ mg/L
 Month 3: _____ _____ mg/L
 Quarterly Average: _____ mg/L
 Was the (4.0 mg/L) threshold exceeded? Yes No Running Annual Average: _____ mg/L

III. FOR SYSTEMS USING OZONATION - attach additional sheet(s) to report more than 1 plant

E. Bromate (treated) Plant Name: _____
 Total Number of Samples: _____ Monthly Averages: _____ mg/L
 Month 1: _____ (report all 3 months per quarter) _____ mg/L
 Month 2: _____ _____ mg/L
 Month 3: _____ _____ mg/L
 Quarterly Average: _____ mg/L
 Was the Running Annual Average MCL (0.010 ug/l) exceeded? Yes No Running Annual Average: _____ mg/L

F. Bromide (raw) Plant Name: _____
 Required for systems seeking or approved to reduce Bromate monitoring
 Total Number of Samples: _____ Monthly Averages: _____ mg/L
 Month 1: _____ (report all 3 months per quarter) _____ mg/L
 Month 2: _____ _____ mg/L
 Month 3: _____ _____ mg/L
 Quarterly Average: _____ mg/L
 Was the (0.05 mg/l) threshold exceeded? Yes No Running Annual Average: _____ mg/L

IV. FOR SYSTEMS USING CHLORINE DIOXIDE - Report compliance information on your Chlorine/Chlorine Dioxide (Daily Samples) Report

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Primary Certified Operator Signature: William Corbett Date: 2-13-2020

| DEFINITIONS | |
|--------------------------|--|
| MONTHLY AVERAGE: | Monthly average = average of all results within the current month. |
| QUARTERLY AVERAGE: | Quarterly Average = average result of all locations sampled during monitoring period |
| RUNNING ANNUAL AVERAGE: | Running Annual Average = Average of 4 quarters. Average of this quarter and three prior consecutive quarterly averages (for systems on quarterly monitoring) |
| TOTAL NUMBER OF SAMPLES: | Total number of samples collected during the monitoring period. |

NOTE: Record and calculate all ND or <MDL results as the number zero (0).

Submit one copy of this form each quarter to your DEP regional office (by Jan 10th, April 10th, July 10th, and Oct 10th of each year)

DEP REVIEW STATUS (Initial & Date)
 Accepted _____ Disapproved _____
 Review Comments _____