







**Town of Randolph
South Main Station Playground**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
Access to Goods and Services												
Doors, Doorways, & Gates												
1	Basketball Court	Ext.		Doors, Doorways, & Gates	Other		Gate requires excessive opening force.	20lbs	Adjust gate to require no more that 15 pounds of opening force.	1	0	\$0
Stairways												
2	Basketball Court	Ext.		Stairways	Other		Handrails do not extend 12" from stairs	-	Bottom: Ensure handrails extend to one tread depth beyond the last riser.	1	0	\$0
Exterior Benches												
3	Playground	Ext.		Exterior Benches	N/A		No accessible route to one bench in area	-	Provide an accessible route to at least one bench in this area.	1	0	\$0
Play and Sport Areas												
Play Areas												
4	Playground	Ext.		Play Areas	N/A		Accessible route not provided around playground		Provide a 48" wide min. accessible route around the perimeter of the play area inside the fence.	1	0	\$0

**Town of Randolph
South Main Station Playground**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
5	Playground	Ext.		Play Areas	N/A		Accessible route not provided to play components	-	Provide a compliant impact-attenuating surface to and around the play components.	1	0	\$0
Best Practice												
Parking by Basketball Court												
6	Basketball Court	Ext.		Parking by Basketball Court	N/A				Recommend providing a van accessible parking space near the accessible entrance to the basketball court.	1	0	\$0